

J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing



January 5, 2026

Mr. Craig Cammarata
Levittown Union Free School District
B&G Office
850 Seamans Neck Road
Seaford, New York 11783

1775 Expressway Drive North
Hauppauge, NY 11788
631.584.5492
Fax: 631.584.3395
www.jcbroderick.com

Re: **Lead Testing in School Drinking Water
Remedial Action Plan
2023-25 Compliance 10 NYCRR Subpart 67-4**

JCB#: **23-53783**

Dear Mr. Cammarata:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead in Water Remediation Plan
Attachment 2: Outlet Inventory and Lead Testing Results
Attachment 3: Laboratory Analytical Reports
Attachment 4: Laboratory Certifications

If you have any questions, or if more information is needed, please contact our office.

Sincerely,

Anthony Lombardo
J C Broderick & Associates, Inc.

Attachment 1:

Lead in Water Remediation Plan



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

If the lead concentration of water at an outlet exceeds the action level, the school shall:

(a) prohibit use of the outlet until:

*(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
(2) test results indicate that the lead levels are at or below the action level;*

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

Step 1A: Potable Outlets (Outlets intended to be used for drinking/cooking)


Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

Step 1B: Non-Potable Outlets (Outlets not intended for drinking/cooking)

See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead.pdf.



Do not use for drinking



Step 2: Service & Repair or Outlet Replacement

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

Step 3: Retesting & Return to Service

Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:

Outlet Inventory and Lead Testing Results



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395



Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

Page 1 of 126

JCB #: 23-53783

Levittown Union Free School District

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0001	Room 100A Orchestra Storage Room	1001A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0002	Room 103	1003	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0003	Room 103	1003	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0004	Room 103	1003	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0005	Room 105	1004	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0006	Room 105	1004	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0007	Room 105	1004	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0008	Room 102	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0009	Room 102	1008	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-0010	Film Darkroom	1008B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0011	Print Darkroom	1008C	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0012	Room 113A	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0013	Room 113A	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0022	Custodial Closet (Across Rm 113A)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0023	Women's Bathroom adj. Boiler Rm	1016	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0024	Women's Bathroom adj. Boiler Rm	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0025	Women's Bathroom adj. Boiler Rm	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0026	Women's Bathroom adj. Boiler Rm	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0027	Women's Bathroom adj. Boiler Rm	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0028	Women's Bathroom adj. Boiler Rm	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0029	Women's Bathroom adj. Boiler Rm	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0030	Women's Bathroom adj. Boiler Rm	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0031	Women's Bathroom adj. Boiler Rm	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0032	Women's Bathroom adj. Boiler Rm	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0033	Custodial Office Break Room	1024A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0034	Boy's Locker Room Coaches Office Bathroom	1032A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0035	Boy's Locker Room Coaches Office Bathroom	1034A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0036	Boy's Locker Room	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0037	Boy's Locker Room	1032	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0038	Boy's Locker Room	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0039	Boy's Locker Room	1032	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0045	Girl's Locker Room Coaches Office Bathroom	1038B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0046	Girl's Locker Room Coaches Office Bathroom	1038B1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0047	Girl's Locker Room Bathroom	1038D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0048	New Girls Locker Room Bathroom	1041A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0049	New Girls Locker Room Bathroom	1041A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0050	Gym Lobby Custodial Closet	1036	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0053	Room 221	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0054	Room 221	2009	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-0057	Cafeteria A Girl's Bathroom	2033A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0058	Cafeteria A Girl's Bathroom	2033A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0059	Cafeteria A Girl's Bathroom	2033A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0060	Cafeteria A Girl's Bathroom	2033A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0061	Cafeteria A Boy's Bathroom	2033B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0062	Cafeteria A Boy's Bathroom	2033B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0063	Cafeteria A Boy's Bathroom	2033B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0064	Custodial Room	2031	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0065	Girl's Bathroom Adj. Café A	2030	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0066	Girl's Bathroom Adj. Café A	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0067	Girl's Bathroom Adj. Café A	2030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0068	Girl's Bathroom Adj. Café A	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0069	Girl's Bathroom Adj. Café A	2030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0070	Girl's Bathroom Adj. Café A	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0071	Girl's Bathroom Adj. Café A	2030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0072	Girl's Bathroom Adj. Café A	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0073	Girl's Bathroom Adj. Café A	2030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0074	Girl's Bathroom Adj. Café A	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0075	Girl's Bathroom Adj. Café A	2030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0077	Boy's Bathroom Adj. Main Office	2028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0078	Boy's Bathroom Adj. Main Office	2028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0079	Boy's Bathroom Adj. Main Office	2028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0080	Boy's Bathroom Adj. Main Office	2028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0081	Boy's Bathroom Adj. Main Office	2028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0082	Boy's Bathroom Adj. Main Office	2028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0083	Boy's Bathroom Adj. Main Office	2028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0084	Boy's Bathroom Adj. Main Office	2028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0086	Former Room 217 (Reconstructed)	2012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0087	Former Room 217 (Reconstructed)	2012	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0092	Women's Bathroom Adj. Rm 200	2024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0093	Women's Bathroom Adj. Rm 200	2024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0094	Men's Bathroom Adj. Rm 209	2023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0095	Men's Bathroom Adj. Rm 209	2023	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0096	Nurses Office	2044	Nurse's Office Sink	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0097	Nurses Office Sick Room	2044B	Nurse's Office Sink	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0098	Nurse's Office Bathroom	2044A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0099	Nurse's Office Bathroom	2044A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0101	Faculty Lounge 213	2014	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0102	Faculty Lounge 213	2014	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0104	Corridor Rooms 208 to Stairwell	2036	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0105	Corridor Rooms 208 to Stairwell	2036	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0106	Guidance Chair Office Bathroom	2043A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0107	Guidance Chair Office Bathroom	2043A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0108	Women's Bathroom o/s Guidance	2042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0109	Corridor From Nurses Office to Room 99 (Outside)	2045	Water Fountain-No Chiller	RFI	10/2/2025	6.0			Removed From Inventory
LVT-0110	Men's Bathroom o/s Guidance	2041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0111	Room 99 Custodial Closet (Attic Access)	2040A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0112	Room C4	6005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0113	Room C4	6005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0114	Room C4	6005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0115	Room C4	6005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0116	Men's Bathroom	7005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0117	Men's Bathroom	7005	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0120	Women's Bathroom	7003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0121	Women's Bathroom	7003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0124	Kitchen	2034	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0126	Kitchen	2034	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0127	Kitchen	2034	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0128	Kitchen	2034	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0130	Kitchen Bathroom	2034B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0132	Gym Lobby Women's Bathroom	1034	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0133	Gym Lobby Women's Bathroom	1034	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0134	Gym Lobby Men's Bathroom	1035	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0135	Gym Lobby Men's Bathroom	1035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0136	New Boys Locker Room Bathroom	1046A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0137	New Boys Locker Room Bathroom	1046A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0138	Room 322	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0139	Room 322 Office	3001A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0141	Room 325	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0142	Room 325	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0143	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0144	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0145	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0146	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0147	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0148	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0149	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0150	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0151	Room 320	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0152	Room 320 Office	3003A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0153	Room 323	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0154	Room 323	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0155	Room 323	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0156	Room 323	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0157	Room 323	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0158	Room 323	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0159	Room 323	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0160	Room 323	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0161	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0162	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0163	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0164	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0165	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0166	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0167	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0168	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0169	Room 318	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0170	Room 316	3006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0171	Room 316	3006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0172	Room 316	3006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0173	Room 316 Office	3006A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0174	Room 316	3006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0175	Room 314	3009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0176	Room 314	3009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0177	Room 314	3009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0178	Room 316 Office Inner Office	3006A1	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0179	Room 314 Office	3009A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0181	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0182	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0183	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0184	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0185	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0186	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0187	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0188	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0189	Room 312	3011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0190	Room 310	3012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0191	Room 310	3012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0192	Room 310	3012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0193	Room 310	3012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0194	Room 310	3012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0195	Room 310	3012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0196	Women's Bathroom Adj. Rm 313	3017	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0197	Women's Bathroom Adj. Rm 313	3017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0198	Women's Bathroom Adj. Rm 313	3017	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0199	Women's Bathroom Adj. Rm 313	3017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0200	Women's Bathroom Adj. Rm 313	3017	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0201	Women's Bathroom Adj. Rm 313	3017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0202	Women's Bathroom Adj. Rm 313	3017	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0203	Women's Bathroom Adj. Rm 313	3017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0204	Women's Bathroom Adj. Rm 313	3017	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0205	Women's Bathroom Adj. Rm 313	3017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0206	Women's Bathroom Adj. Rm 313	3017	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0207	Custodial Closet (Across Library)	3018	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0208	Corridor Rooms 300-322 (o/s Bathrooms)	3036	Bottle Fill Station	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0209	Men's Bathroom Across Library	3019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0210	Men's Bathroom Across Library	3019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0211	Men's Bathroom Across Library	3019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0212	Men's Bathroom Across Library	3019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0213	Men's Bathroom Across Library	3019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0214	Men's Bathroom Across Library	3019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0215	Men's Bathroom Across Library	3019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0216	Men's Bathroom Across Library	3019	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0217	Assistant Principals Office	3021A2	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.6			Result Below Action Level Continue O&M
LVT-0218	Corridor Rooms 300-322	3036	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0219	Custodial Closet	7004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0220	Concession Stand Kitchen	5000	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.8			Result Below Action Level Continue O&M
LVT-0226	Exterior Fountain By Baseball Field	N/A	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2277	Room 111	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2278	Room 111	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2298	Corridor Room C19 to Room C21 (Outside Room C7)	7002	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2450	Science Office	3015	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2451	Science Office	3015	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2452	Room 205 Attendance Suite	2018	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2453	Room 205 Attendance Suite	2018	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2456	Boiler Room	1020	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2457	Boiler Room	1020	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2471	Room 207	2017	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2472	Room 207	2017	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2483	New Gym Ice Machine Closet	1042	Ice Machine	Applicable	10/2/2025	2.4			Result Below Action Level Continue O&M
LVT-2484	New Gym Ice Machine Closet	1042	Bottle Fill Station	Applicable	10/2/2025	1.4			Result Below Action Level Continue O&M
LVT-2515	Room 211 (Refrigerator)	2015	Ice Machine	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2545	Men's Faculty Bathroom	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2546	Men's Faculty Bathroom	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2547	Men's Faculty Bathroom	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2548	Men's Faculty Bathroom	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2549	Custodial Office Break Room	1024A	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2550	Custodial Office Break Room	1024A	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2551	Gym Lobby/Corridor (Outside Bathrooms)	1031	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2552	Room 211	2015	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2553	Room 211	2015	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2554	Room 211	2015	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2555	Room 211	2015	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2556	Custodial Closet (across Main Office)	2029	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2557	Cafeteria A	2033	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2558	Kitchen	2034	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2559	Kitchen (Adj. Serving Line)	2034	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2560	Guidance Suite File Area	2043K	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2561	Guidance Suite File Area	2043K	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2562	Nurses Office	2044	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2563	Main Lobby adj. Staff Bathrooms	N/A	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2564	Room 322	3001	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2565	Room 322 Office	3001A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2566	Room 325	3002	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2567	Room 320	3003	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2568	Room 320	3003	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2569	Room 318	3005	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2570	Room 318	3005	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2571	Room 316	3006	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2572	Room 316 Office	3006A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2573	Room 316 Office Inner Office	3006A1	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2574	Room 314	3009	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2575	Room 312	3011	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2576	Room 310	3012	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2577	Room 310	3012	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2578	Room 302 Social Studies Chairperson	3026	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2579	Room 302 Social Studies Chairperson	3026	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2580	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2581	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2582	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2583	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2584	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2585	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2586	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2587	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2588	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2589	Room C5	7006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2590	Room C5	7006	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2591	Room C5	7006	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2592	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2593	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2594	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2595	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2596	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2597	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2598	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2599	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2600	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2601	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2602	Room C6	7007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2603	Room C6	7007	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2604	Room C6	7007	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2605	Prep Room Between Rooms C5 & C6	7007A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2606	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2607	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2608	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2609	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2610	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2611	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2612	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2613	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2614	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2615	Room C7	7008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2616	Room C7	7008	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2617	Room C7	7008	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2618	Womens Bathroom across C5	7003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2619	Womens Bathroom across C5	7003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

General Douglas MacArthur High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2620	Womens Bathroom across C5	7003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2621	Womens Bathroom across C5	7003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2622	Womens Bathroom across C5	7003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2623	Custodial Closet adj. Bathrooms	7004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2624	Mens Bathroom across C5	7005	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2625	Mens Bathroom across C5	7005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2626	Mens Bathroom across C5	7005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2627	Mens Bathroom across C5	7005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2628	Mens Bathroom across C5	7005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2629	Exterior o/s Main Entrance	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2630	Exterior o/s Room 15	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2631	Exterior o/s Room 105	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2632	Exterior o/s Guidance Suite	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2633	Exterior o/s Guidance Suite	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2789	New Gym Lobby o/s Ice Room	1040	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2790	Exterior Hose Bib (Outside Snack Shack)	N/A	Hose Bib	Applicable	10/2/2025	115			Removed From Service, Pending Remediation
LVT-2906	New Gym Lobby o/s Ice Room	1040	Water Cooler	Applicable	12/5/2025	<1.00 ND			Result Below Action Level Continue O&M

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0227	Room 252 Bathroom	2000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0228	Room 252 Bathroom	2000A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0230	Custodial Closet Across Rm 240	2015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0231	Library 234 Magazine Room	2021A	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0233	Faculty Men's Bathroom Adj. Rm 239	2014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0234	Faculty Men's Bathroom Adj. Rm 239	2014	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0235	Faculty Men's Bathroom Adj. Rm 239	2014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0236	Faculty Men's Bathroom Adj. Rm 239	2014	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0237	Faculty Men's Bathroom Adj. Rm 239	2014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0238	Faculty Men's Bathroom Adj. Rm 239	2014	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0239	Faculty Women's Bathroom Adj. Rm 238	2016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0240	Faculty Women's Bathroom Adj. Rm 238	2016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0241	Faculty Women's Bathroom Adj. Rm 238	2016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0242	Faculty Women's Bathroom Adj. Rm 238	2016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0243	Faculty Women's Bathroom Adj. Rm 238	2016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0244	Faculty Women's Bathroom Adj. Rm 238	2016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0245	Faculty Women's Bathroom Adj. Rm 238	2016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0246	Faculty Women's Bathroom Adj. Rm 238	2016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0247	Custodial Closet Across Aud Balcony	2027	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0248	Room 232	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0249	Room 232	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0250	Room 232	2031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0251	Room 230	2034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0252	Custodial Closet Across Rm 228	2038	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0253	Room 228	2035	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0254	Room 228	2035	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0255	Room 228	2035	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0256	Room 225	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0257	Room 225	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0258	Room 225	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0259	Room 225	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0260	Room 225	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0261	Room 225	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0262	Room 226	2041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0263	Room 226	2041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0264	Room 226	2041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0265	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0266	Room 226	2041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0267	Room 226	2041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0268	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0269	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0270	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0271	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0272	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0273	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0274	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0275	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0276	Room 223	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0277	Room 221	2045	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0278	Room 221	2045	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0279	Room 221	2045	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0280	Room 221	2045	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0281	Room 221	2045	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0282	Room 221	2045	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0283	Room 221	2045	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0284	Room 221	2045	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0285	Room 223 Prep Room	2043B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0286	Room 223 Prep Room	2043B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0287	Room 222	2046	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0288	Room 222	2046	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0289	Room 222	2046	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0290	Room 222	2046	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0291	Room 222	2046	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0292	Room 222	2046	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0293	Room 219	2047	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0294	Room 219	2047	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0295	Room 219 Kitchen	2047A	Kitchen Faucet (Cold)	Applicable	10/2/2025	43.6	12/12/2025	2.7	Outlet Remediated and Returned to Service Continue O&M
LVT-0296	Room 220	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0297	Room 220	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0298	Room 220	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0299	Room 220	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0300	Room 220	2048	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0301	Room 212	2054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0302	Room 213	2058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0303	Room 213	2058	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-0304	Room 207 Bathroom	2063B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0305	Room 207 Bathroom	2063B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0306	Custodial Closet	2064	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0307	Room 107	1008	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0309	English Chairperson Conference Room Bathroom	1008C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0310	English Chairperson Conference Room Bathroom	1008C1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0311	Faculty Women's Bathroom Across Rm 205	2065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0312	Faculty Women's Bathroom Across Rm 205	2065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0313	Faculty Women's Bathroom Across Rm 205	2065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0314	Faculty Women's Bathroom Across Rm 205	2065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0315	Faculty Women's Bathroom Across Rm 205	2065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0316	Faculty Women's Bathroom Across Rm 205	2065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0317	Faculty Women's Bathroom Across Rm 205	2065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0318	Faculty Women's Bathroom Across Rm 205	2065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0319	Room 207A Bathroom	2061A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0320	Room 207A Bathroom	2061A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0321	Room 207A Bathroom	2061A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0322	Room 207A Bathroom	2061A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0323	Room 207A Bathroom	2061A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0324	Room 207A Bathroom	2061A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0325	Faculty Men's Bathroom Adj. Rm 104	1004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0326	Faculty Men's Bathroom Adj. Rm 104	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0327	Faculty Men's Bathroom Adj. Rm 104	1004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0328	Faculty Men's Bathroom Adj. Rm 104	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0329	Faculty Men's Bathroom Adj. Rm 104	1004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0330	Faculty Men's Bathroom Adj. Rm 104	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0331	Faculty Women's Bathroom Across Rm 105	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0332	Faculty Women's Bathroom Across Rm 105	1005	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0333	Faculty Women's Bathroom Across Rm 105	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0334	Faculty Women's Bathroom Across Rm 105	1005	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0335	Faculty Women's Bathroom Across Rm 105	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0336	Faculty Women's Bathroom Across Rm 105	1005	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0337	Faculty Women's Bathroom Across Rm 105	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0338	Faculty Women's Bathroom Across Rm 105	1005	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0339	Custodial Closet Across Rm 107	1006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0340	Room 129	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0341	Room 125	1027	Home Economics Faucet (Cold)	Applicable	10/2/2025	2.4			Result Below Action Level Continue O&M
LVT-0342	Room 125	1027	Home Economics Faucet (Cold)	Applicable	10/2/2025	16.3	12/12/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
LVT-0343	Room 125	1027	Home Economics Faucet (Cold)	Applicable	10/2/2025	1.6			Result Below Action Level Continue O&M
LVT-0344	Room 125	1027	Home Economics Faucet (Cold)	Applicable	10/2/2025	3.3			Result Below Action Level Continue O&M
LVT-0345	Room 132	1033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0346	Boy's Bathroom Adj. Rm 129	1033A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0347	Room 132	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0348	Boy's Bathroom Adj. Rm 129	1033A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0349	Room 132	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0350	Boy's Bathroom Adj. Rm 129	1033A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0351	Custodial Closet Across Rm 130	1034	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0352	Girl's Bathroom Across Rm 130	1035	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0353	Girl's Bathroom Across Rm 130	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0354	Girl's Bathroom Across Rm 130	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0355	Girl's Bathroom Across Rm 130	1035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0356	Girl's Bathroom Across Rm 130	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0357	Girl's Bathroom Across Rm 130	1035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0358	Faculty Room 133	1038	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0360	Faculty Room 133 Men's Bathroom	1038A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0361	Faculty Room 133 Men's Bathroom	1038A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0362	Faculty Room 133 Men's Bathroom	1038A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0363	Faculty Room 133 Men's Bathroom	1038A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0364	Faculty Room 133 Men's Bathroom	1038A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0365	Faculty Room 133 Men's Bathroom	1038A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0366	Faculty Room 133 Men's Bathroom	1038A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0367	Faculty Room 133 Men's Bathroom	1038A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0368	Faculty Room 133 Women's Bathroom	1038B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0369	Faculty Room 133 Women's Bathroom	1038B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0370	Faculty Room 133 Women's Bathroom	1038B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0371	Auditorium Lobby Women's Bathroom	1042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0372	Auditorium Lobby Men's Bathroom	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0373	Main Office Kitchen	1046B2	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0374	Main Office Women's Bathroom	1046D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0375	Main Office Men's Bathroom	1046E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0376	Principal's Office Bathroom	1046F2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0377	Room 140 Health Office	1049	Nurse's Office Sink	Applicable	10/2/2025	1.3			Result Below Action Level Continue O&M
LVT-0378	Room 140 Bathroom	1049A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0380	Boy's Bathroom Across Health Office	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0381	Boy's Bathroom Across Health Office	1051	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0382	Boy's Bathroom Across Health Office	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0383	Boy's Bathroom Across Health Office	1051	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0384	Boy's Bathroom Across Health Office	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0385	Boy's Bathroom Across Health Office	1051	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0386	Boy's Bathroom Across Health Office	1051	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0387	Custodial Closet Across Rm 140	1052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0388	Girl's Bathroom Adj. Rm 143	1053	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0389	Girl's Bathroom Adj. Rm 143	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0390	Girl's Bathroom Adj. Rm 143	1053	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0391	Girl's Bathroom Adj. Rm 143	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0392	Girl's Bathroom Adj. Rm 143	1053	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0393	Girl's Bathroom Adj. Rm 143	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0394	Girl's Bathroom Adj. Rm 143	1053	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0395	Girl's Bathroom Adj. Rm 143	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0396	Girl's Bathroom Adj. Rm 143	1053	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0397	Room 146	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0398	Life Skills Room 150	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0399	Life Skills Room 150 Bathroom	1057C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0400	Life Skills Room 150 Bathroom	1057C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0401	Corridor Faculty Bathroom Adj. Rm 150	1061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0402	Room 151	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0403	Room 152	1064	Home Economics Faucet (Cold)	Applicable	10/2/2025	1.6			Result Below Action Level Continue O&M
LVT-0404	Room 152	1064	Spray Nozzle	Applicable	10/2/2025	33.0	12/12/2025	1.4	Outlet Remediated and Returned to Service Continue O&M
LVT-0405	Room 152	1064	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0407	Room 152	1064	Home Economics Faucet (Cold)	Applicable	10/2/2025	7.2	12/12/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
LVT-0408	Room 152 Bathroom	1064C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0409	Room 152 Bathroom	1064C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0411	Girls Locker Room 2	1048D	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0412	Girls Locker Room 2	1048D	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0413	Girls Locker Room 2	1048D	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0414	Girls Locker Room 2 Shower Area	1048D2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0415	Girls Locker Room	1048B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0416	Girls Locker Room	1048B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0417	Girls Locker Room	1048B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0418	Room 318 File Storage	1095C	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0419	Corridor Outside Fan Room	0005	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0424	East Cafeteria Office/Maintainer	1071A	Kitchen Faucet (Cold)	Applicable	10/2/2025	22.3	12/12/2025	1.2	Outlet Remediated and Returned to Service Continue O&M
LVT-0425	Kitchen	1070	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.5			Result Below Action Level Continue O&M
LVT-0426	Kitchen	1070	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0427	Kitchen	1070	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0428	Kitchen	1070	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0429	Kitchen	1070	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.0			Result Below Action Level Continue O&M
LVT-0430	Kitchen	1070	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0431	Kitchen	1070	Spray Nozzle	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0432	Kitchen Serving Area (Reconstructed, Now Part of	1070H	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0433	Kitchen Office (Interior Wall Removed, Part of New	1070A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0434	Kitchen Ladies Bathroom 1	1070B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0435	Custodial Lounge Bathroom	1073A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0436	Gym Lobby Girl's Bathroom	1106	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0437	Gym Lobby Girl's Bathroom	1106	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0438	Gym Lobby Girl's Bathroom	1106	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0439	Gym Lobby Boy's Bathroom	1105	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0440	Gym Lobby Boy's Bathroom	1105	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0441	Gym Lobby Boy's Bathroom	1105	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0442	Room 313	1104	Ice Machine	Applicable	10/2/2025	2.7			Result Below Action Level Continue O&M
LVT-0443	Room 313 Bathroom	1104A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0446	Room 317 Athletic Office Bathroom	1099B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0447	Room 317 Athletic Office Bathroom	1099B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0448	Room 319 Robotics	1096	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0449	Room 319 Robotics	1096	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0450	Engineering Room 323	1086	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0451	Engineering Room 323	1086	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0452	Men's Faculty Restroom Adj. Rm 324	1083	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0453	Men's Faculty Restroom Adj. Rm 324	1083	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0454	Men's Faculty Restroom Adj. Rm 324	1083	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0455	Men's Faculty Restroom Adj. Rm 324	1083	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0456	Custodial Closet Across Rm 325	1082	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0457	Ladies Faculty Restroom Adj. Rm 326	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0458	Ladies Faculty Restroom Adj. Rm 326	1081	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0459	Ladies Faculty Restroom Adj. Rm 326	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0460	Ladies Faculty Restroom Adj. Rm 326	1081	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0461	Graphics Room 326	1080	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0462	Graphics Room 326	1080	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0464	Room 328 Dark Room	1078A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-0465	Room 328 Dark Room	1078A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-0466	Room 328 Dark Room	1078A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0467	Room 328 Dark Room	1078A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0468	Print Shop	1076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0469	Print Shop	1076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0470	Room 329	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0471	Room 329	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0472	Room 329	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0473	Room 329	1075	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-0474	Room 329	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0475	Storage Room Adjacent Room 322	1088	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0476	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0477	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0478	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0479	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0480	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0481	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0482	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0483	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0484	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0485	Snack Shack	4001	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.8			Result Below Action Level Continue O&M
LVT-0486	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0487	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0488	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0489	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0490	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0491	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0492	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0493	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0494	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0495	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2255	Boy's Locker Room Custodial Closet	0018B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2258	Corridor Rooms 212 to 230 (Outside Room 221)	2056	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2260	Auditorium Lobby	1044	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2262	Room 155	1066	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-2263	Room 155	1066	Kitchen Faucet (Cold)	Applicable	10/2/2025	18.6	12/12/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2264	Corridor Rooms 319-324 (Outside Men's Bathroom)	1097	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2275	Architecture Room 330	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2276	Architecture Room 330	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2299	Faculty Room 133	1038	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2311	Auditorium Lobby	1044	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2315	Custodial Lounge	1073	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2316	Custodial Lounge	1073	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2319	Corridor Rooms 319-324 (Outside Men's Bathroom)	1097	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2320	Boy's Locker Room Office 2	0018C	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2322	Room 236	2020	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2323	Room 236	2020	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2324	Corridor Rooms 212 to 230 (Outside Room 221)	2056	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2481	Room 142	1054	Ice Machine	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2482	Room 142	1054	Water Cooler	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2531	Corridor Main Office To Room 151 (Outside Room 144)	1068	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2532	Corridor Rooms 114-134 (Outside Room 132)	1037	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2534	West Cafeteria	1069	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2535	East Cafeteria	1071	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2536	Gym/Lobby Corridor	1109	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2537	Fitness Center 325	1079	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2538	Boy's Locker Room	0018	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2725	Corridor Rooms 114-134 (Outside Room 114)	1037	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2726	Room 140 Health Office	1049	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2727	Corridor Storage Room to Room 252	2029	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2728	Corridor Storage Room to Room 252	2029	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2729	Room 232	2031	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2730	Storage Room	2037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2731	Men's Bathroom	2037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2732	Men's Bathroom	2037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2733	Men's Bathroom	2037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2734	Men's Bathroom	2037	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2735	Room 228	2035	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2736	Room 225	2040	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2737	Room 226	2041	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2738	Room 223	2043	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2739	Room 223	2043	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2740	Room 221	2045	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2741	Room 221	2045	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2742	Room 221	2045	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2743	Room 219	2047	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

Division Avenue High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2744	Room 219	2047	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2745	Room 219	2047	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2746	Room 220	2048	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2747	Men's Bathroom	2066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2748	Men's Bathroom	2066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2749	Men's Bathroom	2066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2750	Men's Bathroom	2066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2751	Men's Bathroom	2066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2752	Men's Bathroom	2066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2753	Boys Locker Room	0018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2754	Boys Locker Room	0018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2755	Boys Locker Room	0018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0496	Basement Break Room	0001	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.9			Result Below Action Level Continue O&M
LVT-0497	Basement Boiler Room	0005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0498	Faculty Men's Bathroom Across Library	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0499	Faculty Men's Bathroom Across Library	1001	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0500	Faculty Women's Bathroom Across Library	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0501	Faculty Women's Bathroom Across Library	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0502	Unisex Bathroom b/w Library & Media Center	1004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0503	Unisex Bathroom b/w Library & Media Center	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0504	Unisex Bathroom Across Rm 300A	1006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0505	Unisex Bathroom Across Rm 300A	1006	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0506	Room 301	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0508	Room 303	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0509	Boy's Bathroom Adj. Rm 303	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0510	Boy's Bathroom Adj. Rm 303	1014	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0511	Boy's Bathroom Adj. Rm 303	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0512	Boy's Bathroom Adj. Rm 303	1014	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0513	Boy's Bathroom Adj. Rm 303	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0514	Boy's Bathroom Adj. Rm 303	1014	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0515	Custodial Closet (Across Rm 304)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0516	Custodial Closet (Across Rm 304)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0517	Custodial Closet (Across Rm 304)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0518	Custodial Closet (Across Rm 304)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0519	Girl's Bathroom Adj. Room 305	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0520	Girl's Bathroom Adj. Room 305	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0521	Girl's Bathroom Adj. Room 305	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0522	Girl's Bathroom Adj. Room 305	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0523	Girl's Bathroom Adj. Room 305	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0524	Girl's Bathroom Adj. Room 305	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0525	Room 305	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0526	Room 307	1020	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0527	Room 309	1022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0528	Room 310	1021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0529	Room 308	1019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0530	Room 306	1017	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0531	Room 304	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0532	Room 302	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0533	Room 300	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0534	Boys Physical Education Office Locker Room Area	1026C2A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0535	Boys Physical Education Office Locker Room Area	1026C2A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0536	Boys Physical Education Office/Tool Storage Bathroom	1026C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0537	Boys Physical Education Office/Tool Storage Bathroom	1026C1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0538	Kitchen	1024	Kitchen Service Area	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0542	Kitchen Bathroom	1024A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0543	Kitchen	1024	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0544	Kitchen	1024	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0547	Cafeteria	1025	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0549	Girl's Bathroom Across Rm 210	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0550	Girl's Bathroom Across Rm 210	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0551	Girl's Bathroom Across Rm 210	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0552	Girl's Bathroom Across Rm 210	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0553	Girl's Bathroom Across Rm 210	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0554	Girl's Bathroom Across Rm 210	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0555	Custodial Closet (Across Rm 210)	1034	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0556	Custodial Closet (Across Rm 210)	1034	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0557	Custodial Closet (Across Rm 210)	1034	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0558	Boy's Bathroom Adj. Rm 207	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0559	Boy's Bathroom Adj. Rm 207	1035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0560	Boy's Bathroom Adj. Rm 207	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0561	Boy's Bathroom Adj. Rm 207	1035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0562	Boy's Bathroom Adj. Rm 207	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0563	Boy's Bathroom Adj. Rm 207	1035	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0564	Room 207	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0565	Room 205	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0566	Room 203	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0567	Room 201	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0568	Room 201	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0571	Room 199 Bathroom	1079A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0573	Room 199	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0574	Room 200 Bathroom	1078A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0575	Room 200	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0576	Room 200	1078	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0577	Room 202	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0578	Room 202 Bathroom	1046A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0579	Room 204	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0580	Room 206	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0583	Room 210	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0584	Psychologist Office Bathroom	1032C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0587	Social Worker Copy Room Bathroom	1032B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0588	Social Worker Copy Room Bathroom	1032B1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0589	Men's Bathroom Across Rm 110	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0590	Men's Bathroom Across Rm 110	1028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0591	Women's Bathroom Across Rm 110	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0592	Women's Bathroom Across Rm 110	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0593	Women's Bathroom Across Rm 110	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0594	Women's Bathroom Across Rm 110	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0595	Custodial Closet (Adj. Rm 113)	1051	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0596	Room 115 Bathroom	1049B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0597	Room 117	1048	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0598	Gym Music Room 116 Bathroom	1026B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0599	Gym Music Room 116 Bathroom	1026B2	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0600	Gym Music Room 116 Office Bathroom	1026B1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0601	Gym Music Room 116 Office Bathroom	1026B1A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0605	Women's Staff Bathroom Outside Faculty Room	1055	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0606	Women's Staff Bathroom Outside Faculty Room	1055	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0607	Faculty Room	1056	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.0			Result Below Action Level Continue O&M
LVT-0608	Faculty Room	1056	Spray Nozzle	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0609	Room 108 Bathroom	1058A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0610	Room 108 Bathroom	1058A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0611	Room 106	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0612	Room 106 Bathroom	1060A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0613	Room 106 Bathroom	1060A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0614	Room 104	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0615	Room 104 Bathroom	1062A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0616	Room 104 Bathroom	1062A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0617	Room 102	1064	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0618	Room 102 Bathroom	1064A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0619	Room 100	1066	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0620	Room 100 Bathroom	1066A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0622	Room 98	1070	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0625	Room 96 Bathroom	1076A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0626	Room 96	1076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0628	Room 97	1077	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0629	Room 97	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0630	Room 97 Bathroom	1077A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0631	Faculty Bathroom	1075	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0632	Room 99	1071	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0634	Room 99 Bathroom	1071A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0635	Room 101 Bathroom	1067A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0636	Room 101	1067	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0637	Room 103	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0640	Room 105	1063	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0641	Room 105 Bathroom	1063A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0642	Room 105 Bathroom	1063A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0643	Room 107	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0644	Room 107 Bathroom	1061A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0645	Room 107 Bathroom	1061A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0646	Room 109	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0647	Room 109 Bathroom	1059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0648	Room 109 Bathroom	1059A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0649	Nurse's Office	1057A	Nurse's Office Sink	Applicable	10/2/2025	4.0			Result Below Action Level Continue O&M
LVT-0650	Nurse's Office Bathroom	1057A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0651	Nurse's Office Bathroom	1057A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0652	Main Office Corridor Closet	1053C	Kitchen Faucet (Cold)	Applicable	10/2/2025	25.5			Removed From Service, Pending Remediation
LVT-0653	Main Office Side Corridor Bathroom	1053B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0654	Main Office Side Corridor Bathroom	1053B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0660	Exterior Hose Bib o/s 1065	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0661	Exterior Hose Bib o/s 1057	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2267	Nurses Office Large Exam/Sick Room	1057C	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2272	Kitchen	1024	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2273	Kitchen	1024	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2274	Kitchen	1024	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.4			Result Below Action Level Continue O&M
LVT-2354	Kitchen Bathroom	1024A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2355	Room 201 Bathroom	1045B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2356	Room 202 Bathroom	1046A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2361	Nurses Office Large Exam/Sick Room	1057C	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2362	Women's Staff Bathroom Outside Faculty Room	1054	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2363	Women's Staff Bathroom Outside Faculty Room	1054	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2366	Room 103 Bathroom	1065A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2367	Room 103 Bathroom	1065A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2370	Room 98 Bathroom	1070A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2503	Corridor Library-Room 310 (Outside Room 301)	1023	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2504	Corridor 200 Wing Rooms 200-210 (Outside Room 208)	1047	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2505	Corridor Exit Vestibule by Room 101 (Outside Room 101)	1069	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2525	Cafeteria	1025	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2526	Corridor Outside Gym (Outside Copy Room)	1031	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2652	Room 208	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2653	Room 201 Bathroom	1045B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2654	Nurses Office	1057A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2655	Exterior o/s Room 207	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2656	Exterior o/s Room 203	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Summit Lane Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2657	Exterior o/s Exit 12	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2658	Exterior o/s Room 204	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2659	Exterior o/s Room 210	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2660	Exterior o/s Exit 7	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2661	Exterior o/s Gym	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2662	Exterior o/s Main Entrance	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2663	Exterior o/s Room 304	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2664	Exterior o/s Room 310	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2665	Exterior o/s Room 297	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2808	Kitchen	1024	Spray Nozzle	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0667	Boiler Room	0003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0668	Storage 8	0004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0669	Storage 8	0004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0670	Storage 8	0004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0672	Cafeteria Bathroom Vestibule	0001D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0673	Cafeteria Boy's Bathroom	0001B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0674	Cafeteria Girl's Bathroom	0001C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0675	Kitchen	0001A	Kitchen Faucet (Cold)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0676	Kitchen	0001A	Kitchen Faucet (Cold)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0677	Kitchen	0001A	Kitchen Service Area	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0679	Bathroom o/s Assistant Principals Office	1048A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0680	Room 101	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0681	Room 103C	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0682	Room 105	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0684	Room 105 Bathroom	1059A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0685	Room 105 Bathroom	1059A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0686	Room 106A	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0687	Room 107	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0688	Room 107	1077	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0689	Room 107 Bathroom	1077A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0690	Room 108	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0691	Room 108	1078	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-0692	Room 108 Bathroom	1078A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0693	Room 104	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0694	Room 104 Bathroom	1057A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0696	Room 102A Closet	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0697	Boy's Bathroom Adj. Rm 102	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0698	Boy's Bathroom Adj. Rm 102	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0699	Boy's Bathroom Adj. Rm 102	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0700	Boy's Bathroom Adj. Rm 102	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0701	Boy's Bathroom Adj. Rm 102	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0702	Boy's Bathroom Adj. Rm 102	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0703	Boy's Bathroom Adj. Rm 102	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0704	Boy's Bathroom Adj. Rm 102	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0705	Custodial Closet (Across Nurse)	1064	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0707	Custodial Closet (Across Nurse)	1064	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0708	Girl's Bathroom Adj. Rm 207	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0709	Girl's Bathroom Adj. Rm 207	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0710	Girl's Bathroom Adj. Rm 207	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0711	Girl's Bathroom Adj. Rm 207	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0712	Girl's Bathroom Adj. Rm 207	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0713	Girl's Bathroom Adj. Rm 207	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0714	Girl's Bathroom Adj. Rm 207	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0715	Girl's Bathroom Adj. Rm 207	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0716	Room 207	1067	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0717	Room 209	1068	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0718	Room 211	1070	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0719	Room 213	1074	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0720	Art Room 214	1073	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0721	Room 212	1072	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0723	Room 210	1071	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0724	Room 208	1069	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0725	Nurse's Office Bathroom	1047C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0726	Nurse's Office Bathroom	1047C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0727	Room 421	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0728	Room 423	1021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0729	Room 425	1023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0730	Faculty Lounge 531	1039	Kitchen Faucet (Cold)	Applicable	10/2/2025	5.8	12/12/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
LVT-0731	Room 533	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0732	Room 532	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0733	Faculty Bathroom Adj. Rm 526	1030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0734	Faculty Bathroom Adj. Rm 526	1030	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0743	Custodial Closet (Across Rm 527)	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0744	Custodial Closet (Across Rm 527)	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0745	Custodial Closet (Across Rm 527)	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0746	Girl's Bathroom Adj. Storage 5	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0747	Girl's Bathroom Adj. Storage 5	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0748	Girl's Bathroom Adj. Storage 5	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0749	Girl's Bathroom Adj. Storage 5	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0750	Girl's Bathroom Adj. Storage 5	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0751	Girl's Bathroom Adj. Storage 5	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0752	Girl's Bathroom Adj. Storage 5	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0753	Girl's Bathroom Adj. Storage 5	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0754	Room 426	1024	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0755	Room 424	1022	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0757	Custodian Office 420	1019	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0758	Girl's Bathroom Adj. Custodian Office	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0759	Girl's Bathroom Adj. Custodian Office	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0760	Girl's Bathroom Adj. Custodian Office	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0761	Girl's Bathroom Adj. Custodian Office	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0762	Girl's Bathroom Adj. Custodian Office	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0763	Girl's Bathroom Adj. Custodian Office	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0764	Girl's Bathroom Adj. Custodian Office	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0765	Girl's Bathroom Adj. Custodian Office	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0766	Custodial Closet (Across Rm 314)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0767	Custodial Closet (Across Rm 314)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0768	Custodial Closet (Across Rm 314)	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0769	Boy's Bathroom Across Rm 314	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0770	Storage 3	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0771	Boy's Bathroom Across Rm 314	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0772	Storage 3	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0773	Boy's Bathroom Across Rm 314	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0774	Storage 3	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0775	Boy's Bathroom Across Rm 314	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0776	Storage 3	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0777	Room 315	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0779	Room 317	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0780	Room 319	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0781	Room 319 Bathroom	1011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0782	Room 319 Bathroom	1011A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0783	Room 320	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0784	Room 320 Bathroom	1010A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0785	Room 320 Bathroom	1010A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0786	Room 318	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0791	Men's Bathroom Adj. Library	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0792	Men's Bathroom Adj. Library	1001	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0793	Women's Bathroom Adj. Library	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0794	Women's Bathroom Adj. Library	1043	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0795	Main Office Principal's Office Bathroom	1047B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0807	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2197	Custodial Closet	1083	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2198	Kitchen Staff Bathroom	1082A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2199	Kitchen Staff Bathroom	1082A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2200	Kitchen	1082	Kitchen Faucet (Cold)	Applicable	10/2/2025	15.6	12/3/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
LVT-2201	Kitchen	1082	Spray Nozzle	Applicable	10/2/2025	37.2	12/3/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
LVT-2202	Kitchen	1082	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2203	Kitchen	1082	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2204	Kitchen	1082	Spray Nozzle	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2205	Kitchen	1082	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2206	Kitchen	1082	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2207	Cafeteria Serving Line	1081	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2208	Kitchen	1082	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2209	All Purpose Room	1080	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-2210	All Purpose Room	1080	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2213	All Gender Bathroom 1	1080A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2214	All Gender Bathroom 1	1080A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2215	All Gender Bathroom 2	1080B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2216	All Gender Bathroom 2	1080B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2217	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2218	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2219	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2220	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2221	Exterior Hose Bib o/s Exit 11	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2269	Nurse's Office	1048	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2373	Boy's Bathroom Across Rm 527	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2374	Boy's Bathroom Across Rm 527	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2375	Boy's Bathroom Across Rm 527	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2376	Boy's Bathroom Across Rm 527	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2377	Boy's Bathroom Across Rm 527	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2378	Boy's Bathroom Across Rm 527	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2379	Boy's Bathroom Across Rm 527	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2380	Boy's Bathroom Across Rm 527	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2383	Nurse's Office	1048	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2522	Corridor Rooms 100-104 (Outside Room 102)	1058	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2523	Corridor Rooms 207-212 (Outside Room 210)	1076	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2524	Corridor Main Office To Gym (Outside Library)	1045	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2528	Corridor Rooms 420-426 (Outside Room 423)	1025	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2529	Corridor Rooms 314-318 (Outside Room 317)	1013	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2530	Cafeteria	0001	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2539	Corridor Rooms 527-534 o/s Room 527	1046	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2634	Room 316A	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2635	Custodial Closet (Across Nurse)	1064	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2637	Nurse Office Bathroom	1048A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2638	Nurse Office	1048	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2639	Custodial Office 420	1019	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2640	Custodial Office 420	1019	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2641	Exterior o/s Library	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2642	Exterior o/s Room 316B	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2643	Exterior o/s Room 320	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2644	Exterior o/s Room 426	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Northside Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2645	Exterior o/s Room 531	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2646	Exterior o/s Room 425	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2647	Exterior o/s Exit 8	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2648	Exterior o/s Room 212	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2649	Exterior o/s Room 106A	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2650	Exterior o/s Room 103B	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2651	Exterior o/s Main Office	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0810	Room 103A Office 1	1003A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0811	Room 105	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0812	Boy's Bathroom Adj. Rm 106	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0813	Boy's Bathroom Adj. Rm 106	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0814	Boy's Bathroom Adj. Rm 106	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0815	Boy's Bathroom Adj. Rm 106	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0816	Boy's Bathroom Adj. Rm 106	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0817	Boy's Bathroom Adj. Rm 106	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0818	Boy's Bathroom Adj. Rm 106	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0819	Boy's Bathroom Adj. Rm 106	1007	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0820	Custodial Closet (Acorss Rm 107)	1008	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0821	Custodial Closet (Acorss Rm 107)	1008	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0822	Custodial Closet (Acorss Rm 107)	1008	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0823	Girl's Bathroom Adj. Rm 108	1009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0824	Girl's Bathroom Adj. Rm 108	1009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0825	Girl's Bathroom Adj. Rm 108	1009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0826	Girl's Bathroom Adj. Rm 108	1009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0827	Girl's Bathroom Adj. Rm 108	1009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0828	Girl's Bathroom Adj. Rm 108	1009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0829	Girl's Bathroom Adj. Rm 108	1009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0830	Girl's Bathroom Adj. Rm 108	1009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0831	Boy's Bathroom Adj. Rm 118	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0832	Boy's Bathroom Adj. Rm 118	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0833	Boy's Bathroom Adj. Rm 118	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0834	Boy's Bathroom Adj. Rm 118	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0835	Boy's Bathroom Adj. Rm 118	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0836	Boy's Bathroom Adj. Rm 118	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0837	Boy's Bathroom Adj. Rm 118	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0838	Boy's Bathroom Adj. Rm 118	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0839	Custodial Closet (Across Rm 117)	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0840	Custodial Closet (Across Rm 117)	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0841	Custodial Closet (Across Rm 117)	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0842	Girl's Bathroom Adj. Rm 120	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0843	Girl's Bathroom Adj. Rm 120	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0846	Girl's Bathroom Adj. Rm 120	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0847	Girl's Bathroom Adj. Rm 120	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0848	Girl's Bathroom Adj. Rm 120	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0849	Girl's Bathroom Adj. Rm 120	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0850	Room 121	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0851	Room 122	1033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0852	Instrument Storage Room Right	3018A2	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0853	Instrument Storage Room Left	3018A1	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-0854	Women's Bathroom	3012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0855	Women's Bathroom	3012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0856	Women's Bathroom	3012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0857	Men's Bathroom	3011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0858	Men's Bathroom	3011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0859	Men's Bathroom	3011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-0860	Basement B17	0016	Home Economics Faucet (Cold)	Applicable	10/2/2025	4.3			Result Below Action Level Continue O&M
LVT-0861	Basement B17	0016	Home Economics Faucet (Cold)	Applicable	10/2/2025	1.3			Result Below Action Level Continue O&M
LVT-0862	Basement B17	0016	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0863	Basement B15	0015	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0864	Basement B15	0015	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0865	Basement B15	0015	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0866	Basement B15	0015	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0867	Basement B15	0015	Home Economics Faucet (Cold)	Applicable	10/2/2025	88.3			Removed From Service, Pending Remediation
LVT-0868	Basement Shop Storage Room	0012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0869	Basement Shop Storage Room	0012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0870	Basement Shop Storage Room	0012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0871	Basement Shop Room B13	0013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0872	Boiler Room	1048	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0875	Boiler Room Bathroom	1048A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0876	Boiler Room Bathroom	1048A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0879	Room 404	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0880	Room 404	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0882	Room 404	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0883	Room 404	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0884	Room 404	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0885	Library	1085	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0886	Room 405	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0887	Room 405	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0889	Room 405	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0890	Room 405	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0891	Room 405	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0892	Room 407/405 Prep Room	3001A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0893	Room 407	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0894	Room 407	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0897	Room 407	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0898	Room 407	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0899	Art Room 332	3000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0900	Art Room 332	3000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0904	Room 324	1080	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0905	Room 324	1080	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0906	Room 324	1080	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0908	Room 322	1078	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0909	Room 322	1078	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0912	Room 322	1078	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0913	Room 322	1078	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0914	Girl's Bathroom Adj. Rm 320	1075	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0915	Girl's Bathroom Adj. Rm 320	1075	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0916	Girl's Bathroom Adj. Rm 320	1075	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0917	Girl's Bathroom Adj. Rm 320	1075	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0918	Girl's Bathroom Adj. Rm 320	1075	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0919	Girl's Bathroom Adj. Rm 320	1075	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0920	Boy's Bathroom Adj.Rm 317	1073	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0921	Boy's Bathroom Adj.Rm 317	1073	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0922	Boy's Bathroom Adj.Rm 317	1073	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0923	Boy's Bathroom Adj.Rm 317	1073	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0924	Boy's Bathroom Adj.Rm 317	1073	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0925	Boy's Bathroom Adj.Rm 317	1073	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0926	Boy's Bathroom Adj.Rm 317	1073	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0927	Custodial Closet (Across Rm 317)	1074	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0928	Custodial Closet (Across Rm 317)	1074	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0929	Custodial Closet (Across Rm 317)	1074	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0932	Room 317	1072	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0933	Room 317	1072	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0937	Faculty Room 204	1041	Ice Machine	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0944	Conference Room Closet	1047B1	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.7			Result Below Action Level Continue O&M
LVT-0945	Ladies Bathroom 315B	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0946	Ladies Bathroom 315B	1050	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0947	Ladies Bathroom 315B	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0948	Ladies Bathroom 315B	1050	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0949	Men's Bathroom Adj. Rm 315	1052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0950	Men's Bathroom Adj. Rm 315	1052	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0951	Staff Women's Bathroom by Rm 311	1056	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0952	Staff Women's Bathroom by Rm 311	1056	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0953	Staff Women's Bathroom by Rm 311	1056	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0954	Staff Women's Bathroom by Rm 311	1056	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0955	Staff Women's Bathroom by Rm 311	1056	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0956	Staff Women's Bathroom by Rm 311	1056	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0957	Staff Women's Bathroom by Rm 311	1056	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0958	Staff Women's Bathroom by Rm 311	1056	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0959	Custodial Closet (Across Rm 311)	1057	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0960	Custodial Closet (Across Rm 311)	1057	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0961	Custodial Closet (Across Rm 311)	1057	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0962	Staff Men's Bathroom by Rm 311	1058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0963	Staff Men's Bathroom by Rm 311	1058	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0964	Staff Men's Bathroom by Rm 311	1058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0965	Staff Men's Bathroom by Rm 311	1058	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0966	Staff Men's Bathroom by Rm 311	1058	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0967	Staff Men's Bathroom by Rm 311	1058	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0968	Room 310	1070	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0969	Room 304	1067	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0970	Room 304	1067	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0971	Room 302	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0972	Room 300	1064	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0975	Principal's Office Bathroom	1044A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0976	Principal's Office Bathroom	1044A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0979	Cafeteria Addition All-Gender Bathroom 1	3019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0980	Cafeteria Addition Custodial Closet	3019B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-0981	Cafeteria Addition Custodial Closet	3019B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0982	Cafeteria Addition Custodial Closet	3019B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0983	Cafeteria Addition All-Gender Bathroom 2	3019C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0985	Custodial Closet (Across Kitchen)	1042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0986	Custodial Closet (Across Kitchen)	1042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0987	Custodial Closet (Across Kitchen)	1042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0988	Faculty Room 204	1041	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.2			Result Below Action Level Continue O&M
LVT-0989	Kitchen	1046	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0990	Kitchen	1046	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-0991	Kitchen	1046	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.1			Result Below Action Level Continue O&M
LVT-0994	Kitchen Closet Bathroom	1046C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-0995	Kitchen Custodial Closet	1046E1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0996	Kitchen Custodial Closet	1046E1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0997	Kitchen Custodial Closet	1046E1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-0999	Nurse's Office	1039	Nurse's Office Sink	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1000	Nurse's Office	1039	Nurse's Office Sink	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1001	Nurse's Office Bathroom	1039A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1002	Nurse's Office Bathroom	1039A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1003	Boiler Room	3010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1004	Women's Bathroom 203	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1005	Women's Bathroom 203	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1006	Women's Bathroom 203	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1007	Women's Bathroom 203	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1008	Men's Bathroom 201	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1009	Men's Bathroom 201	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1011	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1012	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1013	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1014	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1015	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1016	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1017	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1018	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1019	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1020	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1021	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1022	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1023	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1024	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1025	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1026	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1027	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1028	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1029	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1030	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1031	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1032	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1033	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1034	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2268	Faculty Room 204	1041	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2286	Kitchen	1046	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2287	Kitchen	1046	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2288	Kitchen	1046	Spray Nozzle	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2300	Basement B17	0016	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2301	Basement B17	0016	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2304	Nurse's Office	1039	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2305	Nurse's Office	1039	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2306	Faculty Room 204	1041	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2307	Room 320	1076	Kitchen Faucet (Cold)	Applicable	10/2/2025	5.4			Removed From Service, Pending Remediation
LVT-2308	Custodial Office	3016	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2309	Custodial Office	3016	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2478	Room 102A Closet	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2487	Corridor Rooms 103-110 (Outside Room 109A)	1016	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2540	Cafeteria	1047	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2541	Cafeteria Addition	3019	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2542	Corridor Room 332 to Custodial Closet (Outside)	3007	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2756	Girl's Bathroom Adj. Rm 120	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2757	Girl's Bathroom Adj. Rm 120	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2758	Nurses Office	1039	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2759	Assistant Principals Office	1040	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2760	Assistant Principals Office	1040	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2761	Faculty Room 204 (Refrigerator)	1041	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2762	Faculty Room 204 (Refrigerator)	1041	Ice Machine	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2763	Kitchen Serving Area	1046F	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.5			Result Below Action Level Continue O&M
LVT-2764	Girls Locker Room	1089	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2765	Girls Locker Room	1089	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2766	Girls Locker Room	1089	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2767	Girls Locker Room	1089	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2768	Boys Phys. Ed. Office Bathroom	1092A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2769	Room 322	1078	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Wisdom Lane Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2770	Room 322	1078	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2771	Room 322	1078	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2772	Room 324	1080	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2773	Room 321	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2774	Room 330	1086	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2775	Room 330	1086	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2776	Room 330	1086	Art Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2777	Boys Locker Room	1091	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2778	Boys Locker Room	1091	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2779	Boys Locker Room	1091	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2780	Girls Coach Office	1088	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2781	Girls Coach Office	1088	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2782	Girls Coach Office Bathroom	1088A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2783	Room 407	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2784	Room 407	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2785	Room 405	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2786	Room 404	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2787	Custodial Closet adj. Custodial Office	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2788	Exterior o/s 1055	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2809	Corridor Boiler Room To Room 200 (Outside Principal's	1049	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1035	Room 202	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1036	Room 202 Bathroom	1002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1039	Room 203	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1041	Room 205	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1042	Room 208	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1051	Custodial Closet (200 Wing)	1009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1060	Room 210	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1061	Room 207	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1062	Room 212	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1063	Women's Bathroom (200 Wing)	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1064	Women's Bathroom (200 Wing)	1016	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1065	Corridor Rooms 201-212	1023	Water Fountain-No Chiller	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1066	Men's Bathroom (200 Wing)	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1067	Men's Bathroom (200 Wing)	1017	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1068	Custodial Storage Bathroom	1022A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1069	Custodial Storage Bathroom	1022A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1070	Kitchen Vestibule	1018	Ice Machine	Applicable	10/2/2025	2.0			Result Below Action Level Continue O&M
LVT-1071	Kitchen Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1072	Kitchen Bathroom	1020	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1073	Main Entrance Bathroom	1053	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1074	Main Entrance Bathroom	1053	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1075	Room 302	1026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1077	Room 302 Bathroom	1026A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1078	Room 302 Bathroom	1026A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1079	Room 301	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1081	Room 301 Bathroom	1025C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1082	Room 301 Bathroom	1025C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1083	Room 303	1027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1084	Corridor Rooms 301-311 (Outside Main Office)	1050	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1086	Room 304	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1087	Room 305	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1088	Room 306	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1096	Custodial Closet (300 Wing)	1032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1097	Custodial Closet (300 Wing)	1032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1098	Custodial Closet (300 Wing)	1032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1107	Room 307	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1108	Room 308	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1109	Room 310	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1110	Room 311	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1111	Room 314	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1112	Nurse's Office Bathroom	1041A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1114	Principal's Office Bathroom	1047B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1115	Principal's Office Bathroom	1047B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1123	Kitchen	1021	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1124	Kitchen	1021	Spray Nozzle	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1125	Library	1059	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.4			Result Below Action Level Continue O&M
LVT-1126	Room 401	3002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1128	Room 401 Bathroom	3002B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1129	Room 401 Bathroom	3002B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1130	Room 402	3003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1132	Room 402 Bathroom	3003B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1133	Room 402 Bathroom	3003B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1136	Room 403 Bathroom	3000B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1137	Room 403 Bathroom	3000B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1138	Room 404	3001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1139	Room 404	3001	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-1140	Room 404 Bathroom	3003B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1141	Room 404 Bathroom	3003B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1142	Room 406	1068	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1143	Boy's Bathroom (400 Wing)	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1144	Boy's Bathroom (400 Wing)	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1145	Boy's Bathroom (400 Wing)	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1146	Boy's Bathroom (400 Wing)	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1147	Boy's Bathroom (400 Wing)	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1150	Custodial Closet (400 Wing)	1064	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1151	Custodial Closet (400 Wing)	1064	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1152	Custodial Closet (400 Wing)	1064	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1162	Faculty Room 409	1062	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1163	Room 411	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1164	Basement Corridor	0006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1165	Basement Corridor	0006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1170	Music Room 515	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1171	Music Room 515	1075	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1172	Art Room 511	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1173	Art Room 511	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1175	Room 508	1082	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1176	Girl's Bathroom (500 Wing)	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1179	Girl's Bathroom (500 Wing)	1084	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1180	Girl's Bathroom (500 Wing)	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1183	Girl's Bathroom (500 Wing)	1084	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1185	Custodial Closet (500 Wing)	1085	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1186	Custodial Closet (500 Wing)	1085	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1187	Custodial Closet (500 Wing)	1085	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1189	Boy's Bathroom (500 Wing)	1086	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1190	Boy's Bathroom (500 Wing)	1086	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1191	Boy's Bathroom (500 Wing)	1086	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1192	Boy's Bathroom (500 Wing)	1086	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1193	Boy's Bathroom (500 Wing)	1086	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1194	Boy's Bathroom (500 Wing)	1086	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1196	Room 501	1091	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1198	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1199	Exterior Hose Bib (Outside Room 404)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1200	Exterior Hose Bib (Outside Library)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1202	Exterior Hose Bib (Outside Nurse's Office)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1204	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1206	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1207	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1208	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1218	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1219	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2283	Kitchen	1021	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2284	Kitchen	1021	Spray Nozzle	Applicable	10/2/2025	2.1			Result Below Action Level Continue O&M
LVT-2285	Kitchen	1021	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.7			Result Below Action Level Continue O&M
LVT-2294	Cafeteria	1058	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-2398	Boy's Bathroom (500 Wing)	1086	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2399	Room 201	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2400	Room 204	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2401	Girl's Bathroom (200 Wing)	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2402	Girl's Bathroom (200 Wing)	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2403	Girl's Bathroom (200 Wing)	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2404	Girl's Bathroom (200 Wing)	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2405	Girl's Bathroom (200 Wing)	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2406	Girl's Bathroom (200 Wing)	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2407	Girl's Bathroom (200 Wing)	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2408	Girl's Bathroom (200 Wing)	1008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2409	Boy's Bathroom (200 Wing)	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2410	Boy's Bathroom (200 Wing)	1010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2411	Boy's Bathroom (200 Wing)	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2412	Boy's Bathroom (200 Wing)	1010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2413	Boy's Bathroom (200 Wing)	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2414	Boy's Bathroom (200 Wing)	1010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2416	Boy's Bathroom (200 Wing)	1010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2419	Boy's Bathroom (300 Wing)	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2420	Boy's Bathroom (300 Wing)	1031	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2421	Boy's Bathroom (300 Wing)	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2422	Boy's Bathroom (300 Wing)	1031	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2423	Boy's Bathroom (300 Wing)	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2424	Boy's Bathroom (300 Wing)	1031	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2425	Boy's Bathroom (300 Wing)	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2426	Boy's Bathroom (300 Wing)	1031	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2427	Girl's Bathroom (300 Wing)	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2428	Girl's Bathroom (300 Wing)	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2429	Girl's Bathroom (300 Wing)	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2430	Girl's Bathroom (300 Wing)	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2431	Girl's Bathroom (300 Wing)	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2432	Girl's Bathroom (300 Wing)	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2433	Girl's Bathroom (300 Wing)	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2434	Girl's Bathroom (300 Wing)	1033	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2439	Girl's Bathroom (400 Wing)	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2440	Girl's Bathroom (400 Wing)	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2441	Girl's Bathroom (400 Wing)	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2442	Girl's Bathroom (400 Wing)	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2443	Girl's Bathroom (400 Wing)	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2444	Girl's Bathroom (400 Wing)	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2445	Girl's Bathroom (400 Wing)	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2446	Girl's Bathroom (400 Wing)	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2447	Girl's Bathroom (400 Wing)	1063	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2449	Room 403	3000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2490	Corridor Rooms 301-311	1050	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2543	Cafeteria	1058	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2666	Room 206	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2667	Room 206	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2668	Boy's Bathroom (200 Wing)	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2669	Corridor Between Rooms 405 And 410	1070	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2670	Girl's Bathroom (400 Wing)	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2671	Girl's Bathroom (400 Wing)	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2672	Girl's Bathroom (400 Wing)	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2673	Girl's Bathroom (400 Wing)	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2674	Girl's Bathroom (400 Wing)	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2675	Girl's Bathroom (400 Wing)	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2676	Girl's Bathroom (400 Wing)	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2677	Girl's Bathroom (400 Wing)	1063	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2678	Girl's Bathroom (400 Wing)	1063	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2679	Boy's Bathroom (400 Wing)	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2680	Women's Faculty Bathroom 1	1072	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2681	Women's Faculty Bathroom 1	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2682	All Gender Restroom 2	1073	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2683	All Gender Restroom 2	1073	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2684	Corridor Between Rooms 405 And 410 (Outside Boy's)	1070	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2685	Girl's Bathroom	1084	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2686	Girl's Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2687	Girl's Bathroom	1084	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2688	Girl's Bathroom	1084	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2689	Girl's Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2690	Exterior Hose Bib (Outside Room 306)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2691	Exterior Hose Bib (Outside Room 301)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2692	Exterior Hose Bib (Outside Room 302)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2693	Exterior Hose Bib (Outside Room 102)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2694	Exterior Hose Bib (Outside Room 311)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2695	Exterior Hose Bib (Outside Custodial Office)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Abbey Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2696	Exterior Hose Bib (Outside Room 203)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2697	Exterior Hose Bib (Outside Room 204)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2698	Exterior Hose Bib (Outside Room 210)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2699	Exterior Hose Bib (Outside Room 101)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2700	Exterior Hose Bib (Outside Room 320)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2701	Exterior Hose Bib (Outside All Purpose Hallway)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1220	Boiler Room	1049B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1221	Shop Room B5	0006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1222	Boy's Locker Room	0009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1223	Boy's Locker Room	0009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1227	Weight Room Custodial Closet	0009D	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1228	Girls Locker Room	0010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1229	Girls Locker Room	0010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1230	Girls Locker Room	0010	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1231	Girls Locker Room Phys. Ed. Office	0010C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1232	Room 132	4006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1235	Men's Faculty Bathroom (Across From Gym)	1000	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1236	Men's Faculty Bathroom (Across From Gym)	1000	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1237	Men's Faculty Bathroom (Across From Gym)	1000	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1238	Ladies Faculty Bathroom	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1239	Ladies Faculty Bathroom	1002	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1240	Girls Bathroom	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1241	Girls Bathroom	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1242	Girls Bathroom	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1243	Girls Bathroom	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1244	Girls Bathroom	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1245	Girls Bathroom	1003	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1246	Girls Bathroom	1003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1247	Custodial Closet	1004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1248	Room 128/126	1007	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1250	Room 128/126	1007	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1251	Room 128/126	1007	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1252	Room 128/126	1007	Home Economics Faucet (Cold)	Applicable	10/2/2025	1.5			Result Below Action Level Continue O&M
LVT-1253	Room 128/126	1007	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1254	Room 123	1012	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1255	Room 122	1014	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1256	Room 122	1014	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1257	Room 122	1014	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1258	Room 122	1014	Home Economics Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1259	Ladies Bathroom	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1260	Ladies Bathroom	1013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1261	Ladies Bathroom	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1262	Ladies Bathroom	1013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1264	Men's Faculty Bathroom	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1265	Men's Faculty Bathroom	1015	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1266	Men's Faculty Bathroom	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1267	Men's Faculty Bathroom	1015	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1269	Nurses Office Cot Room Bathroom	1023B2B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1270	Nurses Office Cot Room Bathroom	1023B2B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1271	Assistant Principal Office Bathroom	1024C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1272	Assistant Principal Office Bathroom	1024C1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1273	Principals Office Bathroom	1025A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1274	Main Office Kitchen	1026A	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1276	Room 107	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1277	Room 107	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1278	Room 107	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1280	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1281	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1282	Boys Bathroom	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1283	Room 109	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1284	Room 109	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1285	Room 109	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1286	Custodial Closet	1038	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1287	Girls Bathroom	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1288	Girls Bathroom	1039	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1289	Girls Bathroom	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1290	Girls Bathroom	1039	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1291	Girls Bathroom	1039	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1292	Men's Faculty Bathroom	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1293	Men's Faculty Bathroom	1043	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1294	Boiler Storage Room Bathroom	1049A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1295	Boiler Storage Room Bathroom	1049A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1297	Room 111	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1298	Room 111	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1299	Room 111	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1300	Room 112	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1301	Room 112	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1302	Room 112	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1303	Room 114	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1304	Room 114	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1305	Room 114	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1307	Room 114	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1309	Room 116 Office 2	1057C	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-1310	Room 116 Office 2	1057C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1311	Ladies Bathroom	1061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1312	Ladies Bathroom	1061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1313	Green Cafeteria	1063	Water Cooler	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1316	Kitchen	1064	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1317	Kitchen	1064	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1318	Kitchen	1064	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1320	Kitchen	1064	Spray Nozzle	RFI	10/2/2025	24.2			Removed From Inventory
LVT-1321	Kitchen Locker Room	1064B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1322	Kitchen Locker Room	1064B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1323	Kitchen Exit Vestibule Bathroom	1064F1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1324	Kitchen Exit Vestibule Bathroom	1064F1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1325	Kitchen Exit Vestibule Bathroom	1064F1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1326	Kitchen Exit Vestibule Bathroom	1064F1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1327	Blue Cafeteria	1065	Water Cooler	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1328	Boys Entrance Into Gym	1067	Water Cooler	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1330	Girls Bathroom	2002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1331	Custodial Closet	2003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1332	Custodial Closet	2003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1334	Room 208	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1335	Room 208	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1336	Room 208	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1337	Room 208	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1338	Room 208	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1339	Room 208	2005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1340	Room 213	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1341	Room 213	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1342	Room 213	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1343	Room 213	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1344	Room 213	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1345	Room 213	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1346	Room 211	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1347	Room 211	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1348	Room 211	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1349	Room 211	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1350	Room 211	2006	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1351	Boys Room Bathroom	2004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1352	Room 206	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1353	Room 206	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1354	Room 206	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1355	Room 206	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1356	Room 206	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1357	Room 206	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1358	Room 209	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1359	Room 207	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1361	Ladies Faculty Bathroom	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1362	Ladies Faculty Bathroom	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1363	Faculty Room	2016	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1364	Library Work Room	2020A	Kitchen Faucet (Cold)	Applicable	10/2/2025	3.5			Result Below Action Level Continue O&M
LVT-1365	Men's Faculty Bathroom	2025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1366	Men's Faculty Bathroom	2025	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1367	Men's Faculty Bathroom	2025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1368	Men's Faculty Bathroom	2025	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1371	Custodial Closet	2038	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1372	Boys Bathroom	2039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1373	Boys Bathroom	2039	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1374	Boys Bathroom	2039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1375	Boys Bathroom	2039	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1376	Boys Bathroom	2039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1377	Boys Bathroom	2039	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1378	Boys Bathroom	2039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1379	Boys Bathroom	2039	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1380	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1381	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1382	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1383	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1384	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1385	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1386	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1387	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1388	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1389	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1390	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1391	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1392	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1393	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1394	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1395	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1396	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1397	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1398	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1399	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1585	Boys Entrance Into Gym	1067	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1586	Girls Bathroom	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1587	Girls Bathroom	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1588	Girls Bathroom	2002	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1589	Girls Bathroom	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1590	Girls Bathroom	2002	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1591	Girls Bathroom	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1592	Girls Bathroom	2002	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2295	Blue Cafeteria	1065	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2486	Corridor Guidance To Room 109 (Outside Guidance)	1042	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2494	Green Cafeteria	1063	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2517	Faculty Room	2016	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2519	Corridor Boys Bathroom To Room 221 (Outside Room 231)	2040	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2520	Corridor Room 203 To Room 210 (Outside Room 213)	2015	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2521	Corridor Boiler Room To Room 112 (Outside Room 110)	1055	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2791	Kitchen	1064	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2792	Kitchen	1064	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.3			Result Below Action Level Continue O&M
LVT-2793	Kitchen	1064	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2794	Weight Room	0009	Ice Machine	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2795	Corridor Room 134 to Room 139	4011	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2796	Nurses Office	1023B	Nurse's Office Sink	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Jonas E. Salk Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2797	Room 116 Music Class Room Office 1	1057B3	Bottle Fill Station (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2798	Room 116 Music Class Room Office 1	1057B3	Bottle Fill Station (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2799	Exterior Hose Bib (Outside Blue Café)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2800	Exterior Hose Bib (Outside Gym)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2801	Exterior Hose Bib (Outside Room 115)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2802	Exterior Hose Bib (Outside Room 109)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2803	Exterior Hose Bib (Outside Chorus-Band Room)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2804	Exterior Hose Bib (Outside Orchestra Room)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2805	Exterior Hose Bib (Outside Woodshop)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2806	Exterior Hose Bib (Outside Art Room)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2807	Exterior Hose Bib (Outside Room 110)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2826	Weight Room	0009	Bottle Fill Station	Applicable	10/17/2025	<1.00 ND			Result Below Action Level Continue O&M

Little Red School House

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1400	3 Year Old Classroom	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1401	3 Year Old Classroom Closet	1002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1402	2 Year Old Classroom	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1403	2 Year Old Classroom	1001	Water Fountain-No Chiller	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-1404	2 Year Old Classroom Closet	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1405	3 Year Old Classroom	1002	Water Fountain-No Chiller	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-1408	Bathroom	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1409	Bathroom	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1410	Office Bathroom	1007A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1411	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2901	Main Entrance Corridor	1000	Bottle Fill Station	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2902	Main Entrance Corridor	1000	Water Cooler	Applicable	11/1/2025	OOS			Testing Required Before Return to Service

B&G Office

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1412	Parts Storage Room	1003	Ice Machine	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1413	Wood Shop	1005	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1414	Pipe Storage Room	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1415	Break Room	1017	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1417	Lobby	1019	Bottle Fill Station	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1418	Ladies Bathroom Entrance	1018	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1419	Ladies Bathroom Entrance	1018	Spray Nozzle	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1420	Ladies Bathroom	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1421	Men's Bathroom	1017C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1422	Men's Bathroom	1017C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1423	Men's Bathroom	1017C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1424	Men's Bathroom	1017C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1425	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1426	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2892	Break Room	1017	Spray Nozzle	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2893	Parts Storage Room	1003	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2894	Parts Storage Room	1003	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M

B&G Bus Garage

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1427	Body Shop	1001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1428	Body Shop	1001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1429	Locker Room Bathroom	1000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1430	Locker Room Bathroom	1000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1431	Locker Room Bathroom	1000A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1432	Locker Room	1000	Water Cooler	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1433	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2899	Locker Room	1000	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2900	Locker Room	1000	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M

B&G Transportation Offices

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1434	Basement	0001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1435	Basement	0001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1436	Basement	0001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1437	Bathroom	1000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1438	Kitchen	1004	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1439	Womens Bathroom	2001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1440	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1441	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2895	Kitchen	1004	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2896	Kitchen	1004	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M

New Building next to Transportation Office

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1444	Bathroom	1000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1445	Bathroom	1000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1446	Bathroom	1000B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1447	Bathroom	1000B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1448	Custodial Closet	1002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1449	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1450	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2897	Common Area	1000	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2898	Common Area	1000	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-2905	Common Area	1000	Water Cooler	Applicable	12/5/2025	<1.00 ND			Result Below Action Level Continue O&M

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1451	Room 97	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1452	Room 97	1001	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1453	Room 97 Bathroom	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1454	Custodial Closet (Outside Rm 98/99)	1003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1455	Custodial Closet (Outside Rm 98/99)	1003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1456	Room 99	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1457	Room 99	1004	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1458	Room 99 Bathroom	1004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1459	Room 99 Bathroom	1004A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1460	Room 100	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1461	Room 100	1005	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1462	Room 100 Bathroom	1005B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1463	Room 100 Bathroom	1005B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1465	Room 101 Bathroom	1007A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1466	Room 101 Bathroom	1007A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1467	Room 102	1008	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1468	Room 102 Bathroom	1008A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1469	Room 102 Bathroom	1008A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1470	Room 103	1009	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1471	Room 103 Bathroom	1009A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1472	Room 103 Bathroom	1009A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1474	Room 104 Bathroom	1010A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1475	Room 104 Bathroom	1010A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1478	Room 105 Bathroom	1011A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1479	Room 105 Bathroom	1011A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1480	Room 106 Bathroom	1012A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1481	Room 106 Bathroom	1012A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1482	Room 107 Bathroom	1013A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1483	Room 107 Bathroom	1013A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1484	Room 107A	1015	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1485	Room 108	1014	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1486	Room 108 Bathroom	1014A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1487	Room 108 Bathroom	1014A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1488	Room 110 Bathroom	1017A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1489	Room 110 Bathroom	1017A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1490	Room 115	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1491	Room 120	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1492	Room 118	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1494	Room 113	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1495	Room 116	1033	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1496	Room 114	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1497	Room 111	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1498	Room 112	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1499	Room 109	1027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1500	Girl's Bathroom (Across Rm 112)	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1501	Girl's Bathroom (Across Rm 112)	1026	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1502	Girl's Bathroom (Across Rm 112)	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1503	Girl's Bathroom (Across Rm 112)	1026	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1504	Girl's Bathroom (Across Rm 112)	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1505	Girl's Bathroom (Across Rm 112)	1026	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1506	Girl's Bathroom (Across Rm 112)	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1507	Girl's Bathroom (Across Rm 112)	1026	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1508	Boy's Bathroom (Across Rm 112)	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1510	Boy's Bathroom (Across Rm 112)	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1511	Boy's Bathroom (Across Rm 112)	1025	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1515	Room 305 Art Room	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1516	Room 305 Art Room	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1517	Room 306	1041	Nurse's Office Sink	Applicable	10/2/2025	1.3			Result Below Action Level Continue O&M
LVT-1518	Room 306 Bathroom	1041A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1519	Room 306 Bathroom	1041A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1526	Principal's Office Bathroom	1049A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1527	Principal's Office Bathroom	1049A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1528	Kitchen	1055	Kitchen Service Area	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1529	Kitchen	1055	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.3			Result Below Action Level Continue O&M
LVT-1530	Kitchen	1055	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1531	Kitchen	1055	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.8			Result Below Action Level Continue O&M
LVT-1535	Assistant Principal's Office Bathroom	1050A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1536	Custodial Office Bathroom	1051A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1537	Boiler Room	1052	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1540	Gym Classroom Office Bathroom	1058C2A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1541	Gym Classroom Office Bathroom	1058C2A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1542	Gym Classroom Bathroom	1058C1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1543	Gym Classroom Bathroom	1058C1A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1544	Custodian Closet Storage 1 (Acorss Café)	1057	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1545	Custodian Closet Storage 1 (Acorss Café)	1057	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1546	Custodian Closet Storage 1 (Acorss Café)	1057	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1547	Room 221	1087	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1548	Room 220	1086	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1549	Room 218	1085	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1550	Room 219	1084	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1551	Room 217 A & B	1081	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1552	Girl's Bathroom Adj. Rm 218	1083	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1553	Girl's Bathroom Adj. Rm 218	1083	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1554	Girl's Bathroom Adj. Rm 218	1083	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1555	Girl's Bathroom Adj. Rm 218	1083	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1556	Girl's Bathroom Adj. Rm 218	1083	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1557	Boy's Bathroom Adj. Rm 217	1080	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1558	Boy's Bathroom Adj. Rm 217	1080	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1559	Boy's Bathroom Adj. Rm 217	1080	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1560	Boy's Bathroom Adj. Rm 217	1080	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1561	Boy's Bathroom Adj. Rm 217	1080	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1563	Room 201	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1564	Room 202	1062	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1566	Room 203	1063	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1567	Room 205	1065	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1568	Room 206	1066	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1569	Room 206	1066	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1570	Boy's Bathroom Adj. Rm 206	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1571	Boy's Bathroom Adj. Rm 206	1069	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1572	Boy's Bathroom Adj. Rm 206	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1573	Boy's Bathroom Adj. Rm 206	1069	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1574	Boy's Bathroom Adj. Rm 206	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1575	Boy's Bathroom Adj. Rm 206	1069	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1576	Boy's Bathroom Adj. Rm 206	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1577	Boy's Bathroom Adj. Rm 206	1069	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1578	Girl's Bathroom Adj. Rm 208	1071	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1579	Girl's Bathroom Adj. Rm 208	1071	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1580	Girl's Bathroom Adj. Rm 208	1071	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1581	Girl's Bathroom Adj. Rm 208	1071	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1582	Girl's Bathroom Adj. Rm 208	1071	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1583	Girl's Bathroom Adj. Rm 208	1071	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1584	Girl's Bathroom Adj. Rm 208	1071	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1593	Room 207A	1072	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1594	Room 209	1073	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1597	Room 211	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1598	Room 213	1076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1599	Room 98	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1600	Room 98	1002	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1601	Room 98 Bathroom	1002B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1602	Room 98 Bathroom	1002B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1603	Custodial Closet (Across Rm 207)	1070	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1604	Custodial Closet (Across Rm 207)	1070	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1605	Custodial Closet (Across Rm 207)	1070	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1606	Custodial Closet (Across Rm 217)	1082	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1607	Custodial Closet (Across Rm 217)	1082	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1608	Custodial Closet (Across Rm 217)	1082	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2049	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2050	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2051	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2052	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2053	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2054	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2055	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2056	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2057	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2058	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2059	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2060	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2061	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2062	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2063	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2065	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2223	Assistant Principal's Office	1050	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-2224	Cafeteria	1053	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2237	Main Entrance Vestibule/Lobby	1022	Bottled Water Dispenser	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2238	Main Entrance Vestibule/Lobby	1022	Bottled Water Dispenser	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2280	Kitchen	1055	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2281	Kitchen	1055	Spray Nozzle	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2282	Kitchen	1055	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2325	Room 105	1011	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2332	Custodial Closet (Across Rm 116)	1032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2333	Room 306	1041	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2334	Room 306	1041	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2335	Principal's Office 300C	1049	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2336	Principal's Office 300C	1049	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2337	Kitchen	1055	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2343	Gym Classroom Office	1058C2	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2344	Cafeteria	1053	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2347	Orchestra Room Bathroom	1056A1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2348	Corridor Exit Vestibule By Library	1089	Bottled Water Dispenser	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2349	Corridor Exit Vestibule By Library	1089	Bottled Water Dispenser	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2495	Corridor Rooms 201-220 (Outside Boy's Bathroom)	1088	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2496	Corridor Rooms 201-220 (Outside Room 207)	1088	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2497	Corridor Rooms 109-120 (Outside Room 116)	1038	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2498	Corridor Rooms 101-110 (Outside Room 104)	1020	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2527	Cafeteria	1053	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2544	Room 303 Faculty	1043	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2723	Custodial Office	1051	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2724	Custodial Office	1051	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2810	Gym Classroom Office	1058C2	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2811	Gym Classroom Old Showers	1058C1B	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2812	Gym Classroom Old Showers	1058C1B	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2813	Gym Classroom Old Showers	1058C1B	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2814	Gym Classroom Old Showers	1058C1B	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2815	Gym Classroom Old Showers	1058C1B	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2816	Gym Classroom Old Showers	1058C1B	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2817	Room 101	1007	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2818	Room 104	1010	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2819	Custodial Storage Adjacent to Room 305	1039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

East Broadway Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2820	Custodial Storage Adjacent to Room 305	1039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2821	Custodial Storage Adjacent to Room 305	1039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2822	Faculty Men's/Women's Bathroom	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2823	Women's Room	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2824	Women's Room	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Gardiners Avenue Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1609	Room 100	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1611	Room 100 Bathroom	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1612	Room 100 Bathroom	1001A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1613	Room 101	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1614	Room 101 Bathroom	1000A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1615	Room 101 Bathroom	1000A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1618	Room 102	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1619	Room 103	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1620	Room 104	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1622	Room 105	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1623	Room 106	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1624	Room 107	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1625	Room 108	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1626	Boy's Bathroom Adj. Rm 107	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1627	Boy's Bathroom Adj. Rm 107	1011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1628	Boy's Bathroom Adj. Rm 107	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1629	Boy's Bathroom Adj. Rm 107	1011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1630	Custodial Closet (Across Rm 108)	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1631	Custodial Closet (Across Rm 108)	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1632	Custodial Closet (Across Rm 108)	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Gardiners Avenue Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1633	Girl's Bathroom Adj. Rm 110	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1634	Girl's Bathroom Adj. Rm 110	1013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1635	Girl's Bathroom Adj. Rm 110	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1636	Girl's Bathroom Adj. Rm 110	1013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1638	Room 109	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1639	Room 112 Bathroom	1017A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1640	Room 112 Bathroom	1017A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1642	Men's Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1643	Men's Bathroom	1020	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1644	Women's Bathroom	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1645	Women's Bathroom	1022	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1646	Room 200	1025	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1647	Room 201	1026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1649	Room 202	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1650	Room 203	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1651	Room 204	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1652	Room 205	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1654	Girl's Bathroom Adj. Rm 204	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1655	Girl's Bathroom Adj. Rm 204	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1656	Girl's Bathroom Adj. Rm 204	1032	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Gardiners Avenue Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1657	Custodial Closet (Across Rm 206)	1033	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1658	Custodial Closet (Across Rm 206)	1033	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1659	Custodial Closet (Across Rm 206)	1033	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1660	Room 206	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1661	Boy's Bathroom Adj. Rm 207	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1662	Boy's Bathroom Adj. Rm 207	1034	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1663	Boy's Bathroom Adj. Rm 207	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1664	Assistant Principal Room 200B Bathroom	1037A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1665	Assistant Principal Room 200B Bathroom	1037A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1666	Room 207	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1667	Computer Room 209	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1669	Library	1039	Kitchen Faucet (Cold)	Applicable	10/2/2025	3.0			Result Below Action Level Continue O&M
LVT-1670	Entrance Lobby Men's Bathroom	1042A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1671	Entrance Lobby Men's Bathroom	1042A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1672	Cafeteria	1043	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-1675	Custodians Office	1043D	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-1676	Kitchen	1043C	Kitchen Service Area	Applicable	10/2/2025	71.9	12/3/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
LVT-1680	Kitchen Utensil Storage	1043C1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1681	Kitchen Utensil Storage	1043C1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1682	Kitchen Utensil Storage	1043C1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Gardiners Avenue Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1683	Kitchen Bathroom	1043C4	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1684	Kitchen Bathroom	1043C4	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1685	Entrance Lobby Women's Bathroom	1042B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1686	Entrance Lobby Women's Bathroom	1042B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1687	Principal's Office Bathroom	1042C2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1688	Principal's Office Bathroom	1042C2	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1689	Nurse's Office Bathroom	1045A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1691	Room 300	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1693	Faculty Room 301	1047	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.1			Result Below Action Level Continue O&M
LVT-1694	Chair Persons Office Room 300D Bathroom	1048A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1695	Chair Persons Office Room 300D Bathroom	1048A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1696	Boy's Bathroom Adj. Rm 303	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1697	Boy's Bathroom Adj. Rm 303	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1698	Boy's Bathroom Adj. Rm 303	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1699	Boy's Bathroom Adj. Rm 303	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1700	Boy's Bathroom Adj. Rm 303	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1701	Boy's Bathroom Adj. Rm 303	1049	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1702	Custodial Closet (Across Rm 303)	1050	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1703	Custodial Closet (Across Rm 303)	1050	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1704	Custodial Closet (Across Rm 303)	1050	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Gardiners Avenue Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1705	Girl's Bathroom Adj. Rm 302	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1706	Girl's Bathroom Adj. Rm 302	1051	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1707	Girl's Bathroom Adj. Rm 302	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1709	Girl's Bathroom Adj. Rm 302	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1710	Girl's Bathroom Adj. Rm 302	1051	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1711	Room 302	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1712	Room 303	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1713	Room 304	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1714	Room 305	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1715	Basement North Boiler Room 2	0011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1716	Room 306	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1717	Room 307	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1718	Room 308	1060	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1719	Psychologist Office Room 400A Bathroom	1062A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1720	Psychologist Office Room 400A Bathroom	1062A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1722	Physical Education Office Bathroom	1064A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1723	Physical Education Office Bathroom	1064A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1724	Men's Bathroom Across North Gym	1065	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1725	Men's Bathroom Across North Gym	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1726	Women's Bathroom Across North Gym	1066	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Gardiners Avenue Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1727	Women's Bathroom Across North Gym	1066	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1728	Room 400	1069	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1729	Room 401	1070	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1730	Room 402	1071	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1731	Room 403	1072	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1732	Room 404	1073	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1733	Girl's Bathroom Adj. Rm 404	1074	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1734	Girl's Bathroom Adj. Rm 404	1074	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1735	Girl's Bathroom Adj. Rm 404	1074	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1736	Girl's Bathroom Adj. Rm 404	1074	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1737	Girl's Bathroom Adj. Rm 404	1074	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1738	Girl's Bathroom Adj. Rm 404	1074	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1739	Custodial Closet (Across Rm 403)	1075	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1740	Custodial Closet (Across Rm 403)	1075	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1741	Custodial Closet (Across Rm 403)	1075	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1742	Boy's Bathroom Adj. Rm 406	1076	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1743	Boy's Bathroom Adj. Rm 406	1076	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1744	Boy's Bathroom Adj. Rm 406	1076	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1745	Boy's Bathroom Adj. Rm 406	1076	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1746	Boy's Bathroom Adj. Rm 406	1076	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Gardiners Avenue Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1747	Boy's Bathroom Adj. Rm 406	1076	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1749	Room 405	1077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1750	Room 406	1078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1751	Room 407	1079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1752	Room 408	1080	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1753	Room 409	1084	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1754	Room 410	1083	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1755	Desk Storage	0007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1756	Desk Storage	0007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2033	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2034	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2035	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2037	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2044	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2289	Kitchen	1043C	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.0			Result Below Action Level Continue O&M
LVT-2290	Kitchen	1043C	Spray Nozzle	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2291	Kitchen	1043C	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2292	Kitchen	1043C	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2297	Kitchen	1043C	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.2			Result Below Action Level Continue O&M
LVT-2506	Corridor Rooms 200-Library (Outside Room 205)	1041	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Gardiners Avenue Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2507	Corridor Rooms 100-112 (Outside Room 106)	1018	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2508	Corridor Rooms 300-308 (Outside Nurse's Office)	1061	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2509	Corridor Rooms 400-410 (Outside Room 405)	1085	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2707	Girl's Bathroom Adj. Rm 302	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2708	Exterior Hose Bib (Outside Room 100C)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2709	Exterior Hose Bib (Outside Room 104)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2710	Exterior Hose Bib (Outside Room 109)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2711	Exterior Hose Bib (Outside Room 204)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2712	Exterior Hose Bib (Outside Room 207C)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2713	Exterior Hose Bib (Outside Main Office)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2714	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2715	Exterior Hose Bib (Outside Room 307)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2716	Exterior Hose Bib (Outside Room 305)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2717	Exterior Hose Bib (Outside Room 300)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2718	Exterior Hose Bib (Outside Room 206)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2719	Exterior Hose Bib (Outside Room 201)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2825	Cafeteria	1043	Bottle Fill Station	Applicable	10/11/2025	<1.00 ND			Result Below Action Level Continue O&M

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1757	Boiler Room	0001A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1758	Boiler Room	0001A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1759	Boiler Room	0001A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1760	Room 11	0005	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1761	Room 11	0005	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1762	Room 11	0005	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1763	Room 11	0005	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1764	Room 11	0005	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1766	Room 9	0006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1767	Room 9	0006	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1769	Room 7	0007	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1770	Room 7	0007	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1771	Room 7	0007	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1773	Room 7	0007	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1775	Ladies Bathroom	0013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1776	Ladies Bathroom	0013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1777	Mens Bathroom	0014	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1778	Mens Bathroom	0014	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1779	Custodial Closet	0015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1780	Custodial Closet	0015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1781	Custodial Closet	0015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1782	Ladies Bathroom	0018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1783	Ladies Bathroom	0018A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1784	Men's Bathroom	0019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1785	Men's Bathroom	0019A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1792	Corridor Room 5 to Custodial Area	0029	Bottle Fill Station	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1793	Room 2 Nurse Office	0028	Nurse's Office Sink	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1795	Garage	0030B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1796	Custodial Corridor	0030	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-1797	Room 123 Sink Room	1000C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1798	Room 123 Sink Room	1000C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1799	Room 120 Office Bathroom Closet	1003A1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1800	Room 120 Storage/Old Bathroom	1003B	Water Fountain-No Chiller	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-1801	Room 120 Storage/Old Bathroom	1003B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1802	Room 120 Storage/Old Bathroom	1003B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1803	Room 120 Storage/Old Bathroom	1003B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1804	Room 120 Storage/Old Bathroom	1003B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1805	Room 120 Storage/Old Bathroom	1003B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1806	Room 120 Storage/Old Bathroom	1003B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1807	Custodial Closet	1007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1808	Custodial Closet	1007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1809	Custodial Closet	1007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1810	Room 115	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1811	Room 101 Kitchen	1021	Kitchen Faucet (Cold)	Applicable	11/1/2025	6.8			Removed From Service, Pending Remediation
LVT-1812	Room 101 Kitchen	1021	Kitchen Faucet (Cold)	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-1813	Ladies Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1814	Ladies Bathroom	1020	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1815	Ladies Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1816	Ladies Bathroom	1020	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1817	Custodial Closet	1019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1818	Custodial Closet	1019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1819	Custodial Closet	1019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1820	Men's Bathroom	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1821	Men's Bathroom	1018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1823	Men's Bathroom	1018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1824	Room 100	1017	Kitchen Faucet (Cold)	Applicable	11/1/2025	8.0			Removed From Service, Pending Remediation
LVT-1826	Room 108	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1827	Room 110	1011	Kitchen Faucet (Cold)	Applicable	11/1/2025	22.2			Removed From Service, Pending Remediation
LVT-1828	Room 110	1011	Spray Nozzle	Applicable	11/1/2025	4.7			Result Below Action Level Continue O&M
LVT-1830	Culinary Boys Dressing Room	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1831	Culinary Boys Dressing Room	1028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1832	Culinary Boys Dressing Room	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1833	Culinary Boys Dressing Room	1028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1834	Culinary Boys Dressing Room	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1835	Culinary Boys Dressing Room	1028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1836	Culinary Boys Dressing Room	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1837	Culinary Boys Dressing Room	1028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1838	Culinary Boys Dressing Room	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1839	Culinary Boys Dressing Room	1028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1840	Culinary Boys Dressing Room	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1841	Culinary Boys Dressing Room	1028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1842	Culinary Girls Dressing Room	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1843	Culinary Girls Dressing Room	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1844	Culinary Girls Dressing Room	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1845	Culinary Girls Dressing Room	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1846	Culinary Girls Dressing Room	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1847	Culinary Girls Dressing Room	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1848	Culinary Girls Dressing Room	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1849	Culinary Girls Dressing Room	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1850	Culinary Girls Dressing Room	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1851	Culinary Girls Dressing Room	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1852	Culinary Girls Dressing Room	1029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1853	Culinary Girls Dressing Room	1029	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1854	Fitness Room 206	1034	Kitchen Faucet (Cold)	Applicable	11/1/2025	5.1			Removed From Service, Pending Remediation
LVT-1855	Fitness Room 206	1034	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-1857	Ladies Bathroom	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1858	Ladies Bathroom	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1859	Ladies Bathroom	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1860	Ladies Bathroom	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1861	Ladies Bathroom	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1862	Ladies Bathroom	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1863	Ladies Bathroom	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1864	Ladies Bathroom	1036	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1865	Ladies Bathroom	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1872	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1873	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1874	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1875	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1876	Men's Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1877	Men's Bathroom	1038	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1878	Custodial Closet	1042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1879	Custodial Closet	1042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1880	Custodial Closet	1042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1882	Room 301 Bathroom	1065A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1885	Men's Bathroom	1067	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1886	Custodial Closet	1068	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1887	Custodial Closet	1068	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1888	Custodial Closet	1068	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1891	Men's Bathroom	1078	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1892	Ladies Bathroom	1077	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1894	Room 422A	1073A	Kitchen Faucet (Cold)	Applicable	11/1/2025	13.7			Removed From Service, Pending Remediation
LVT-1895	Room 409 Kitchen/Conference	1086A	Kitchen Faucet (Cold)	Applicable	11/1/2025	4.5			Result Below Action Level Continue O&M
LVT-1896	Room 414	1089	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1897	Room 410 Assistant Superintendents Office	1090D2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1899	Men's Room	1095	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1900	Room 401	1097	Kitchen Faucet (Cold)	Applicable	11/1/2025	3.9			Result Below Action Level Continue O&M
LVT-1901	Room 401	1097	Ice Machine	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-1902	Room 401	1097	Kitchen Faucet (Cold)	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-1903	Room 401	1097	Kitchen Faucet (Cold)	Applicable	11/1/2025	141			Removed From Service, Pending Remediation
LVT-1904	Room 401	1097	Kitchen Faucet (Cold)	Applicable	11/1/2025	OOS			Testing Required Before Return to Service

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1907	Room 401	1097	Spray Nozzle	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-1908	Room 401 Freezer Room Bathroom	1097C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1909	Room 401 Freezer Room Bathroom	1097C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1910	Room 401	1097	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-1911	Superintendent Office Bathroom	1098B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1912	Superintendent Conference Room Bathroom	1098A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1913	Superintendent Office Conference Room	1098A	Kitchen Faucet (Cold)	Applicable	11/1/2025	4.5			Result Below Action Level Continue O&M
LVT-1915	Ladies Bathroom	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1916	Ladies Bathroom	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1917	Ladies Bathroom	1027	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1918	Gym Office Bathroom	1040A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1919	Gym Office Bathroom	1040A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2015	Exterior	N/A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-2025	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2026	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2027	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2028	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2029	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2030	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2031	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2032	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2493	Room 209 Wood Shop	1039D	Bottle Fill Station	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2499	Room 209 Wood Shop Closet 2 (Boy's Bathroom)	1039D2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2500	Room 209 Wood Shop Closet 2 (Boy's Bathroom)	1039D2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2501	Room 209 Wood Shop Closet 3 (Girls Bathroom)	1039D4	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2502	Room 209 Wood Shop Closet 3 (Girls Bathroom)	1039D4	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2510	Room 209 Wood Shop Locker Room	1039D3	Ice Machine	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2518	Corridor Auditorium To Lobby (Outside Room 414)	1092	Bottle Fill Station	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2827	Room 11	0005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2828	Room 11	0005	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2829	Room 7 Laundry Room 7A	0007A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2830	Room 7	0007	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
LVT-2831	Room 7	0007	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2832	Ladies Bathroom	0013	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2833	Room 5 Printing Room	0020A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2834	Room 5 Printing Room	0020A	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2835	Room 1 (Garage/Auto Shop)	0027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2836	Room 1 (Garage/Auto Shop)	0027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2837	Room 1 (Garage/Auto Shop)	0027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2838	Room 1 (Garage/Auto Shop)	0027	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2839	Room 2 Nurse Office	0028	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2840	Room 2 Nurse Bathroom	0028A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2841	Room 120 Storage/Old Bathroom	1003B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2842	Men's Bathroom	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2843	Corridor Outside Gymnasium	1041	Bottle Fill Station	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2844	Room 318	1047	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2845	Room 318	1047	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-2846	Room 309	1056	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-2847	Room 309	1056	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-2848	Room 304	1061	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2849	Room 304	1061	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2850	Men's Bathroom	1067	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2851	Ladies Bathroom	1069	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2852	Ladies Bathroom	1069	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2853	Room 420	1071	Kitchen Faucet (Cold)	Applicable	11/1/2025	2.5			Result Below Action Level Continue O&M
LVT-2854	Room 420	1071	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2855	Room 420	1071	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2856	Janitors Closet	1079	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2857	Ladies Room	1094	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2858	Superintendent Office Bathroom	1098B1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service RFI = Removed from Inventory

Levittown Memorial Education Center

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2859	Exterior o/s Main Entrance	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2860	Exterior o/s Room 403	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2861	Exterior o/s Room 401	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2862	Exterior o/s Automative Repair Shop	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2863	Exterior o/s Room 5	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2864	Exterior o/s Room 13	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2865	Exterior o/s Boiler Room	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2866	Exterior o/s Boiler Room	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2867	Exterior o/s Room 120	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2868	Exterior o/s Gymnasium	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2869	Exterior o/s Room 320A	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2870	Exterior o/s Room 304	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2871	Exterior o/s Room 405	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2903	Room 109	1024	Bottled Water Dispenser (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2904	Room 109	1024	Bottled Water Dispenser (Hot)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M

Lee Road Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1920	Room 1	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1922	Room 1 Bathroom	1015B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1923	Room 1 Bathroom	1015B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1926	Storage Bathroom	1013A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1927	Storage Bathroom	1013A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1928	Gym Office Bathroom	1012B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1929	Room 22	1021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1930	Room 22	1021	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1931	Room 22 Bathroom	1021A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1932	Room 23	1019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1933	Room 23	1019	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1934	Room 23 Bathroom	1019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1935	Art Room 24	1018	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1936	Art Room 24	1018	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1937	Art Bathroom	1018A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1938	Room 25	1020	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1939	Room 25	1020	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1940	Room 25 Bathroom	1020A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1941	Room 22A	1022	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1942	Room 3	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Lee Road Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1943	Room 3 Bathroom	1008B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1944	Room 3 Bathroom	1008B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1945	Room 5	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1946	Room 5	1006	Water Fountain-No Chiller	RFI	10/2/2025	10.8			Removed From Inventory
LVT-1947	Room 5 Bathroom	1006B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1948	Room 5 Bathroom	1006B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1949	Room 7	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1950	Room 7	1004	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1951	Room 7 Bathroom	1004B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1952	Room 7 Bathroom	1004B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1953	Room 9	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1954	Room 9	1002	Water Fountain-No Chiller	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1955	Room 9 Bathroom	1002C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1956	Room 9 Bathroom	1002C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1957	Room 10	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1959	Room 10 Bathroom	1001B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1960	Room 10 Bathroom	1001B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1961	Room 8 Kindergarten	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1962	Room 8 Kindergarten	1003	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1963	Room 8 Bathroom	1003B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service RFI = Removed from Inventory

Lee Road Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1964	Room 8 Bathroom	1003B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1965	Room 6	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1966	Room 6	1005	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1967	Room 6 Bathroom	1005B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1968	Room 6 Bathroom	1005B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1969	Room 4	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1970	Room 4	1007	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-1971	Room 4 Bathroom	1007B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1972	Room 4 Bathroom	1007B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1976	Lobby All Gender Staff Only Bathroom	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1977	Cafeteria All Gender Bathroom 1	1030A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1978	Cafeteria All Gender Bathroom 1	1030A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1979	Cafeteria	1030	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1981	Cafeteria	1030	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1982	Cafeteria All Gender Bathroom 2	1030B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1983	Cafeteria All Gender Bathroom 2	1030B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1984	Corridor Between Principal and Office Bathroom	1033B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1985	Nurse's Office Bathroom	1034B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1986	Kitchen	1031	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1987	Kitchen	1031	Spray Nozzle	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Lee Road Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-1988	Kitchen	1031	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-1989	Boiler Room Entrance off Corridor	1036	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1990	Boiler Room Entrance off Corridor	1036	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1991	Boiler Room Entrance off Corridor	1036	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1994	Fountain Vestibule (Outside Student Bathrooms)	2002	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-1995	Custodial Adjacent to Room 11	2007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-1996	Room 12	2008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1997	Room 11	2009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1998	Room 14	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-1999	Room 13	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2000	Room 13	2011	Water Fountain-No Chiller	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2001	Room 16	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2002	Room 16	2012	Water Fountain-No Chiller	Applicable	10/2/2025	4.0			Result Below Action Level Continue O&M
LVT-2003	Room 15	2013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2004	Room 15	2013	Water Fountain-No Chiller	Applicable	10/2/2025	1.0			Result Below Action Level Continue O&M
LVT-2005	Exterior Hose Bib (Outside Main Entrance)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2006	Exterior Hose Bib (Outside Gym/Exit Door 2)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2007	Exterior Hose Bib (Outside Room 25)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2008	Exterior Hose Bib (Outside Room 10)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2009	Exterior Hose Bib (Outside Room 6)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Lee Road Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2010	Exterior Hose Bib (Outside Cafeteria)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2479	Lobby Women's Bathroom	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2480	Lobby Women's Bathroom	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2702	Faculty Room	1011	Kitchen Faucet (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2703	Corridor Rooms 1-10 (Outside Gym)	1016	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2704	Nurse's Office	1034	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2705	Nurse's Office	1034	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2706	Nurse's Office	1034	Eye Wash	Non-Applicable					Placarded for Non-Drinking Use
LVT-2720	Fountain Vestibule (Outside Student Bathrooms)	2002	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2721	Custodial Office	1035	Bottled Water Dispenser (Cold)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2722	Custodial Office	1035	Bottled Water Dispenser (Hot)	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Laurel Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2064	Room 101 Boys Bathroom	1000B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2066	Room 104 Bathroom	1002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2067	Room 104 Bathroom	1002A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2069	Room 105	1003	Kitchen Faucet (Cold)	Applicable	10/2/2025	2.2			Result Below Action Level Continue O&M
LVT-2070	Bathroom D	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2071	Main Office	1009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2072	Bathroom D	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2073	Main Office	1009	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2074	Principal's Office Bathroom	1005A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2075	Small Kitchen	1008	Kitchen Faucet (Cold)	Applicable	10/2/2025	5.3	12/12/2025	1.8	Outlet Remediated and Returned to Service Continue O&M
LVT-2076	Corridor Server Room - Room 102	1016	Water Cooler	Applicable	10/2/2025	OOS			Testing Required Before Return to Service
LVT-2077	Bathroom E	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2078	Receiving	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2079	Boiler Room	1014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2080	Kitchen	1013	Kitchen Faucet (Cold)	Applicable	10/2/2025	8.6	12/12/2025	<1.00 ND	Outlet Remediated and Returned to Service Continue O&M
LVT-2081	Kitchen	1013	Kitchen Faucet (Cold)	Applicable	10/2/2025	8.0	12/12/2025	1.4	Outlet Remediated and Returned to Service Continue O&M
LVT-2082	Visitor Bathroom	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2083	Room 108 Associate Executive Director Office	1017	Kitchen Faucet (Cold)	Applicable	10/2/2025	1.1			Result Below Action Level Continue O&M
LVT-2084	Bathroom G	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2085	Room 114 Nurse/Classroom 5	1027	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Laurel Lane School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2086	Room 114/Classroom 5 Bathroom	1027A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2087	Room 114/Classroom 5 Bathroom	1027A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2089	Room 115/Exercise Bathroom	1028A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2090	Room 115/Exercise Room	1028	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2091	Room 118/Classroom 6	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2092	Room 118/Classroom 6 Bathroom	1032A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2093	Room 118/Classroom 6 Bathroom	1032A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2094	Room 117/Clinic 2 / Room 8	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2095	Room 117/Clinic 2 Bathroom	1031A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2096	Room 117/Clinic 2 Bathroom	1031A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2097	Room 116/Clinic 1	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2098	Room 116/Clinic 1 Bathroom	1030A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2099	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2100	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2101	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2102	Exterior Hose Bib	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2239	Room 118/Classroom 6	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2240	Corridor Gymnasium - Room 118	1033	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-2241	Corridor Server Room - Room 102	1016	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-2485	Corridor Server Room - Room 102	1016	Bottle Fill Station	Applicable	10/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Seaman Neck Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2103	Room 201	2000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2104	Room 203 Classroom	2001A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2105	Room 204	2005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2106	2nd Floor Corridor near Gang Bathrooms	2016	Water Fountain-No Chiller	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-2107	Room 205	2004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2108	Girls Bathroom	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2109	Girls Bathroom	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2110	Girls Bathroom	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2111	Girls Bathroom	2006	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2112	Custodial Closet	2007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2117	Boys Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2118	Boys Bathroom	2008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2119	Room 207 Classroom	2009A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2120	Room 209	2010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2121	Room 206	2011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2122	Room 211 Classroom	2013A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2123	Room 208	2012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2124	Room 210	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2125	Room 110 Classroom	1032A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2127	Thinking Room 1 Resource Room	1030A	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M

Seaman Neck Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2128	Room 106	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2129	Room 109	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2130	Boys Bathroom	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2132	Boys Bathroom	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2134	Custodial Storage	1025	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2135	Women's Bathroom	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2136	Women's Bathroom	1024	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2138	Women's Bathroom	1024	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2139	Room 107 Classroom	1027A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2140	Room 104 Classroom	1023A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2141	Room 105 Classroom	1022A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2143	Room 102	1020	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2144	Room 103	1019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2145	Room 101 Classroom	1018A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2146	Corridor Rooms 101 To 110 near Gang Bathrooms	1033	Water Fountain-No Chiller	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-2148	Men's Room	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2149	Men's Room	1011	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2152	Custodial Office Bathroom	1006C	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2153	Nurse's Office	1000	Nurse's Office Sink	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2154	Nurse's Bathroom	1000B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Seaman Neck Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2155	Nurse's Bathroom	1000B	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2156	K2 Kitchen/Classroom	1002B	Home Economics Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2157	Shop Room	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2158	Corridor Custodial Closet Outside Kitchen	1055	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2159	Kitchen	1034	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2160	Kitchen	1034	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2161	Kitchen	1034	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2162	Kitchen	1034	Spray Nozzle	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2163	Kitchen Bathroom	1034C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2164	Cafeteria	1035	Water Cooler	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2166	Ladies Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2167	Ladies Bathroom	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2171	Room 304	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2172	Room 302	1051	Home Economics Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2173	Room 303 Classroom	1053A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2174	Room 301	1050	Home Economics Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2175	Room 301	1050	Home Economics Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2176	Girls Bathroom	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2177	Corridor Outside Gymnasium adj. Gymnasium Entrance	1054	Water Fountain-No Chiller	Applicable	11/1/2025	1.2			Result Below Action Level Continue O&M
LVT-2178	Men's Bathroom	1048	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Seaman Neck Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2179	Custodial Closet	1045	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
LVT-2180	Corridor Outside Gymnasium near Gang Bathrooms	1054	Water Fountain-No Chiller	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2181	Physical Education Office Bathroom	1047A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2182	Physical Education Office Bathroom	1047A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2184	Weight Room Closet	1047B1	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
LVT-2187	Gym Coach Office Bathroom	1040B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2188	Gym Coach Office Bathroom	1040B1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2385	Room 108 Classroom	1031A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2386	Kitchen	1034	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2388	Physical Therapy Office Bathroom	1040A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2389	Physical Therapy Office Bathroom	1040A1	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2390	Room 305	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2391	Boys Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2392	Boys Bathroom	2008	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2393	Boys Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2394	Boys Bathroom	2008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2395	Room 210	2014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2872	Custodial Office Bathroom	1006C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2873	Custodial Office Bathroom	1006C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
LVT-2874	Corridor Men's Bathroom To Principal's Office adj.	1012	Bottle Fill Station	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M

Seaman Neck Middle School


Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
LVT-2875	Corridor Men's Bathroom To Principal's Office adj.	1012	Water Cooler	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2876	Ladies Room	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2877	Women's Bathroom	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2878	Boys Bathroom	1026	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2879	Boys Bathroom	1026	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2880	Faculty Room	1036	Kitchen Faucet (Cold)	Applicable	11/1/2025	<1.00 ND			Result Below Action Level Continue O&M
LVT-2881	Ladies Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2882	Ladies Bathroom	1037	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2883	Men's Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
LVT-2884	Weight Room	1047B	Water Fountain-No Chiller	Applicable	11/1/2025	OOS			Testing Required Before Return to Service
LVT-2885	Exterior Hose Bib o/s Main Entrance	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2886	Exterior Hose Bib o/s Kitchen	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2887	Exterior Hose Bib o/s Room 305	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2888	Exterior Hose Bib o/s Room 301	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2889	Exterior Hose Bib o/s Gang Bathrooms 1024/1026	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2890	Exterior Hose Bib o/s Room 111	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
LVT-2891	Exterior Hose Bib o/s Room 103	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Attachment 3:

Laboratory Analytical Reports



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395



Lead in Water: Chain of Custody for ED56606

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53783
Building: Laurel Lane School
LLS

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2069	OF	1003	Room 105	KC	10/2/2025	10:43:00 AM
LVT-2075	OF	1008	Small Kitchen	KC	10/2/2025	10:48:00 AM
LVT-2080	KI	1013	Kitchen	KC	10/2/2025	10:48:00 AM
LVT-2081	KI	1013	Kitchen	KC	10/2/2025	10:48:00 AM
LVT-2083	FL	1017	Room 108 Associate Executive Director Office	KC	10/2/2025	10:58:00 AM
LVT-2485	HA	1016	Corridor Server Room - Room 102	WF	10/2/2025	10:42:00 AM

Samples Submitted 6



RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 17 25, PM 01:25

Pb 200.8
Kathleen
10/23/25

Building Address

11 Laurel Lane
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 10/17/25 1:25 PM

Signature: David Wharton

Samplers Name: Connor Molanphy

Samplers Signature: CM

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556606**LIMS Reference ID:** ED56606**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - Laurel Lane School LLS - 11 Laurel Lane, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:25
Reported: 11/26/2025 08:45

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2069									
Metals									
Lead	2.2	1	1.0	µg/L	10/23/25 13:38	10/23/25 13:38	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2075									
Metals									
Lead	5.3	1	1.0	µg/L	10/23/25 13:41	10/23/25 13:41	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2080									
Metals									
Lead	8.6	1	1.0	µg/L	10/23/25 13:43	10/23/25 13:43	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2081									
Metals									
Lead	8.0	1	1.0	µg/L	10/23/25 14:05	10/23/25 14:05	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2083									
Metals									
Lead	1.1	1	1.0	µg/L	10/23/25 14:07	10/23/25 14:07	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2485									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:08	10/23/25 14:08	KT1	EPA 200.8 (DA)/EPA 200.8	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556606

LIMS Reference ID: ED56606

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - Laurel Lane School LLS - 11 Laurel Lane, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:25
Reported: 11/26/2025 08:45

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556606

LIMS Reference ID: ED56606

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - Laurel Lane School LLS - 11 Laurel Lane, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:25
Reported: 11/26/2025 08:45


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56607

Page 1 of 2

JCB #:

23-53783

Building: East Broadway Elementary School

EBE

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1517	NO	1041	Room 306	NS	10/2/2025	11:48:00 AM
LVT-1528	KI	1055	Kitchen	SA	10/2/2025	12:05:00 PM
LVT-1529	KI	1055	Kitchen	KC	10/2/2025	12:06:00 PM
LVT-1530	KI	1055	Kitchen	KC	10/2/2025	12:06:00 PM
LVT-1531	KI	1055	Kitchen	KC	10/2/2025	12:08:00 PM
LVT-2224	CA	1053	Cafeteria	BWC	10/2/2025	12:03:00 PM
LVT-2237	HA	1022	Main Entrance Vestibule/Lobby	BW	10/2/2025	11:25:00 AM
LVT-2238	HA	1022	Main Entrance Vestibule/Lobby	BW	10/2/2025	11:25:00 AM
LVT-2280	KI	1055	Kitchen	KC	10/2/2025	12:06:00 PM
LVT-2281	KI	1055	Kitchen	SN	10/2/2025	12:08:00 PM
LVT-2282	KI	1055	Kitchen	KC	10/2/2025	12:07:00 PM
LVT-2333	NO	1041	Room 306	BWC	10/2/2025	11:49:00 AM
LVT-2334	NO	1041	Room 306	BWH	10/2/2025	11:49:00 AM
LVT-2335	OF	1049	Principal's Office 300C	BWC	10/2/2025	11:57:00 AM
LVT-2336	OF	1049	Principal's Office 300C	BWH	10/2/2025	11:57:00 AM
LVT-2343	OF	1058C2	Gym Classroom Office	BWC	10/2/2025	12:17:00 PM
LVT-2344	CA	1053	Cafeteria	BWH	10/2/2025	12:03:00 PM
LVT-2348	HA	1089	Corridor Exit Vestibule By Library	BW	10/2/2025	12:20:00 PM

Building Address

751 Seaman Neck Road
Seaford, NY 11783

Analysis Type: ELAP 200.5

Lab Received: DAVID WHITROW


10/17/25
1:24 PM

Signature: David Whitrow

Samplers Name: Anthony Lombardo

Samplers Signature: 

JCB Project Manager: LOMBARDO



Lead in Water: Chain of Custody for **ED56607**

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53783

Building: East Broadway Elementary School

EBE

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2349	HA	1089	Corridor Exit Vestibule By Library	BW	10/2/2025	12:21:00 PM
LVT-2495	HA	1088	Corridor Rooms 201-220 (Outside Boy's Bathroom)	WF	10/2/2025	12:31:00 PM
LVT-2496	HA	1088	Corridor Rooms 201-220 (Outside Room 207)	WF	10/2/2025	12:27:00 PM
LVT-2497	HA	1038	Corridor Rooms 109-120 (Outside Room 116)	WF	10/2/2025	11:40:00 AM
LVT-2498	HA	1020	Corridor Rooms 101-110 (Outside Room 104)	WF	10/2/2025	11:22:00 AM
LVT-2527	CA	1053	Cafeteria	WF	10/2/2025	12:04:00 PM
LVT-2544	FL	1043	Room 303 Faculty	KC	10/2/2025	11:52:00 AM
LVT-2723	OF	1051	Custodial Office	BWC	10/2/2025	12:02:00 PM
LVT-2724	OF	1051	Custodial Office	BWH	10/2/2025	12:01:00 PM
LVT-2810	OF	1058C2	Gym Classroom Office	BWH	10/2/2025	12:17:00 PM

Samples Submitted 28

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

OCT 17 25, PM01:25

PB 2008 Katharine 10/23/25

Building Address

751 Seaman Neck Road
Seaford, NY 11783

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 10/17/25 1:25 PM

Signature: *David Wharton*

Samplers Name: *Anthony Lombardo*

Samplers Signature: *AL*

JCB Project Manager: *Lombardo*

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556607**LIMS Reference ID:** ED56607**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
East Broadway Elementary School EBE - 751
Seaman Neck Road, Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:24
Reported: 11/26/2025 08:46

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1517									
Metals									
Lead	1.3	1	1.0	µg/L	10/23/25 14:09	10/23/25 14:09	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1528									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:11	10/23/25 14:11	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1529									
Metals									
Lead	1.3	1	1.0	µg/L	10/23/25 14:12	10/23/25 14:12	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1530									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:13	10/23/25 14:13	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1531									
Metals									
Lead	1.8	1	1.0	µg/L	10/23/25 14:14	10/23/25 14:14	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2224									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:21	10/23/25 14:21	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2237									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:22	10/23/25 14:22	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2238									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:23	10/23/25 14:23	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2280									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556607**LIMS Reference ID:** ED56607**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
East Broadway Elementary School EBE - 751
Seaman Neck Road, Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:24
Reported: 11/26/2025 08:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2280 (Continued)									Sampled: 10/02/25 00:00:00
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:25	10/23/25 14:25	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2281									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:26	10/23/25 14:26	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2282									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:27	10/23/25 14:27	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2333									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:29	10/23/25 14:29	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2334									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:30	10/23/25 14:30	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2335									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:31	10/23/25 14:31	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2336									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:48	10/23/25 14:48	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2337									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 16:29	10/24/25 16:29	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2344									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 16:29	10/24/25 16:29	KT1	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062556607**LIMS Reference ID:** ED56607**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
 East Broadway Elementary School EBE - 751
 Seaman Neck Road, Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:24
Reported: 11/26/2025 08:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2344 (Continued)									
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:52	10/23/25 14:52	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2348									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:53	10/23/25 14:53	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2349									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:54	10/23/25 14:54	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2495									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:58	10/23/25 14:58	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2496									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 14:59	10/23/25 14:59	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2497									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 15:01	10/23/25 15:01	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2498									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 15:02	10/23/25 15:02	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2527									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 15:03	10/23/25 15:03	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2544									
Metals									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556607

LIMS Reference ID: ED56607

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
East Broadway Elementary School EBE - 751
Seaman Neck Road, Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:24
Reported: 11/26/2025 08:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2544 (Continued)									
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/23/25 15:05	10/23/25 15:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2723									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 15:06	10/23/25 15:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2724									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 15:10	10/23/25 15:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2810									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/23/25 15:14	10/23/25 15:14	KT1	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556607

LIMS Reference ID: ED56607

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
East Broadway Elementary School EBE - 751
Seaman Neck Road, Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:24
Reported: 11/26/2025 08:46

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556607

LIMS Reference ID: ED56607

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
East Broadway Elementary School EBE - 751
Seaman Neck Road, Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:24
Reported: 11/26/2025 08:46

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56612

JCB #:

23-53783

Building: General Douglas MacArthur High School

MAC

Client:

Levittown Union Free School District

Courier

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0096	NO	2044	Nurses Office	NS	10/2/2025	7:23:00 AM
LVT-0097	NO	2044B	Nurses Office Sick Room	NS	10/2/2025	7:22:00 AM
LVT-0101	FL	2014	Faculty Lounge 213	KC	10/2/2025	7:27:00 AM
LVT-0102	FL	2014	Faculty Lounge 213	KC	10/2/2025	7:26:00 AM
LVT-0109	HA	2045	Corridor From Nurses Office to Room 99 (Outside Guidance Suite)	DW	10/2/2025	7:49:00 AM
LVT-0124	KI	2034	Kitchen	KC	10/2/2025	7:30:00 AM
LVT-0126	KI	2034	Kitchen	KC	10/2/2025	7:31:00 AM
LVT-0127	KI	2034	Kitchen	KC	10/2/2025	7:31:00 AM
LVT-0128	KI	2034	Kitchen	KC	10/2/2025	7:32:00 AM
LVT-0217	OF	3021A2	Assistant Principals Office	KC	10/2/2025	7:57:00 AM
LVT-0220	KI	5000	Concession Stand Kitchen	KC	10/2/2025	8:12:00 AM
LVT-2298	HA	7002	Corridor Room C19 to Room C21 (Outside Room C7)	WF	10/2/2025	EMSL ANALYTICAL INC.
LVT-2450	OF	3015	Science Office	BWC	10/2/2025	Carrie Platzer 7:59:00 AM OCT 17 2025, PM03:33
LVT-2451	OF	3015	Science Office	BWH	10/2/2025	7:59:00 AM
LVT-2452	OF	2018	Room 205 Attendance Suite	BWC	10/2/2025	7:45:00 AM
LVT-2453	OF	2018	Room 205 Attendance Suite	BWH	10/2/2025	7:45:00 AM
LVT-2471	CR	2017	Room 207	BWC	10/2/2025	7:44:00 AM
LVT-2472	CR	2017	Room 207	BWH	10/2/2025	7:44:00 AM

Building Address

3369 Jerusalem Road
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: DAN 10 WATERTON

Signature: Dan Waterton

10/17/25 Samplers Name: Willow Mercer

3:33 pm Samplers Signature: WM

JCB Project Manager: Anthony Lombardo

PL 2008
10/12/25



Lead in Water: Chain of Custody for

ED56612

Page 2 of 3

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53783

Building: General Douglas MacArthur High School

MAC

Client:

Levittown Union Free School District

Retest/New Install

Turn Arounds Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2483	ST	1042	New Gym Ice Machine Closet	IM	10/2/2025	7:09:00 AM
LVT-2484	ST	1042	New Gym Ice Machine Closet	WF	10/2/2025	7:09:00 AM
LVT-2515	HE	2015	Room 211 (Refrigerator)	IM	10/2/2025	7:39:00 AM
LVT-2549	FL	1024A	Custodial Office Break Room	BWC	10/2/2025	7:14:00 AM
LVT-2550	FL	1024A	Custodial Office Break Room	BWH	10/2/2025	7:14:00 AM
LVT-2551	HA	1031	Gym Lobby/Corridor (Outside Bathrooms)	WF	10/2/2025	7:12:00 AM
LVT-2552	HE	2015	Room 211	EC	10/2/2025	7:36:00 AM
LVT-2553	HE	2015	Room 211	EC	10/2/2025	7:36:00 AM
LVT-2554	HE	2015	Room 211	EC	10/2/2025	7:37:00 AM
LVT-2555	HE	2015	Room 211	EC	10/2/2025	7:37:00 AM
LVT-2557	CA	2033	Cafeteria A	WF	10/2/2025	7:34:00 AM
LVT-2558	KI	2034	Kitchen	KC	10/2/2025	RECEIVED 7:30:00 AM
LVT-2559	KI	2034	Kitchen (Adj. Serving Line)	WF	10/2/2025	EMSL ANALYTICAL, INC. 7:29:00 AM
LVT-2560	ST	2043K	Guidance Suite File Area	BWC	10/2/2025	Carle Place, NY 7:48:00 AM OCT 17 25, PM 03:34
LVT-2561	ST	2043K	Guidance Suite File Area	BWH	10/2/2025	7:48:00 AM
LVT-2563	HA	N/A	Main Lobby adj. Staff Bathrooms	WF	10/2/2025	8:06:00 AM
LVT-2578	OF	3026	Room 302 Social Studies Chairperson	BWC	10/2/2025	7:56:00 AM
LVT-2579	OF	3026	Room 302 Social Studies Chairperson	BWH	10/2/2025	7:56:00 AM

Building Address

3369 Jerusalem Road
Levittown, NY 11756

Analysis Type: ELAP 200.5


Lab Received: DAVID MARTON 10/17/25 3:33PM

Signature: David Marton

Samplers Name: Willow Mercer

Samplers Signature: WM

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56612

JCB #: 23-53783

Building: General Douglas MacArthur High School

MAC

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2789	HA	1040	New Gym Lobby o/s Ice Room	WF	10/2/2025	7:05:00 AM
LVT-2790	EX		Exterior Hose Bib (Outside Snack Shack)	HB	10/2/2025	8:13:00 AM

Samples Submitted 38

PC 2008 Print 10/22/25

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

OCT 17 25, PM03:34

Building Address

3369 Jerusalem Road
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: DAVID MARTON 10/17/25
3:34 pm

Signature: David whalen

Samplers Name: Willow Mercer

Samplers Signature: WM

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556612**LIMS Reference ID:** ED56612**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - General Douglas MacArthur High School MAC - 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 15:33
Reported: 11/26/2025 08:47

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0096									
Metals									
Lead									
Sample: LVT-0097									
Metals									
Lead									
Sample: LVT-0101									
Metals									
Lead									
Sample: LVT-0102									
Metals									
Lead									
Sample: LVT-0109									
Metals									
Lead									
Sample: LVT-0124									
Metals									
Lead									
Sample: LVT-0126									
Metals									
Lead									
Sample: LVT-0127									
Metals									
Lead									
Sample: LVT-0128									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556612**LIMS Reference ID:** ED56612**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - General Douglas MacArthur High School MAC - 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 15:33
Reported: 11/26/2025 08:47

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0128 (Continued)									
Metals (Continued)									
Lead									
	< 1.0		1	1.0	µg/L	10/22/25 10:33	10/22/25 10:33	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0217									
Metals									
Lead									
	1.6		1	1.0	µg/L	10/22/25 10:34	10/22/25 10:34	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0220									
Metals									
Lead									
	1.8		1	1.0	µg/L	10/22/25 10:35	10/22/25 10:35	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2298									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	10/22/25 10:37	10/22/25 10:37	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2450									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	10/22/25 10:41	10/22/25 10:41	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2451									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	10/22/25 10:45	10/22/25 10:45	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2452									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	10/22/25 11:19	10/22/25 11:19	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2453									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	10/22/25 11:23	10/22/25 11:23	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2471									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	10/22/25 11:23	10/22/25 11:23	BP	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556612**LIMS Reference ID:** ED56612**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - General Douglas MacArthur High School MAC - 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 15:33
Reported: 11/26/2025 08:47

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2471 (Continued)									Sampled: 10/02/25 00:00:00
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/22/25 11:24	10/22/25 11:24	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2472									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 13:25	10/22/25 13:25	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2483									Sampled: 10/02/25 00:00:00
Metals									
Lead	2.4		1	1.0	µg/L	10/22/25 13:29	10/22/25 13:29	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2484									Sampled: 10/02/25 00:00:00
Metals									
Lead	1.4		1	1.0	µg/L	10/22/25 13:30	10/22/25 13:30	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2515									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 13:32	10/22/25 13:32	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2549									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 13:36	10/22/25 13:36	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2550									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 13:37	10/22/25 13:37	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2551									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/22/25 13:38	10/22/25 13:38	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2552									Sampled: 10/02/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556612**LIMS Reference ID:** ED56612**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - General Douglas MacArthur High School MAC - 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 15:33
Reported: 11/26/2025 08:47

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: LVT-2552 (Continued) Lims Reference ID: ED56612-25 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals (Continued)

Lead < 1.0 1 1.0 µg/L 10/22/25 13:39 10/22/25 13:39 BP EPA 200.8 (DA)/EPA 200.8

Sample: LVT-2553 Lims Reference ID: ED56612-26 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 10/22/25 13:41 10/22/25 13:41 BP EPA 200.8 (DA)/EPA 200.8

Sample: LVT-2554 Lims Reference ID: ED56612-27 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 10/22/25 13:42 10/22/25 13:42 BP EPA 200.8 (DA)/EPA 200.8

Sample: LVT-2555 Lims Reference ID: ED56612-28 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 10/22/25 13:43 10/22/25 13:43 BP EPA 200.8 (DA)/EPA 200.8

Sample: LVT-2557 Lims Reference ID: ED56612-29 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 10/22/25 13:47 10/22/25 13:47 BP EPA 200.8 (DA)/EPA 200.8

Sample: LVT-2558 Lims Reference ID: ED56612-30 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 10/22/25 14:15 10/22/25 14:15 BP EPA 200.8 (DA)/EPA 200.8

Sample: LVT-2559 Lims Reference ID: ED56612-31 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 10/22/25 14:17 10/22/25 14:17 BP EPA 200.8 (DA)/EPA 200.8

Sample: LVT-2560 Lims Reference ID: ED56612-32 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 10/22/25 14:18 10/22/25 14:18 BP EPA 200.8 (DA)/EPA 200.8

Sample: LVT-2561 Lims Reference ID: ED56612-33 Matrix: Drinking Water Sampled: 10/02/25 00:00:00

Metals

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556612**LIMS Reference ID:** ED56612**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - General Douglas MacArthur High School MAC - 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 15:33
Reported: 11/26/2025 08:47

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2561 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 10/22/25 14:19 10/22/25 14:19 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2563									
Metals									
Lead < 1.0 1 1.0 µg/L 10/22/25 14:20 10/22/25 14:20 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2578									
Metals									
Lead < 1.0 1 1.0 µg/L 10/22/25 14:22 10/22/25 14:22 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2579									
Metals									
Lead < 1.0 1 1.0 µg/L 10/22/25 14:23 10/22/25 14:23 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2789									
Metals									
Lead < 1.0 1 1.0 µg/L 10/22/25 14:24 10/22/25 14:24 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2790									
Metals									
Lead 115 5 5.0 µg/L 10/22/25 15:03 10/22/25 15:03 BP EPA 200.8 (DA)/EPA 200.8									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556612

LIMS Reference ID: ED56612

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - General Douglas MacArthur High School MAC - 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 15:33
Reported: 11/26/2025 08:47

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556612

LIMS Reference ID: ED56612

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District - General Douglas MacArthur High School MAC - 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 15:33
Reported: 11/26/2025 08:47

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56613

JCB #: 23-53783
Building: Wisdom Lane Middle School
WLM

Client: Levittown Union Free School District
Retest/New Install:
Turn Around: Normal 1 wk Rush


Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0860	HE	0016	Basement B17	EC	10/2/2025	8:17:00 AM
LVT-0861	HE	0016	Basement B17	EC	10/2/2025	8:18:00 AM
LVT-0862	HE	0016	Basement B17	EC	10/2/2025	8:19:00 AM
LVT-0863	HE	0015	Basement B15	EC	10/2/2025	8:12:00 AM
LVT-0864	HE	0015	Basement B15	EC	10/2/2025	8:12:00 AM
LVT-0865	HE	0015	Basement B15	EC	10/2/2025	8:13:00 AM
LVT-0866	HE	0015	Basement B15	EC	10/2/2025	8:14:00 AM
LVT-0867	HE	0015	Basement B15	EC	10/2/2025	8:15:00 AM
LVT-0885	LI	1085	Library	KC	10/2/2025	8:27:00 AM
LVT-0937	FL	1041	Faculty Room 204	IM	10/2/2025	7:38:00 AM
LVT-0944	KI	1047B1	Conference Room Closet	KC	10/2/2025	8:06:00 AM
LVT-0968	OF	1070	Room 310	KC	10/2/2025	Carle Place 8:37:00 AM
LVT-0988	FL	1041	Faculty Room 204	KC	10/2/2025	Oct 17 2025, PM 1:35 7:37:00 AM
LVT-0989	KI	1046	Kitchen	KC	10/2/2025	7:07:00 AM
LVT-0990	KI	1046	Kitchen	KC	10/2/2025	7:06:00 AM
LVT-0991	KI	1046	Kitchen	KC	10/2/2025	7:05:00 AM
LVT-0999	NO	1039	Nurse's Office	NS	10/2/2025	7:28:00 AM
LVT-2286	KI	1046	Kitchen	KC	10/2/2025	7:14:00 AM

Building Address
120 Center Lane
Levittown, NY 11756

Analysis Type: ELAP 200.5
Lab Received: DAVID WATKIN 10/17/25 1:35pm
Signature: David White

Samplers Name: Anthony Lombardo
Samplers Signature:
JCB Project Manager: LOMBARDO

10/23/25
PB 200.5 Billing 10/21/25
PB 200.5 Billing 10/21/25
PB 200.5 Billing 10/21/25
PB 200.5 Billing 10/21/25



Lead in Water: Chain of Custody for

ED56613

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53783

Building: Wisdom Lane Middle School

WLM

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2287	KI	1046	Kitchen	KC	10/2/2025	7:15:00 AM
LVT-2288	KI	1046	Kitchen	SN	10/2/2025	7:16:00 AM
LVT-2304	OF	1039	Nurse's Office	BWH	10/2/2025	7:29:00 AM
LVT-2305	OF	1039	Nurse's Office	BWC	10/2/2025	7:29:00 AM
LVT-2307	FL	1076	Room 320	KC	10/2/2025	7:54:00 AM
LVT-2308	OF	3016	Custodial Office	BWH	10/2/2025	7:53:00 AM
LVT-2309	OF	3016	Custodial Office	BWC	10/2/2025	7:53:00 AM
LVT-2487	HA	1016	Corridor Rooms 103-110 (Outside Room 109A)	WF	10/2/2025	7:44:00 AM
LVT-2540	CA	1047	Cafeteria	WF	10/2/2025	7:03:00 AM
LVT-2541	CA	3019	Cafeteria Addition	WF	10/2/2025	7:04:00 AM
LVT-2542	HA	3007	Corridor Room 332 to Custodial Closet (Outside Custodial Office)	WF	10/2/2025	7:48:00 AM
LVT-2761	FL	1041	Faculty Room 204 (Refrigerator)	WF	10/2/2025	7:36:00 AM
LVT-2762	FL	1041	Faculty Room 204 (Refrigerator)	IM	10/2/2025	7:36:00 AM
LVT-2763	KI	1046F	Kitchen Serving Area	KC	10/2/2025	7:10:00 AM
LVT-2809	HA	1049	Corridor Boiler Room To Room 200 (Outside Principal's Office)	WF	10/2/2025	7:00:00 AM

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

OCT 17 25, PM01:35

Building Address

120 Center Lane

Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: DAVID MALAR 10/17/25 1:35 PM

Signature: David Malar

Samplers Name: Anthony Lombardo

Samplers Signature:

JCB Project Manager: LOMBARDO



Lead in Water: Chain of Custody for

ED56613

Page 3 of 3

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53783

Building: Wisdom Lane Middle School

WLM

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 33

10/12/125
200-8 Blwng 10/12/125
200-8 Blwng 10/22/125 Pb Brng 200-8
10/12/125
200-8 Blwng 10/22/125 Pb Brng 200-8

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

OCT 17 25, PM 11:35

Building Address

120 Center Lane

Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 10/17/25
1:35 PM

Signature: David White

Samplers Name: Anthony Lombardo

Samplers Signature: (Signature)

JCB Project Manager: LOMBARDO

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556613**LIMS Reference ID:** ED56613**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Wisdom Lane Middle School WLM - 120 Center
Lane, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:35
Reported: 11/26/2025 08:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0860									
Metals									
Lead	4.3	1	1.0	µg/L	10/21/25 15:50	10/21/25 15:50	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0861									
Metals									
Lead	1.3	1	1.0	µg/L	10/21/25 15:54	10/21/25 15:54	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0862									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 15:55	10/21/25 15:55	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0863									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 15:59	10/21/25 15:59	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0864									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:00	10/21/25 16:00	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0865									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:02	10/21/25 16:02	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0866									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:03	10/21/25 16:03	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0867									
Metals									
Lead	88.3	1	1.0	µg/L	10/23/25 00:00	10/23/25 09:27	BP	EPA 200.8 (Dig)/EPA 200.8	
Sample: LVT-0885									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556613**LIMS Reference ID:** ED56613**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Wisdom Lane Middle School WLM - 120 Center
Lane, Levittown, NY 11756

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 10/17/2025 13:35

Reported: 11/26/2025 08:49

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0885 (Continued)									
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:04	10/21/25 16:04	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0937									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:06	10/21/25 16:06	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0944									
Metals									
Lead	1.7	1	1.0	µg/L	10/21/25 16:07	10/21/25 16:07	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0968									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:08	10/21/25 16:08	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0988									
Metals									
Lead	2.2	1	1.0	µg/L	10/21/25 16:15	10/21/25 16:15	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0989									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:16	10/21/25 16:16	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0990									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:18	10/21/25 16:18	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0991									
Metals									
Lead	1.1	1	1.0	µg/L	10/21/25 16:19	10/21/25 16:19	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0999									
Metals									
Lead									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556613**LIMS Reference ID:** ED56613**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Wisdom Lane Middle School WLM - 120 Center
Lane, Levittown, NY 11756

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 10/17/2025 13:35

Reported: 11/26/2025 08:49

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0999 (Continued)									
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:20	10/21/25 16:20	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2286									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:21	10/21/25 16:21	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2287									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:23	10/21/25 16:23	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2288									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:24	10/21/25 16:24	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2304									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/21/25 16:25	10/21/25 16:25	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2305									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 09:43	10/22/25 09:43	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2307									
Metals									
Lead	5.4	1	1.0	µg/L	10/22/25 09:45	10/22/25 09:45	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2308									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 09:46	10/22/25 09:46	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2309									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 09:47	10/22/25 09:47	BP	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556613**LIMS Reference ID:** ED56613**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Wisdom Lane Middle School WLM - 120 Center
Lane, Levittown, NY 11756

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 10/17/2025 13:35

Reported: 11/26/2025 08:49

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2309 (Continued)									
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/22/25 09:47	10/22/25 09:47	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2487									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 10:46	10/22/25 10:46	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2540									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 10:47	10/22/25 10:47	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2541									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 10:49	10/22/25 10:49	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2542									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 10:50	10/22/25 10:50	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2761									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 00:00	10/23/25 09:28	BP	EPA 200.8 (Dig)/EPA 200.8	
Sample: LVT-2762									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 10:51	10/22/25 10:51	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2763									
Metals									
Lead	1.5	1	1.0	µg/L	10/22/25 10:52	10/22/25 10:52	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2809									
Metals									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556613

LIMS Reference ID: ED56613

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Wisdom Lane Middle School WLM - 120 Center
Lane, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:35
Reported: 11/26/2025 08:49

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2809 (Continued)									
Metals (Continued)									
Lead									
	< 1.0		1	1.0	µg/L	10/22/25 10:54	10/22/25 10:54	BP	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556613

LIMS Reference ID: ED56613

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Wisdom Lane Middle School WLM - 120 Center
Lane, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:35
Reported: 11/26/2025 08:49

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556613

LIMS Reference ID: ED56613

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Wisdom Lane Middle School WLM - 120 Center
Lane, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:35
Reported: 11/26/2025 08:49


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56616

JCB #:

23-53783

Building: Gardiners Avenue Elementary School

GAE

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1669	LI	1039	Library	KC	10/2/2025	10:20:00 AM
LVT-1676	KI	1043C	Kitchen	SA	10/2/2025	10:15:00 AM
LVT-1693	FL	1047	Faculty Room 301	KC	10/2/2025	10:28:00 AM
LVT-2289	KI	1043C	Kitchen	KC	10/2/2025	10:12:00 AM
LVT-2290	KI	1043C	Kitchen	SN	10/2/2025	10:12:00 AM
LVT-2291	KI	1043C	Kitchen	KC	10/2/2025	10:13:00 AM
LVT-2292	KI	1043C	Kitchen	KC	10/2/2025	10:14:00 AM
LVT-2297	KI	1043C	Kitchen	KC	10/2/2025	10:14:00 AM
LVT-2506	HA	1041	Corridor Rooms 200-Library (Outside Room 205)	WF	10/2/2025	10:21:00 AM
LVT-2507	HA	1018	Corridor Rooms 100-112 (Outside Room 106)	WF	10/2/2025	10:23:00 AM
LVT-2508	HA	1061	Corridor Rooms 300-308 (Outside Nurse's Office)	WF	10/2/2025	10:27:00 AM
LVT-2509	HA	1085	Corridor Rooms 400-410 (Outside Room 405)	WF	10/2/2025	10:31:00 AM
LVT-2825	CA	1043	Cafeteria	WF	10/11/2025	7:34:00 AM

Samples Submitted

13
RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

OCT 17 25, PM 01:38



Pb 200.8 Bldg 10/20/25

Building Address

610 Gardiners Avenue
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: DAVID MARTIN 10/17/25 1:38 PM

Signature: David Martin

Samplers Name: Willow Mercer

Samplers Signature:

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556616**LIMS Reference ID:** ED56616**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Gardiners Avenue Elementary School GAE - 610
Gardiners Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:38
Reported: 11/26/2025 08:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1669									
Metals									
Lead	3.0	1	1.0	µg/L	10/20/25 15:42	10/20/25 15:42	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1676									
Metals									
Lead	71.9	1	1.0	µg/L	10/20/25 15:46	10/20/25 15:46	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1693									
Metals									
Lead	1.1	1	1.0	µg/L	10/20/25 15:48	10/20/25 15:48	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2289									
Metals									
Lead	1.0	1	1.0	µg/L	10/20/25 15:52	10/20/25 15:52	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2290									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 15:53	10/20/25 15:53	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2291									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 15:54	10/20/25 15:54	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2292									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 15:56	10/20/25 15:56	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2297									
Metals									
Lead	2.2	1	1.0	µg/L	10/20/25 15:57	10/20/25 15:57	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2506									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556616**LIMS Reference ID:** ED56616**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Gardiners Avenue Elementary School GAE - 610
Gardiners Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:38
Reported: 11/26/2025 08:49

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2506 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 10/20/25 15:58 10/20/25 15:58 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2507									
Metals									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:00 10/20/25 16:00 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2508									
Metals									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:01 10/20/25 16:01 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2509									
Metals									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:07 10/20/25 16:07 BP EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2825									
Metals									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:09 10/20/25 16:09 BP EPA 200.8 (DA)/EPA 200.8									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556616

LIMS Reference ID: ED56616

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Gardiners Avenue Elementary School GAE - 610
Gardiners Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:38
Reported: 11/26/2025 08:49

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556616

LIMS Reference ID: ED56616

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Gardiners Avenue Elementary School GAE - 610
Gardiners Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:38
Reported: 11/26/2025 08:49

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56618

JCB #: 23-53783
Building: Abbey Lane School
ALS

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Page 1 of 2

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1065	HA	1023	Corridor Rooms 201-212	DW	10/2/2025	11:20:00 AM
LVT-1070	KI	1018	Kitchen Vestibule	IM	10/2/2025	11:21:00 AM
LVT-1084	HA	1050	Corridor Rooms 301-311 (Outside Main Office)	WF	10/2/2025	11:44:00 AM
LVT-1119	KI	1021	Kitchen	KC	10/2/2015	11:25:00 AM
LVT-1123	KI	1021	Kitchen	KC	10/2/2025	11:26:00 AM
LVT-1124	KI	1021	Kitchen	SN	10/2/2025	11:26:00 AM
LVT-1125	LI	1059	Library	KC	10/2/2025	11:32:00 AM
LVT-1162	FL	1062	Faculty Room 409	KC	10/2/2025	11:35:00 AM
LVT-2283	KI	1021	Kitchen	KC	10/2/2025	11:26:00 AM
LVT-2284	KI	1021	Kitchen	SN	10/2/2025	11:25:00 AM
LVT-2285	KI	1021	Kitchen	KC	10/2/2025	11:24:00 AM
LVT-2490	HA	1050	Corridor Rooms 301-311	WF	10/2/2025	11:48:00 AM
LVT-2543	CA	1058	Cafeteria	WF	10/2/2025	11:30:00 AM
LVT-2669	HA	1070	Corridor Between Rooms 405 And 410	WF	10/2/2025	11:34:00 AM
LVT-2684	HA	1070	Corridor Between Rooms 405 And 410 (Outside Boy's Bathroom)	WF	10/2/2025	11:34:00 AM

1b 200.8 Bolling 10/20/25
1b 200.8 Kothandew 10/20/25



RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 17 25, PM01:36

Building Address

239 Gardiners Avenue
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: DAVID WYATTOW 10/17/25
1:36 PM
Signature: David Wyatt

Samplers Name: Willow Mercer

Samplers Signature: WM

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED56618

23-53783

JCB #:

Building: Abbey Lane School

ALS

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 15

Pb 200-8 Belling 10/20/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 17 25, PM01:36

Building Address

239 Gardiners Avenue
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 10/17/25
1:36 PM

Signature: David Wharton

Samplers Name: Willow Mercer

Samplers Signature: WM

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556618**LIMS Reference ID:** ED56618**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Abbey Lane School ALS - 239 Gardiners Avenue,
Levittown, NY 11756

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 10/17/2025 13:36

Reported: 11/26/2025 08:50

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1065									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 16:10	10/20/25 16:10	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1070									
Metals									
Lead	2.0	1	1.0	µg/L	10/20/25 16:11	10/20/25 16:11	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1084									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 16:13	10/20/25 16:13	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1119									
Metals									
Lead	26900	500	500	µg/L	10/20/25 19:37	10/20/25 19:37	KT1	EPA 200.8 (Dig)/EPA 200.8	
Sample: LVT-1123									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 16:14	10/20/25 16:14	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1124									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 16:15	10/20/25 16:15	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1125									
Metals									
Lead	2.4	1	1.0	µg/L	10/20/25 16:32	10/20/25 16:32	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1162									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 16:36	10/20/25 16:36	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2283									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556618**LIMS Reference ID:** ED56618**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Abbey Lane School ALS - 239 Gardiners Avenue,
Levittown, NY 11756

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 10/17/2025 13:36

Reported: 11/26/2025 08:50

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2283 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:38 10/20/25 16:38 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2284									
Metals									
Lead 2.1 1 1.0 µg/L 10/20/25 16:39 10/20/25 16:39 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2285									
Metals									
Lead 2.7 1 1.0 µg/L 10/20/25 16:43 10/20/25 16:43 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2490									
Metals									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:44 10/20/25 16:44 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2543									
Metals									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:46 10/20/25 16:46 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2669									
Metals									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:47 10/20/25 16:47 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2684									
Metals									
Lead < 1.0 1 1.0 µg/L 10/20/25 16:48 10/20/25 16:48 KT1 EPA 200.8 (DA)/EPA 200.8									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556618

LIMS Reference ID: ED56618

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Abbey Lane School ALS - 239 Gardiners Avenue,
Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:36
Reported: 11/26/2025 08:50

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556618

LIMS Reference ID: ED56618

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Abbey Lane School ALS - 239 Gardiners Avenue,
Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 13:36
Reported: 11/26/2025 08:50

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56620

Page 1 of 2

JCB #:

23-53783

Building: Lee Road Elementary School

LEE


Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1946	CR	1006	Room 5	DW	10/2/2025	9:18:00 AM
LVT-1954	CR	1002	Room 9	DW	10/2/2025	9:11:00 AM
LVT-1979	CA	1030	Cafeteria	KC	10/2/2025	9:54:00 AM
LVT-1981	CA	1030	Cafeteria	KC	10/2/2025	9:54:00 AM
LVT-1986	KI	1031	Kitchen	KC	10/2/2025	9:04:00 AM
LVT-1987	KI	1031	Kitchen	SN	10/2/2025	9:04:00 AM
LVT-1988	KI	1031	Kitchen	KC	10/2/2025	9:05:00 AM
LVT-2002	CR	2012	Room 16	DW	10/2/2025	10:10:00 AM
LVT-2004	CR	2013	Room 15	DW	10/2/2025	10:12:00 AM
LVT-2702	FL	1011	Faculty Room	KC	10/2/2025	9:25:00 AM
LVT-2703	HA	1016	Corridor Rooms 1-10 (Outside Gym)	WF	10/2/2025	9:30:00 AM
LVT-2704	NO	1034	Nurse's Office	BWC	10/2/2025	RECEIVED 9:49:00 AM
LVT-2705	NO	1034	Nurse's Office	BWH	10/2/2025	EMB ANALYTICAL INC. 9:49:00 AM
LVT-2720	HA	2002	Fountain Vestibule (Outside Student Bathrooms)	WF	10/2/2025	Carle Place, NY 10:01:00 AM OCT 17 25, PM 04:57
LVT-2721	FL	1035	Custodial Office	BWC	10/2/2025	10:19:00 AM
LVT-2722	FL	1035	Custodial Office	BWH	10/2/2025	10:20:00 AM



Pb 200.8
Kathleen 10/20/25

Building Address

901 Lee Road
Wantagh, NY 11793

Analysis Type: ELAP 200.5

Lab Received: DAVID MARTON


Signature: David Marton

10/17/25
4:57 pm

Samplers Name: Anthony Lombardo

Samplers Signature:

JCB Project Manager: LOMBARDO



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56620

JCB #: 23-53783
Building: Lee Road Elementary School
LEE

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 16

PB 200-8
Rmt 10/22/25

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

OCT 17 25, PM04:57

PB 200-8
Rmt 10/22/25

Building Address

901 Lee Road
Wantagh, NY 11793

Analysis Type: ELAP 200.5

Lab Recieved: DAVID MARTIN

Signature: David Martin

10/17/25 Samplers Name: Anthony Lombardo

4:57 pm Samplers Signature: 

JCB Project Manager: LOMBARDO

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556620**LIMS Reference ID:** ED56620**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Lee Road Elementary School LEE - 901 Lee Road,
Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 16:57
Reported: 11/26/2025 08:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1946									
Metals									
Lead	10.8	1	1.0	µg/L	10/20/25 16:50	10/20/25 16:50	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1954									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 16:51	10/20/25 16:51	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1979									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 16:55	10/20/25 16:55	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1981									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 16:59	10/20/25 16:59	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1986									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 17:00	10/20/25 17:00	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1987									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 17:02	10/20/25 17:02	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1988									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 17:03	10/20/25 17:03	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2002									
Metals									
Lead	4.0	1	1.0	µg/L	10/20/25 17:04	10/20/25 17:04	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2004									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556620**LIMS Reference ID:** ED56620**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Lee Road Elementary School LEE - 901 Lee Road,
Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 16:57
Reported: 11/26/2025 08:55

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2004 (Continued)									
Metals (Continued)									
Lead	1.0	1	1.0	µg/L	10/20/25 17:05	10/20/25 17:05	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2702									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 17:07	10/20/25 17:07	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2703									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/20/25 17:08	10/20/25 17:08	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2704									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 11:10	10/22/25 11:10	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2705									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 11:14	10/22/25 11:14	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2720									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 11:15	10/22/25 11:15	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2721									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 11:17	10/22/25 11:17	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2722									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/22/25 11:21	10/22/25 11:21	BP	EPA 200.8 (DA)/EPA 200.8	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556620

LIMS Reference ID: ED56620

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Lee Road Elementary School LEE - 901 Lee Road,
Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 16:57
Reported: 11/26/2025 08:55

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556620

LIMS Reference ID: ED56620

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 - Levittown Union Free School District -
Lee Road Elementary School LEE - 901 Lee Road,
Wantagh, NY 11793
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/17/2025 16:57
Reported: 11/26/2025 08:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

EDS 6690

Page 1 of 2

JCB #: 23-53783

Building: Northside Elementary School

NES

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0730	FL	1039	Faculty Lounge 531	KC	10/2/2025	9:29:00 AM
LVT-0757	FL	1019	Custodian Office 420	KC	10/2/2025	9:19:00 AM
LVT-2200	KI	1082	Kitchen	KC	10/2/2025	9:42:00 AM
LVT-2201	KI	1082	Kitchen	SN	10/2/2025	9:42:00 AM
LVT-2202	KI	1082	Kitchen	KC	10/2/2025	9:41:00 AM
LVT-2203	KI	1082	Kitchen	KC	10/2/2025	9:40:00 AM
LVT-2204	KI	1082	Kitchen	SN	10/2/2025	9:40:00 AM
LVT-2205	KI	1082	Kitchen	KC	10/2/2025	9:43:00 AM
LVT-2206	KI	1082	Kitchen	KC	10/2/2025	9:44:00 AM
LVT-2207	KI	1081	Cafeteria Serving Line	KC	10/2/2025	9:46:00 AM
LVT-2208	KI	1082	Kitchen	KC	10/2/2025	9:47:00 AM
LVT-2210	CA	1080	All Purpose Room	WF	10/2/2025	9:39:00 AM
LVT-2269	NO	1048	Nurse's Office	BWC	10/2/2025	9:34:00 AM
LVT-2383	NO	1048	Nurse's Office	BWH	10/2/2025	9:34:00 AM
LVT-2522	HA	1058	Corridor Rooms 100-104 (Outside Room 102)	WF	10/2/2025	9:36:00 AM
LVT-2523	HA	1076	Corridor Rooms 207-212 (Outside Room 210)	WF	10/2/2025	9:38:00 AM
LVT-2524	HA	1045	Corridor Main Office To Gym (Outside Library)	WF	10/2/2025	9:32:00 AM
LVT-2528	HA	1025	Corridor Rooms 420-426 (Outside Room 423)	WF	10/2/2025	9:27:00 AM

Building Address

35 Pelican Road

Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received:


Signature:

Samplers Name: Conor Malanaphy

Samplers Signature: CM

JCB Project Manager: Anthony Lombardo

Pb 200.8 Kohlenslaw 10/29/25



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

EDS 6690

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

NES

JCB #: 23-53783

Building: Northside Elementary School

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2529	HA	1013	Corridor Rooms 314-318 (Outside Room 317)	WF	10/2/2025	9:25:00 AM
LVT-2530	CA	0001	Cafeteria	WF	10/2/2025	9:22:00 AM
LVT-2539	HA	1046	Corridor Rooms 527-534 o/s Room 527	WF	10/2/2025	9:28:00 AM
LVT-2639	FL	1019	Custodial Office 420	BWC	10/2/2025	9:17:00 AM
LVT-2640	FL	1019	Custodial Office 420	BWH	10/2/2025	9:17:00 AM

Samples Submitted 23

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

OCT 22 25, PM02:43

Pb200.8
Kathleen 10/29/25

Building Address


35 Pelican Road

Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received:

Signature:



Samplers Name: Connor Maloney

Samplers Signature: CM

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556690**LIMS Reference ID:** ED56690**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:43
Reported: 11/26/2025 08:51

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0730									
Metals									
Lead	5.8	1	1.0	µg/L	10/28/25 16:31	10/28/25 16:31	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0757									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/28/25 16:35	10/28/25 16:35	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2200									
Metals									
Lead	15.6	1	1.0	µg/L	10/28/25 16:36	10/28/25 16:36	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2201									
Metals									
Lead	37.2	1	1.0	µg/L	10/28/25 16:38	10/28/25 16:38	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2202									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/28/25 16:39	10/28/25 16:39	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2203									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/28/25 17:19	10/28/25 17:19	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2204									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/28/25 17:20	10/28/25 17:20	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2205									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:41	10/29/25 14:41	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2206									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062556690

LIMS Reference ID: ED56690

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: JCB# 23-53783, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:43
Reported: 11/26/2025 08:51

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2206 (Continued)									Sampled: 10/02/25 00:00:00
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:45	10/29/25 14:45	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2207									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:47	10/29/25 14:47	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2208									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:48	10/29/25 14:48	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2210									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:52	10/29/25 14:52	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2269									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:53	10/29/25 14:53	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2383									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:54	10/29/25 14:54	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2522									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 15:35	10/29/25 15:35	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2523									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 15:39	10/29/25 15:39	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2524									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 15:40	10/29/25 15:40	KT1	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556690**LIMS Reference ID:** ED56690**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:43
Reported: 11/26/2025 08:51

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2524 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:40 10/29/25 15:40 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2528									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:42 10/29/25 15:42 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2529									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:46 10/29/25 15:46 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2530									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:47 10/29/25 15:47 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2539									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:48 10/29/25 15:48 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2639									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:49 10/29/25 15:49 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2640									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:51 10/29/25 15:51 KT1 EPA 200.8 (DA)/EPA 200.8									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556690

LIMS Reference ID: ED56690

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:43
Reported: 11/26/2025 08:51

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556690

LIMS Reference ID: ED56690

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#: 23-53783, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:43
Reported: 11/26/2025 08:51

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

ED516692

Client:

Levittown Union Free School District

JCB #:

23-53783

Building: Division Avenue High School

DAH

Retest/New Install

Turn Around: Normal 1 wk Rush

Stephanie
2008-2009
10/22/25

10/22/25

JCB

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0231	OF	2021A	Library 234 Magazine Room	KC	10/2/2025	8:12:00 AM
LVT-0295	SC	2047A	Room 219 Kitchen	KC	10/2/2025	8:20:00 AM
LVT-0341	HE	1027	Room 125	EC	10/2/2025	7:07:00 AM
LVT-0342	HE	1027	Room 125	EC	10/2/2025	7:08:00 AM
LVT-0343	HE	1027	Room 125	EC	10/2/2025	7:08:00 AM
LVT-0344	HE	1027	Room 125	EC	10/2/2025	7:09:00 AM
LVT-0358	FL	1038	Faculty Room 133	KC	10/2/2025	7:12:00 AM
LVT-0373	KI	1046B2	Main Office Kitchen	KC	10/2/2025	7:18:00 AM
LVT-0377	NO	1049	Room 140 Health Office	NS	10/2/2025	7:19:00 AM
LVT-0403	HE	1064	Room 152	EC	10/2/2025	7:25:00 AM
LVT-0404	HE	1064	Room 152	SN	10/2/2025	7:25:00 AM
LVT-0405	HE	1064	Room 152	EC	10/2/2025	7:27:00 AM
LVT-0407	HE	1064	Room 152	EC	10/2/2025	7:27:00 AM
LVT-0424	OF	1071A	East Cafeteria Office/Maintainer	KC	10/2/2025	RECEIVED 7:41:00 AM
LVT-0425	KI	1070	Kitchen	KC	10/2/2025	7:35:00 AM
LVT-0426	KI	1070	Kitchen	KC	10/2/2025	7:36:00 AM
LVT-0427	KI	1070	Kitchen	KC	10/2/2025	7:37:00 AM
LVT-0428	KI	1070	Kitchen	KC	10/2/2025	7:38:00 AM

Building Address120 Division Avenue
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: A. Minnifield

Signature: A. Minnifield
10/22/25 2:42 pm

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

ED56692

Client:

Levittown Union Free School District

JCB #: 23-53783

Building: Division Avenue High School

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

DAH

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0429	KI	1070	Kitchen	KC	10/2/2025	7:38:00 AM
LVT-0430	KI	1070	Kitchen	KC	10/2/2025	7:39:00 AM
LVT-0431	KI	1070	Kitchen	SN	10/2/2025	7:39:00 AM
LVT-0442	SP	1104	Room 313	IM	10/2/2025	7:54:00 AM
LVT-0485	KI	4001	Snack Shack	KC	10/2/2025	8:26:00 AM
LVT-2258	HA	2056	Corridor Rooms 212 to 230 (Outside Room 221)	BWC	10/2/2025	8:14:00 AM
LVT-2260	HA	1044	Auditorium Lobby	BWH	10/2/2025	7:16:00 AM
LVT-2263	CR	1066	Room 155	KC	10/2/2025	7:29:00 AM
LVT-2264	HA	1097	Corridor Rooms 319-324 (Outside Men's Bathroom)	BWC	10/2/2025	7:50:00 AM
LVT-2299	FL	1038	Faculty Room 133	WF	10/2/2025	7:13:00 AM
LVT-2311	HA	1044	Auditorium Lobby	BWC	10/2/2025	7:15:00 AM
LVT-2315	FL	1073	Custodial Lounge	BWC	10/2/2025	7:43:00 AM
LVT-2316	FL	1073	Custodial Lounge	BWH	10/2/2025	RECEIVED 7:43:00 AM
LVT-2319	HA	1097	Corridor Rooms 319-324 (Outside Men's Bathroom)	BWH	10/2/2025	7:50:00 AM
LVT-2322	CR	2020	Room 236	BWC	10/2/2025	8:09:00 AM
LVT-2323	CR	2020	Room 236	BWH	10/2/2025	8:09:00 AM
LVT-2324	HA	2056	Corridor Rooms 212 to 230 (Outside Room 221)	BWH	10/2/2025	8:14:00 AM
LVT-2481	OF	1054	Room 142	IM	10/2/2025	7:21:00 AM

Building Address

120 Division Avenue
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: A. Minnfield

Signature: A. Minnfield

10/22/25 2:42 pm

Samplers Name: Conor Malanphy

Samplers Signature: Conor Malanphy

JCB Project Manager: Anthony Lombardo

Pb 2008
10/22/25

Pb 2008
10/22/25

PLW
10/22/25



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED516692

Client:

Levittown Union Free School District

JCB #: 23-53783
Building: Division Avenue High School
DAH

Retest/New Install

Turn Around: Normal 1 wk Rush

10/22/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2482	OF	1054	Room 142	WC	10/2/2025	7:22:00 AM
LVT-2531	HA	1068	Corridor Main Office To Room 151 (Outside Room 144)	WF	10/2/2025	7:23:00 AM
LVT-2532	HA	1037	Corridor Rooms 114-134 (Outside Room 132)	WF	10/2/2025	7:11:00 AM
LVT-2534	CA	1069	West Cafeteria	WF	10/2/2025	7:33:00 AM
LVT-2535	CA	1071	East Cafeteria	WF	10/2/2025	7:41:00 AM
LVT-2536	HA	1109	Gym/Lobby Corridor	WF	10/2/2025	7:53:00 AM
LVT-2537	SP	1079	Fitness Center 325	WF	10/2/2025	7:48:00 AM
LVT-2538	LR	0018	Boy's Locker Room	WF	10/2/2025	7:58:00 AM
LVT-2725	HA	1037	Corridor Rooms 114-134 (Outside Room 114)	WF	10/2/2025	7:11:00 AM
LVT-2727	HA	2029	Corridor Storage Room to Room 252	BWC	10/2/2025	8:07:00 AM
LVT-2728	HA	2029	Corridor Storage Room to Room 252	BWH	10/2/2025	9:07:00 AM

Samples Submitted 47

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 22 25, PM02:42

Building Address

120 Division Avenue
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: A. Minnifield

Signature: A. Minnifield

10/22/25 2:42pm

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062556692**LIMS Reference ID:** ED56692**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: 23-53783, Division Avenue High School, DAH , Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:42
Reported: 11/26/2025 08:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0231									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 11:16	10/29/25 11:16	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0295									Sampled: 10/02/25 00:00:00
Metals									
Lead	43.6		1	1.0	µg/L	10/29/25 11:19	10/29/25 11:19	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0341									Sampled: 10/02/25 00:00:00
Metals									
Lead	2.4		1	1.0	µg/L	10/29/25 11:21	10/29/25 11:21	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0342									Sampled: 10/02/25 00:00:00
Metals									
Lead	16.3		1	1.0	µg/L	10/29/25 11:25	10/29/25 11:25	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0343									Sampled: 10/02/25 00:00:00
Metals									
Lead	1.6		1	1.0	µg/L	10/29/25 11:26	10/29/25 11:26	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0344									Sampled: 10/02/25 00:00:00
Metals									
Lead	3.3		1	1.0	µg/L	10/29/25 11:27	10/29/25 11:27	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0358									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 11:29	10/29/25 11:29	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0373									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 11:30	10/29/25 11:30	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0377									Sampled: 10/02/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556692**LIMS Reference ID:** ED56692**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Division Avenue High School, DAH , Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:42
Reported: 11/26/2025 08:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0377 (Continued)									Sampled: 10/02/25 00:00:00
Metals (Continued)									
Lead	1.3		1	1.0	µg/L	10/29/25 11:31	10/29/25 11:31	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0403									Sampled: 10/02/25 00:00:00
Metals									
Lead	1.6		1	1.0	µg/L	10/29/25 11:32	10/29/25 11:32	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0404									Sampled: 10/02/25 00:00:00
Metals									
Lead	33.0		1	1.0	µg/L	10/29/25 11:34	10/29/25 11:34	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0405									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 11:40	10/29/25 11:40	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0407									Sampled: 10/02/25 00:00:00
Metals									
Lead	7.2		1	1.0	µg/L	10/29/25 11:41	10/29/25 11:41	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0424									Sampled: 10/02/25 00:00:00
Metals									
Lead	22.3		1	1.0	µg/L	10/29/25 11:43	10/29/25 11:43	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0425									Sampled: 10/02/25 00:00:00
Metals									
Lead	2.5		1	1.0	µg/L	10/29/25 11:44	10/29/25 11:44	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0426									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 11:45	10/29/25 11:45	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0427									Sampled: 10/02/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062556692**LIMS Reference ID:** ED56692**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: 23-53783, Division Avenue High School, DAH , Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:42
Reported: 11/26/2025 08:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0427 (Continued)									
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	10/29/25 11:47	10/29/25 11:47	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0428									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 11:48	10/29/25 11:48	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0429									
Metals									
Lead	2.0		1	1.0	µg/L	10/29/25 11:49	10/29/25 11:49	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0430									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 11:50	10/29/25 11:50	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0431									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 13:50	10/29/25 13:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0442									
Metals									
Lead	2.7		1	1.0	µg/L	10/29/25 13:54	10/29/25 13:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0485									
Metals									
Lead	2.8		1	1.0	µg/L	10/29/25 13:55	10/29/25 13:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2258									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/29/25 13:56	10/29/25 13:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2260									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556692**LIMS Reference ID:** ED56692**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Division Avenue High School, DAH , Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:42
Reported: 11/26/2025 08:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2260 (Continued)									Sampled: 10/02/25 00:00:00
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:00	10/29/25 14:00	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2263									Sampled: 10/02/25 00:00:00
Metals									
Lead	18.6	1	1.0	µg/L	10/29/25 14:01	10/29/25 14:01	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2264									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:03	10/29/25 14:03	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2299									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:04	10/29/25 14:04	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2311									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:05	10/29/25 14:05	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2315									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:07	10/29/25 14:07	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2316									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:08	10/29/25 14:08	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2319									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:12	10/29/25 14:12	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2322									Sampled: 10/02/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062556692**LIMS Reference ID:** ED56692**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: 23-53783, Division Avenue High School, DAH , Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:42
Reported: 11/26/2025 08:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2322 (Continued)									Sampled: 10/02/25 00:00:00
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:16	10/29/25 14:16	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2323									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:17	10/29/25 14:17	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2324									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:18	10/29/25 14:18	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2481									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:19	10/29/25 14:19	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2482									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:21	10/29/25 14:21	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2531									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:22	10/29/25 14:22	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2532									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:23	10/29/25 14:23	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2534									Sampled: 10/02/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	10/29/25 14:25	10/29/25 14:25	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2535									Sampled: 10/02/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556692**LIMS Reference ID:** ED56692**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Division Avenue High School, DAH , Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:42
Reported: 11/26/2025 08:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2535 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 10/29/25 14:56 10/29/25 14:56 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2536									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 14:57 10/29/25 14:57 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2537									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 14:58 10/29/25 14:58 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2538									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 14:59 10/29/25 14:59 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2725									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:03 10/29/25 15:03 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2727									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:07 10/29/25 15:07 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2728									
Metals									
Lead < 1.0 1 1.0 µg/L 10/29/25 15:08 10/29/25 15:08 KT1 EPA 200.8 (DA)/EPA 200.8									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556692

LIMS Reference ID: ED56692

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Division Avenue High School, DAH , Levittown Union Free School District, 120 Division Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:42
Reported: 11/26/2025 08:52

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556692

LIMS Reference ID: ED56692

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Division Avenue High School, DAH ,
Levittown Union Free School District, 120 Division
Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:42
Reported: 11/26/2025 08:52


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53783

Building: Jonas E. Salk Middle School

SALK

ED56692

Page 1 of 3

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1248	HE	1007	Room 128/126	EC	10/2/2025	8:55:00 AM
LVT-1250	HE	1007	Room 128/126	EC	10/2/2025	8:57:00 AM
LVT-1251	HE	1007	Room 128/126	EC	10/2/2025	9:00:00 AM
LVT-1252	HE	1007	Room 128/126	EC	10/2/2025	8:59:00 AM
LVT-1253	HE	1007	Room 128/126	EC	10/2/2025	8:58:00 AM
LVT-1254	CR	1012	Room 123	KC	10/2/2025	9:02:00 AM
LVT-1255	HE	1014	Room 122	EC	10/2/2025	9:03:00 AM
LVT-1256	HE	1014	Room 122	EC	10/2/2025	9:04:00 AM
LVT-1257	HE	1014	Room 122	EC	10/2/2025	9:05:00 AM
LVT-1258	HE	1014	Room 122	EC	10/2/2025	9:06:00 AM
LVT-1274	KI	1026A	Main Office Kitchen	KC	10/2/2025	9:11:00 AM
LVT-1316	KI	1064	Kitchen	KC	10/2/2025	8:36:00 AM
LVT-1317	KI	1064	Kitchen	KC	10/2/2025	8:35:00 AM
LVT-1318	KI	1064	Kitchen	KC	10/2/2025	8:32:00 AM
LVT-1320	KI	1064	Kitchen	SN	10/2/2025	8:36:00 AM
LVT-1363	FL	2016	Faculty Room	KC	10/2/2025	Carlie Plat 9:23:00 AM
LVT-1364	LI	2020A	Library Work Room	KC	10/2/2025	Oct 22 2025 9:26:00 AM
LVT-1585	GY	1067	Boys Entrance Into Gym	WF	10/2/2025	9:36:00 AM

Building Address

3359 Old Jerusalem Road
Levittown, NY 11756

Analysis Type: ELAP 200.5


Lab Received: *CR*
Signature: *CR*

Samplers Name: Willow Mercer

Samplers Signature: *WM*

JCB Project Manager: *AL* Anthony Lombardo

Walk In



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56692

Page 2 of 3

JCB #: 23-53783
Building: Jonas E. Salk Middle School
SALK

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2295	CA	1065	Blue Cafeteria	WF	10/2/2025	9:34:00 AM
LVT-2486	HA	1042	Corridor Guidance To Room 109 (Outside Guidance)	WF	10/2/2025	9:12:00 AM
LVT-2494	CA	1063	Green Cafeteria	WF	10/2/2025	9:32:00 AM
LVT-2517	FL	2016	Faculty Room	WF	10/2/2025	9:23:00 AM
LVT-2519	HA	2040	Corridor Boys Bathroom To Room 221 (Outside Room 231)	WF	10/2/2025	9:29:00 AM
LVT-2520	HA	2015	Corridor Room 203 To Room 210 (Outside Room 213)	WF	10/2/2025	9:21:00 AM
LVT-2521	HA	1055	Corridor Boiler Room To Room 112 (Outside Room 110)	WF	10/2/2025	8:24:00 AM
LVT-2791	KI	1064	Kitchen	KC	10/2/2025	8:33:00 AM
LVT-2792	KI	1064	Kitchen	KC	10/2/2025	8:34:00 AM
LVT-2793	KI	1064	Kitchen	KC	10/2/2025	8:34:00 AM
LVT-2794	SP	0009	Weight Room	IM	10/2/2025	8:46:00 AM
LVT-2795	HA	4011	Corridor Room 134 to Room 139	WF	10/2/2025	8:52:00 AM
LVT-2796	NO	1023B	Nurses Office	NS	10/2/2025	9:10:00 AM
LVT-2797	OF	1057B3	Room 116 Music Class Room Office 1	WFH	10/2/2025	9:18:00 AM
LVT-2798	OF	1057B3	Room 116 Music Class Room Office 1	WFC	10/2/2025	9:18:00 AM
LVT-2826	SP	0009	Weight Room	WF	10/17/2025	RECEIVED 6:45:00 AM EMBL ANALYTICAL, INC.

Carle Place, NY
OCT 22 25, PM02:46

Building Address
3359 Old Jerusalem Road
Levittown, NY 11756

Analysis Type: ELAP 200.5


Lab Received: Carle

Signature: Willow Mercer

Samplers Name: Willow Mercer

Samplers Signature: WM

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

EDS6692

Page 3 of 3

JCB #: 23-53783

Building: Jonas E. Salk Middle School

SALK

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 34

Building Address
3359 Old Jerusalem Road
Levittown, NY 11756

Analysis Type: ELAP 200.5 200.8

Lab Received: _____

Signature: _____

Samplers Name: Willow Merrett

Samplers Signature: WM

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556693**LIMS Reference ID:** ED56693**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Jonas E. Salk Middle School: 3359 Old Jerusalem Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:46
Reported: 11/26/2025 08:53

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1248									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 18:53	10/23/25 18:53	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1250									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/23/25 18:54	10/23/25 18:54	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1251									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 13:46	10/24/25 13:46	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1252									
Metals									
Lead	1.5	1	1.0	µg/L	10/24/25 13:50	10/24/25 13:50	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1253									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 13:51	10/24/25 13:51	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1254									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 13:55	10/24/25 13:55	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1255									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 13:56	10/24/25 13:56	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1256									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 13:57	10/24/25 13:57	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1257									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556693**LIMS Reference ID:** ED56693**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Jonas E. Salk Middle School: 3359 Old Jerusalem Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:46
Reported: 11/26/2025 08:53

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1257 (Continued)									
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	10/24/25 13:58	10/24/25 13:58	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1258									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:00	10/24/25 14:00	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1274									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:01	10/24/25 14:01	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1316									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:02	10/24/25 14:02	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1317									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:04	10/24/25 14:04	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1318									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:10	10/24/25 14:10	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1320									
Metals									
Lead	24.2	1	1.0	µg/L	10/24/25 17:41	10/24/25 17:41	KT1	EPA 200.8 (Dig)/EPA 200.8	
Sample: LVT-1363									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:11	10/24/25 14:11	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1364									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:11	10/24/25 14:11	DAZ	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062556693**LIMS Reference ID:** ED56693**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: Jonas E. Salk Middle School: 3359 Old Jerusalem Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:46
Reported: 11/26/2025 08:53

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1364 (Continued)									
Metals (Continued)									
Lead	3.5	1	1.0	µg/L	10/24/25 14:13	10/24/25 14:13	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-1585									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:14	10/24/25 14:14	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2295									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:15	10/24/25 14:15	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2486									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:16	10/24/25 14:16	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2494									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:18	10/24/25 14:18	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2517									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:19	10/24/25 14:19	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2519									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 14:20	10/24/25 14:20	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2520									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 16:09	10/24/25 16:09	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2521									
Metals									
Lead	< 1.0	1	1.0	µg/L	10/24/25 16:09	10/24/25 16:09	JH	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062556693

LIMS Reference ID: ED56693

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: Jonas E. Salk Middle School: 3359 Old Jerusalem Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:46
Reported: 11/26/2025 08:53

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2521 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 10/24/25 16:13 10/24/25 16:13 JH EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2791 Lims Reference ID: ED56693-26 Matrix: Drinking Water Sampled: 10/02/25 08:33:00									
Metals									
Lead < 1.0 1 1.0 µg/L 10/24/25 16:14 10/24/25 16:14 JH EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2792 Lims Reference ID: ED56693-27 Matrix: Drinking Water Sampled: 10/02/25 08:34:00									
Metals									
Lead 1.3 1 1.0 µg/L 10/24/25 16:16 10/24/25 16:16 JH EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2793 Lims Reference ID: ED56693-28 Matrix: Drinking Water Sampled: 10/02/25 08:34:00									
Metals									
Lead < 1.0 1 1.0 µg/L 10/24/25 16:19 10/24/25 16:19 JH EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2794 Lims Reference ID: ED56693-29 Matrix: Drinking Water Sampled: 10/02/25 08:46:00									
Metals									
Lead < 1.0 1 1.0 µg/L 10/24/25 16:21 10/24/25 16:21 JH EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2795 Lims Reference ID: ED56693-30 Matrix: Drinking Water Sampled: 10/02/25 08:52:00									
Metals									
Lead < 1.0 1 1.0 µg/L 10/24/25 16:22 10/24/25 16:22 JH EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2796 Lims Reference ID: ED56693-31 Matrix: Drinking Water Sampled: 10/02/25 09:10:00									
Metals									
Lead < 1.0 1 1.0 µg/L 10/24/25 16:23 10/24/25 16:23 JH EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2797 Lims Reference ID: ED56693-32 Matrix: Drinking Water Sampled: 10/02/25 09:18:00									
Metals									
Lead < 1.0 1 1.0 µg/L 10/24/25 16:25 10/24/25 16:25 JH EPA 200.8 (DA)/EPA 200.8									
Sample: LVT-2798 Lims Reference ID: ED56693-33 Matrix: Drinking Water Sampled: 10/02/25 09:18:00									
Metals									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556693

LIMS Reference ID: ED56693

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Jonas E. Salk Middle School: 3359 Old Jerusalem Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:46
Reported: 11/26/2025 08:53

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: LVT-2798 (Continued) **Lims Reference ID:** ED56693-33 **Matrix:** Drinking Water **Sampled:** 10/02/25 09:18:00

Metals (Continued)

Lead	< 1.0	1	1.0	µg/L	10/24/25 16:26	10/24/25 16:26	JH	EPA 200.8 (DA)/EPA 200.8
------	-------	---	-----	------	----------------	----------------	----	--------------------------

Sample: LVT-2826 **Lims Reference ID:** ED56693-34 **Matrix:** Drinking Water **Sampled:** 10/02/25 06:45:00

Metals

Lead	< 1.0	1	1.0	µg/L	10/24/25 16:27	10/24/25 16:27	JH	EPA 200.8 (DA)/EPA 200.8
------	-------	---	-----	------	----------------	----------------	----	--------------------------

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556693

LIMS Reference ID: ED56693

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Jonas E. Salk Middle School: 3359 Old Jerusalem Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:46
Reported: 11/26/2025 08:53

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556693

LIMS Reference ID: ED56693

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Jonas E. Salk Middle School: 3359 Old Jerusalem Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:46
Reported: 11/26/2025 08:53

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56094

JCB #: 23-53783

Building: Summit Lane Elementary School

SLE

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0496	SP	0001	Basement Break Room	KC	10/2/2025	8:43:00 AM
LVT-0538	KI	1024	Kitchen	SA	10/2/2025	8:50:00 AM
LVT-0607	FL	1056	Faculty Room	KC	10/2/2025	9:01:00 AM
LVT-0649	NO	1057A	Nurse's Office	NS	10/2/2025	8:59:00 AM
LVT-0652	KI	1053C	Main Office Corridor Closet	KC	10/2/2025	8:58:00 AM
LVT-2267	NO	1057C	Nurses Office Large Exam/Sick Room	BWC	10/2/2025	9:00:00 AM
LVT-2272	KI	1024	Kitchen	KC	10/2/2025	8:46:00 AM
LVT-2273	KI	1024	Kitchen	KC	10/2/2025	8:47:00 AM
LVT-2274	KI	1024	Kitchen	KC	10/2/2025	8:48:00 AM
LVT-2361	OF	1057C	Nurses Office Large Exam/Sick Room	BWH	10/2/2025	9:00:00 AM
LVT-2503	HA	1023	Corridor Library-Room 310 (Outside Room 301)	WF	10/2/2025	8:45:00 AM
LVT-2504	HA	1047	Corridor 200 Wing Rooms 200-210 (Outside Room 208)	WF	10/2/2025	8:53:00 AM
LVT-2505	HA	1069	Corridor Exit Vestibule by Room 101 (Outside Room 101)	WF	10/2/2025	9:04:00 AM
LVT-2525	CA	1025	Cafeteria	WF	10/2/2025	8:51:00 AM
LVT-2526	HA	1031	Corridor Outside Gym (Outside Copy Room)	WF	10/2/2025	8:52:00 AM
LVT-2808	KI	1024	Kitchen	SN	10/2/2025	RECEIVED 8:48:00 AM

ENSL ANALYTICAL, INC.

Carle Place, NY

OCT 22 25, PM 02:41

Pb 200.8
10/22/25 10/23/25

Building Address

4 Summit Lane

Levittown, NY 11756

Analysis Type: ELAP 200.5


Lab Received: 10/22/25 14:41

Signature:

Samplers Name: Conner Malanaphy

Samplers Signature: CM

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED56694

Page 2 of 2

JCB #: 23-53783
Building: Summit Lane Elementary School
SLE

Client: Levittown Union Free School District
Retest/New Install:
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 16

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
OCT 22 25, PM02:41


Pb 200.8
Kathleen 10/28/25

Building Address

4 Summit Lane
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: 10/22/25 14:41

Signature: 

Samplers Name: Connor McManamy

Samplers Signature: CM

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062556694**LIMS Reference ID:** ED56694**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: Summit Lane Elementary School: 4 Summit Lane, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:41
Reported: 11/26/2025 08:56

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0496									
Metals									
Lead	2.9		1	1.0	µg/L	10/28/25 16:33	10/28/25 16:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0538									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:34	10/28/25 16:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0607									
Metals									
Lead	2.0		1	1.0	µg/L	10/28/25 16:36	10/28/25 16:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0649									
Metals									
Lead	4.0		1	1.0	µg/L	10/28/25 16:38	10/28/25 16:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-0652									
Metals									
Lead	25.5		1	1.0	µg/L	10/28/25 16:39	10/28/25 16:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2267									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:41	10/28/25 16:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2272									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:42	10/28/25 16:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2273									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:47	10/28/25 16:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2274									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:48	10/28/25 16:48	KT1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556694**LIMS Reference ID:** ED56694**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Summit Lane Elementary School: 4 Summit Lane, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:41
Reported: 11/26/2025 08:56

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2274 (Continued)									
Metals (Continued)									
Lead	1.4		1	1.0	µg/L	10/28/25 16:51	10/28/25 16:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2361									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:53	10/28/25 16:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2503									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:54	10/28/25 16:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2504									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:56	10/28/25 16:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2505									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:58	10/28/25 16:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2525									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 16:59	10/28/25 16:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2526									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:01	10/28/25 17:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2808									
Metals									
Lead	< 1.0		1	1.0	µg/L	10/28/25 17:02	10/28/25 17:02	KT1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556694

LIMS Reference ID: ED56694

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Summit Lane Elementary School: 4 Summit Lane, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:41
Reported: 11/26/2025 08:56

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556694

LIMS Reference ID: ED56694

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Summit Lane Elementary School: 4 Summit Lane, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 10/22/2025 14:41
Reported: 11/26/2025 08:56

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED56988

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

JCB #:

23-53783

Building: Little Red School House

LRS

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2901	HA	1000	Main Entrance Corridor	WF	11/1/2025	9:55:00 AM

Samples Submitted 1

Pb 200.8 Bldg 11/12/25

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

NOV 05 25, PM01:51

Courier

Building Address

Sand Hill Road & Wantagh Ave
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: Abigail Minnfield

Signature: A. Minnfield

11/5/25 1:51pm

Samplers Name: Conor Malanphy

Samplers Signature: Conor Malanphy

JCB Project Manager: Anthony Lombardo



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556988

LIMS Reference ID: ED56988

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 , Little Red School House, LRS , Levittown Union Free School District, Sand Hill Road & Wantagh Ave, Levittown NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 08:57

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2901									Lims Reference ID: ED56988-01 Matrix: Drinking Water Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 13:05	11/12/25 13:05	BP	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556988

LIMS Reference ID: ED56988

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 , Little Red School House, LRS , Levittown Union Free School District, Sand Hill Road & Wantagh Ave, Levittown NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 08:57

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556988

LIMS Reference ID: ED56988

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 , Little Red School House, LRS , Levittown Union Free School District, Sand Hill Road & Wantagh Ave, Levittown NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 08:57

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody For

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53783

Building: New Building next to Transportation Office

Page 1 of 1

Client:

Levittown Union Free School District

Turn Around: Normal (1wk) Rush

23/02/9

Building Address

Analysis Type: ELAP 200.5

Lab Received-

Signature-

ELAP 200.5

11/5/20
1:51 PM

Samplers Name: Connor Malenaphy

Samplers Signature: Conor Malin

JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556989**LIMS Reference ID:** ED56989**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#23-53783, New Building Next to Transportation Office, Levittown Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 08:57

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1442									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/08/25 12:42	11/08/25 12:42	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1443									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/08/25 12:44	11/08/25 12:44	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2827									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/08/25 12:45	11/08/25 12:45	JH	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556989

LIMS Reference ID: ED56989

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#23-53783, New Building Next to Transportation Office, Levittown Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 08:57

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556989

LIMS Reference ID: ED56989

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#23-53783, New Building Next to Transportation Office, Levittown Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 08:57


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53783
Building: B&G Transportation Offices
BGT

ED56990

Page 1 of 1

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1438	KI	1004	Kitchen	KC	11/1/2025	7:52:00 AM
LVT-2895	KI	1004	Kitchen	BWC	11/1/2025	7:53:00 AM
LVT-2896	KI	1004	Kitchen	BWH	11/1/2025	7:53:00 AM

Samples Submitted 3

RECEIVED

ENSL ANALYTICAL, INC.

Carle Place, NY

NOV 05 25, PM01:52

Pb 200.8 Blng 11/12/25

Courier

Building Address
850 Seaman Neck Road
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: Sen Celi 11/5/25
Signature: VM Celi 11/5/25

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardo



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556990

LIMS Reference ID: ED56990

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 850 Seaman Neck Road Levittown NY 11756, B&G Transportation Offices, JCB#23-53783, Levittown Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:52
Reported: 11/26/2025 08:58

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1438									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 13:09	11/12/25 13:09	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2895									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 13:10	11/12/25 13:10	BP	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2896									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 13:11	11/12/25 13:11	BP	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556990

LIMS Reference ID: ED56990

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 850 Seaman Neck Road Levittown NY 11756, B&G
Transportation Offices, JCB#23-53783, Levittown
Union Free School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 11/05/2025 13:52

Reported: 11/26/2025 08:58

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556990

LIMS Reference ID: ED56990

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 850 Seaman Neck Road Levittown NY 11756, B&G
Transportation Offices, JCB#23-53783, Levittown
Union Free School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 11/05/2025 13:52

Reported: 11/26/2025 08:58


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53783
Building: B&G Office
BGO

ED56991

Page 1 of 1

Client: Levittown Union Free School District
Retest/New Install:
Turn Around: Normal 1 wk Rush

11/05/2008
BRODERICK

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1412	HA	1003	Parts Storage Room	IM	11/1/2025	7:37:00 AM
LVT-1415	FL	1017	Break Room	KC	11/1/2025	7:01:00 AM
LVT-1417	HA	1019	Lobby	WF	11/1/2025	7:04:00 AM
LVT-1418	KI	1018	Ladies Bathroom Entrance	KC	11/1/2025	7:35:00 AM
LVT-1419	KI	1018	Ladies Bathroom Entrance	SN	11/1/2025	7:35:00 AM
LVT-2892	FL	1017	Break Room	SN	11/1/2025	7:01:00 AM
LVT-2893	SP	1003	Parts Storage Room	BWC	11/1/2025	7:38:00 AM
LVT-2894	SP	1003	Parts Storage Room	BWH	11/1/2025	7:38:00 AM

Samples Submitted 8

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 05 25, PM01:52

Courier

Building Address
850 Seaman Neck Road
Levittown, NY 11756

Analysis Type: ELAP 200.5
Lab Received: Seen 9/11/11 11/5/25
Signature: M. L 1:52 PM
Samplers Name: Conor Malanaphy
Samplers Signature: Conor Malanaphy
JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556991**LIMS Reference ID:** ED56991**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 850 Seaman Neck Road Levittown NY 11756, B&G Office, JCB#23-53783, Levittown Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:52
Reported: 11/26/2025 08:58

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1412									
Metals									
Lead									
Sample: LVT-1415									
Metals									
Lead									
Sample: LVT-1417									
Metals									
Lead									
Sample: LVT-1418									
Metals									
Lead									
Sample: LVT-1419									
Metals									
Lead									
Sample: LVT-2892									
Metals									
Lead									
Sample: LVT-2893									
Metals									
Lead									
Sample: LVT-2894									
Metals									
Lead									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556991

LIMS Reference ID: ED56991

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 850 Seaman Neck Road Levittown NY 11756, B&G Office, JCB#23-53783, Levittown Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:52
Reported: 11/26/2025 08:58

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062556991

LIMS Reference ID: ED56991

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 850 Seaman Neck Road Levittown NY 11756, B&G
Office, JCB#23-53783, Levittown Union Free School
District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:52
Reported: 11/26/2025 08:58

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57001

JCB #: 23-53783

Building: Levittown Memorial Education Center
LMEC

Client:

Levittown Union Free School District

Retest/New Install
Turn Around: Normal 1 wk Rush

Page 1 of 2

Courier

2008
Kotulski 11/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1792	HA	0029	Corridor Room 5 to Custodial Area	WF	11/1/2025	10:12:00 AM
LVT-1793	NO	0028	Room 2 Nurse Office	NS	11/1/2025	10:13:00 AM
LVT-1811	KI	1021	Room 101 Kitchen	KC	11/1/2025	10:15:00 AM
LVT-1824	FL	1017	Room 100	KC	11/1/2025	10:19:00 AM
LVT-1827	CR	1011	Room 110	KC	11/1/2025	10:21:00 AM
LVT-1828	CR	1011	Room 110	SN	11/1/2025	10:21:00 AM
LVT-1854	CR	1034	Fitness Room 206	KC	11/1/2025	10:25:00 AM
LVT-1894	SP	1073A	Room 422A	KC	11/1/2025	10:36:00 AM
LVT-1895	FL	1086A	Room 409 Kitchen/Conference	KC	11/1/2025	10:56:00 AM
LVT-1900	KI	1097	Room 401	KC	11/1/2025	10:45:00 AM
LVT-1903	KI	1097	Room 401	KC	11/1/2025	10:44:00 AM
LVT-1913	OF	1098A	Superintendent Office Conference Room	KC	11/1/2025	10:42:00 AM
LVT-2493	HA	1039D	Room 209 Wood Shop	WF	11/1/2025	10:51:00 AM
LVT-2510	ST	1039D3	Room 209 Wood Shop Locker Room	IM	11/1/2025	10:50:00 AM
LVT-2518	HA	1092	Corridor Auditorium To Lobby (Outside Room 414)	WF	11/1/2025	10:40:00 AM
LVT-2843	HA	1041	Corridor Outside Gymnasium	WF	11/1/2025	10:26:00 AM
LVT-2844	OF	1047	Room 318	BWC	11/1/2025	10:28:00 AM
LVT-2848	OF	1061	Room 304	BWC	11/1/2025	10:32:00 AM

100-9525-PH01-55
Cable Place, NY
RECEIVED
FACILITY

Building Address

150 Abbey Lane
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: AStanley 11/5/25

Signature:  1:55pm

Samplers Name: Conor Malanuphy

Samplers Signature: Conor Malanuphy

JCB Project Manager: Anthony Lamberdo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57001

Page 2 of 2

JCB #: 23-53783
Building: Levittown Memorial Education Center
LMEC

Client: Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2849	OF	1061	Room 304	BWH	11/1/2025	10:32:00 AM
LVT-2853	OF	1071	Room 420	KC	11/1/2025	10:37:00 AM
LVT-2854	OF	1071	Room 420	BWC	11/1/2025	10:34:00 AM
LVT-2855	OF	1071	Room 420	BWH	11/1/2025	10:34:00 AM
LVT-2903	OF	1024	Room 109	BWC	11/1/2025	10:17:00 AM
LVT-2904	OF	1024	Room 109	BWH	11/1/2025	10:17:00 AM


Samples Submitted 24

PC/2025
11/05/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 05 25, PM 01:54

Building Address
150 Abbey Lane
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: ASTanley 11/05/25
Signature:  1:55pm

Samplers Name: Connor Malarkey
Samplers Signature: 
JCB Project Manager: Anthony Lombardo

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557001**LIMS Reference ID:** ED57001**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Levittown Memorial Education Center, LMEC, 150 Abbey Lane Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:55
Reported: 11/26/2025 08:59

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1792									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 15:30	11/12/25 15:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1793									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 15:34	11/12/25 15:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1811									
Metals									
Lead	6.8		1	1.0	µg/L	11/12/25 15:35	11/12/25 15:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1824									
Metals									
Lead	8.0		1	1.0	µg/L	11/12/25 15:36	11/12/25 15:36	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1827									
Metals									
Lead	22.2		1	1.0	µg/L	11/12/25 15:40	11/12/25 15:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1828									
Metals									
Lead	4.7		1	1.0	µg/L	11/12/25 15:41	11/12/25 15:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1854									
Metals									
Lead	5.1		1	1.0	µg/L	11/12/25 15:43	11/12/25 15:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1894									
Metals									
Lead	13.7		1	1.0	µg/L	11/12/25 15:44	11/12/25 15:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1895									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557001**LIMS Reference ID:** ED57001**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Levittown Memorial Education Center, LMEC, 150 Abbey Lane Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:55
Reported: 11/26/2025 08:59

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1895 (Continued)									Sampled: 11/01/25 00:00:00
Metals (Continued)									
Lead	4.5		1	1.0	µg/L	11/12/25 15:45	11/12/25 15:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1900									Sampled: 11/01/25 00:00:00
Metals									
Lead	3.9		1	1.0	µg/L	11/12/25 15:47	11/12/25 15:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1903									Sampled: 11/01/25 00:00:00
Metals									
Lead	141		2	2.0	µg/L	11/12/25 16:06	11/12/25 16:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-1913									Sampled: 11/01/25 00:00:00
Metals									
Lead	4.5		1	1.0	µg/L	11/12/25 15:52	11/12/25 15:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2493									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 15:56	11/12/25 15:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2510									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 15:57	11/12/25 15:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2518									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 15:59	11/12/25 15:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2843									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 16:00	11/12/25 16:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2844									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 16:00	11/12/25 16:00	KT1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557001**LIMS Reference ID:** ED57001**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Levittown Memorial Education Center, LMEC, 150 Abbey Lane Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:55
Reported: 11/26/2025 08:59

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2844 (Continued)									Sampled: 11/01/25 00:00:00
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	11/12/25 16:01	11/12/25 16:01	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2848									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 16:02	11/12/25 16:02	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2849									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 16:04	11/12/25 16:04	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2853									Sampled: 11/01/25 00:00:00
Metals									
Lead	2.5	1	1.0	µg/L	11/12/25 16:05	11/12/25 16:05	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2854									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 15:04	11/12/25 15:04	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2855									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 15:06	11/12/25 15:06	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2903									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 15:07	11/12/25 15:07	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2904									Sampled: 11/01/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 15:08	11/12/25 15:08	KT1	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557001

LIMS Reference ID: ED57001

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Levittown Memorial Education Center, LMEC, 150 Abbey Lane Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:55
Reported: 11/26/2025 08:59

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557001

LIMS Reference ID: ED57001

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District,
Levittown Memorial Education Center, LMEC, 150
Abbey Lane Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:55
Reported: 11/26/2025 08:59

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

ED57003

Page 1 of 1

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53783
Building: B&G Bus Garage
BUS

Levittown Union Free School District
Retest/New Install
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1432	LR	1000	Locker Room	WC	11/1/2025	8:22:00 AM
LVT-2899	LR	1000	Locker Room	BWC	11/1/2025	8:23:00 AM
LVT-2900	LR	1000	Locker Room	BWH	11/1/2025	8:24:00 AM

Samples Submitted 3

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

NOV 05 25, PM01:51

Courier

Building Address

850 Seaman Neck Road
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: Abigail Minnifield

Signature: *A. Minnifield*

11/5/25 1:51pm

*Recd Pb 200.5
11/12/25*

Samplers Name: *Conor Malunaply*

Samplers Signature: *Conor Malunaply*

JCB Project Manager: *Anthony Lombardo*

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557003**LIMS Reference ID:** ED57003**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 , B&G Bus Garage, BUS, Levittown Union Free School Distict, 850 Seaman Neck Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 09:00

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1432									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/12/25 02:47	11/12/25 02:47	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2899									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 18:11	11/14/25 18:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2900									
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 18:12	11/14/25 18:12	KT1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557003

LIMS Reference ID: ED57003

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 , B&G Bus Garage, BUS, Levittown Union Free School Distict, 850 Seaman Neck Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 09:00

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557003

LIMS Reference ID: ED57003

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783 , B&G Bus Garage, BUS, Levittown Union Free School Distict, 850 Seaman Neck Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:51
Reported: 11/26/2025 09:00

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

ED57000

Page 1 of 2

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53783
Building: Seaman Neck Middle School
SEA

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Courier

16 2008 Blng 11/12/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2127	OF	1030A	Thinking Room 1 Resource Room	KC	11/1/2025	9:30:00 AM
LVT-2153	NO	1000	Nurse's Office	NS	11/1/2025	9:18:00 AM
LVT-2156	HE	1002B	K2 Kitchen/Classroom	EC	11/1/2025	9:22:00 AM
LVT-2159	KI	1034	Kitchen	KC	11/1/2025	9:00:00 AM
LVT-2160	KI	1034	Kitchen	KC	11/1/2025	8:58:00 AM
LVT-2161	KI	1034	Kitchen	KC	11/1/2025	8:58:00 AM
LVT-2162	KI	1034	Kitchen	SN	11/1/2025	8:58:00 AM
LVT-2164	CA	1035	Cafeteria	WC	11/1/2025	9:01:00 AM
LVT-2172	HE	1051	Room 302	EC	11/1/2025	9:14:00 AM
LVT-2174	HE	1050	Room 301	EC	11/1/2025	9:13:00 AM
LVT-2175	HE	1050	Room 301	EC	11/1/2025	9:12:00 AM
LVT-2177	HA	1054	Corridor Outside Gymnasium adj. Gymnasium Entrance	DW	11/1/2025	9:11:00 AM
LVT-2180	HA	1054	Corridor Outside Gymnasium near Gang Bathrooms	DW	11/1/2025	9:07:00 AM
LVT-2386	KI	1034	Kitchen	KC	11/1/2025	8:57:00 AM
LVT-2874	HA	1012	Corridor Men's Bathroom To Principal's Office adj. Bathrooms	WF	11/1/2025	8:55:00 AM
LVT-2875	HA	1012	Corridor Men's Bathroom To Principal's Office adj. Bathrooms	WC	11/1/2025	8:55:00 AM
LVT-2880	FL	1036	Faculty Room	KC	11/1/2025	9:06:00 AM

Building Address

1100 Crestline Place
Seaford, NY 11783

Analysis Type: ELAP 200.5

Lab Received: A Stanley

Signature:

11/15/25

1:54pm

Samplers Name: Connor Malaniphy

Samplers Signature:

JCB Project Manager: Anthony Lombardo



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57000

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
			SEA		Samples Submitted	17

Samples Submitted 17

PL 2008 Bldg 11/12/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 05 25, PM01:54

Building Address
1100 Crestline Place
Seaford, NY 11783

Analysis Type: ELAP 200.5

Lab Received: A Stanley 11/5/25
Signature: Conor Malanaphy 1:54pm

Samplers Name: Conor Malanaphy

Samplers Signature: Conor Malanaphy

JCB Project Manager: Anthony Lombardi

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557006**LIMS Reference ID:** ED57006**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Seaman Neck Middle School , SEA, 1100 Crestline Place Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:54
Reported: 11/26/2025 09:01

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2127									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:06	11/12/25 12:06	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2153									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:10	11/12/25 12:10	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2156									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:11	11/12/25 12:11	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2159									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:15	11/12/25 12:15	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2160									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:16	11/12/25 12:16	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2161									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:17	11/12/25 12:17	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2162									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:19	11/12/25 12:19	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2164									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:20	11/12/25 12:20	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2172									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557006**LIMS Reference ID:** ED57006**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Seaman Neck Middle School , SEA, 1100 Crestline Place Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:54
Reported: 11/26/2025 09:01

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2172 (Continued)									
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:21	11/12/25 12:21	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2174									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:23	11/12/25 12:23	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2175									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:24	11/12/25 12:24	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2177									
Metals									
Lead	1.2	1	1.0	µg/L	11/12/25 12:31	11/12/25 12:31	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2180									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:32	11/12/25 12:32	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2386									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:33	11/12/25 12:33	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2874									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:35	11/12/25 12:35	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2875									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:36	11/12/25 12:36	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2880									
Metals									
Lead	< 1.0	1	1.0	µg/L	11/12/25 12:36	11/12/25 12:36	BP	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557006**LIMS Reference ID:** ED57006**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Seaman Neck Middle School , SEA, 1100 Crestline Place Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:54
Reported: 11/26/2025 09:01

**Analytical Results
(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2880 (Continued)									
Metals (Continued)									
Lead									
< 1.0 1 1.0 µg/L 11/12/25 12:37 11/12/25 12:37 BP EPA 200.8 (DA)/EPA 200.8									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557006

LIMS Reference ID: ED57006

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Seaman Neck Middle School , SEA, 1100 Crestline Place Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:54
Reported: 11/26/2025 09:01

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557006

LIMS Reference ID: ED57006

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: 23-53783, Levittown Union Free School District, Seaman Neck Middle School , SEA, 1100 Crestline Place Seaford, NY 11783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/05/2025 13:54
Reported: 11/26/2025 09:01


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

06251 EDS7509

JCB #: 23-53783

Building: Northside Elementary School

NES

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2200	KI	1082	Kitchen	KC	12/3/2025	6:41:00 AM
LVT-2201	KI	1082	Kitchen	SN	12/3/2025	6:42:00 AM

Samples Submitted 2

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

DEC 03 25, PM08:48

Walk In

12/4/25
968008
12/4/25

Building Address

35 Pelican Road

Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: 12/3/25 20:18

Signature: Vivay Warner

Samplers Name: Anthony Lombardo

Samplers Signature: (Signature)

JCB Project Manager: Lombardo Page 4 of 4

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557509**LIMS Reference ID:** ED57509**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Northside Elementary School: 35 Pelican Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/03/2025 20:48
Reported: 12/04/2025 14:41

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2200									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/04/25 14:24	12/04/25 14:24	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2201									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/04/25 14:25	12/04/25 14:25	JH	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557509

LIMS Reference ID: ED57509

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Northside Elementary School: 35 Pelican Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/03/2025 20:48
Reported: 12/04/2025 14:41

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	

Lead 06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557509

LIMS Reference ID: ED57509

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Northside Elementary School: 35 Pelican Road, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/03/2025 20:48
Reported: 12/04/2025 14:41

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492

FAX: (631) 584-3395

ED57510

JCB #:

23-53783

Building: Gardiners Avenue Elementary School

GAE

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-1676	KI	1043C	Kitchen	SA	12/3/2025	6:57:00 AM

Samples Submitted 1

Walk In

PL 800g
12/4/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 03 25, PM08:48

Building Address

610 Gardiners Avenue
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received: 12/3/25 2025

Signature: Rebecca Hayes

Samplers Name: Anthony Lombardo

Samplers Signature: AS

JCB Project Manager: LOMBARDO



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557510

LIMS Reference ID: ED57510

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Gardiners Avenue Elementary School: 610 Gardiners Avenue, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/03/2025 20:48
Reported: 12/04/2025 14:42

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-1676									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/04/25 14:26	12/04/25 14:26	JH	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557510

LIMS Reference ID: ED57510

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Gardiners Avenue Elementary School: 610 Gardiners Avenue, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/03/2025 20:48
Reported: 12/04/2025 14:42

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557510

LIMS Reference ID: ED57510

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: Gardiners Avenue Elementary School: 610 Gardiners Avenue, Levittown, NY 11756: Levittown Union Free School District: Project# 23-53783
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/03/2025 20:48
Reported: 12/04/2025 14:42


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED575 43

Client:

JCB #: 23-53783

Building: New Building next to
Transportation office

Retest/New Install

Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LUT-2905	FL	1000	Common Area	WF	12/5/25	6:20 am

Samples Submitted 1

FEDEX

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 05 25, PM01:27

DEC 05

Building Address

850 Seaford Neck Road
Seaford, NY 11756

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Facile

Samplers Name: Anthony Lombardo

Samplers Signature: *AL*

JCB Project Manager: Lombardo

Page 4 of 4



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557543

LIMS Reference ID: ED57543

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#: 23-53783, New Building next to Transportation Office, 850 Seaman's Neck Road, Seaford, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/05/2025 13:27
Reported: 12/06/2025 12:56

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2905									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/06/25 12:07	12/06/25 12:07	JH	EPA 200.8 (DA)/EPA 200.8	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557543

LIMS Reference ID: ED57543

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#: 23-53783, New Building next to Transportation Office, 850 Seaman's Neck Road, Seaford, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/05/2025 13:27
Reported: 12/06/2025 12:56

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557543

LIMS Reference ID: ED57543

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, New Building next to Transportation Office, 850 Seaman's Neck Road, Seaford, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/05/2025 13:27
Reported: 12/06/2025 12:56


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492

FAX: (631) 584-3395

JCB #:

23-53783

Building: General Douglas MacArthur High School

MAC

ED57544

Page 1 of 1

Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2906	HA	1040	New Gym Lobby o/s Ice Room	WC	12/5/2025	6:28:00 AM

Samples Submitted 1



RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 05 25, PM 01:26

Building Address

3369 Jerusalem Road

Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Anthony Lombardo

Samplers Signature: AL

JCB Project Manager: LOMBARDO Page 4 of 4



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557544

LIMS Reference ID: ED57544

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#: 23-53783, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/05/2025 13:26
Reported: 12/06/2025 12:57

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2906									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/06/25 12:11	12/06/25 12:11	JH	EPA 200.8 (DA)/EPA 200.8	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557544

LIMS Reference ID: ED57544

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/05/2025 13:26
Reported: 12/06/2025 12:57

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557544

LIMS Reference ID: ED57544

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#: 23-53783, General Douglas MacArthur High School, Levittown Union Free School District, 3369 Jerusalem Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/05/2025 13:26
Reported: 12/06/2025 12:57


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-53783
Building: Division Avenue High School
DAH

EDS 7682
Client:

Levittown Union Free School District

Retest/New Install

Turn Around: Normal 1 wk Rush 2 day

Paragon
Courier

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0295	SC	2047A	Room 219 Kitchen	KC	12/12/2025	6:42:00 AM
LVT-0342	HE	1027	Room 125	EC	12/12/2025	6:39:00 AM
LVT-0404	HE	1064	Room 152	SN	12/12/2025	6:46:00 AM
LVT-0407	HE	1064	Room 152	EC	12/12/2025	6:47:00 AM
LVT-0424	OF	1071A	East Cafeteria Office/Maintainer	KC	12/12/2025	6:33:00 AM
LVT-2263	CR	1066	Room 155	KC	12/12/2025	6:48:00 AM

Samples Submitted 6

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 12 25, PM 01:35

PL
12/12/2025
PL/PL

Building Address
120 Division Avenue
Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Anthony Lombardo

Samplers Signature:

JCB Project Manager:

LOMBARDO

Page 4 of 4

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557682**LIMS Reference ID:** ED57682**EMSL Customer ID:** JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, Division Avenue High School,
Levittown Union Free School District, 120 Division
Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/13/2025 13:26

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0295									
Metals									
Lead	2.7	1	1.0	µg/L	12/13/25 12:21	12/13/25 12:21	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0342									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 12:22	12/13/25 12:22	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0404									
Metals									
Lead	1.4	1	1.0	µg/L	12/13/25 12:24	12/13/25 12:24	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0407									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 12:28	12/13/25 12:28	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-0424									
Metals									
Lead	1.2	1	1.0	µg/L	12/13/25 12:32	12/13/25 12:32	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: LVT-2263									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 12:33	12/13/25 12:33	JH	EPA 200.8 (DA)/EPA 200.8	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557682

LIMS Reference ID: ED57682

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, Division Avenue High School,
Levittown Union Free School District, 120 Division
Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/13/2025 13:26

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557682

LIMS Reference ID: ED57682

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#: 23-53783, Division Avenue High School,
Levittown Union Free School District, 120 Division
Avenue, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/13/2025 13:26

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-53783

Building: Laurel Lane School

LLS

Client:


Levittown Union Free School District

Retest/New Install []

Turn Around: Normal 1 wk Rush 2 day

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-2075	OF	1008	Small Kitchen	KC	12/12/2025	7:03:00 AM
LVT-2080	KI	1013	Kitchen	KC	12/12/2025	7:03:00 AM
LVT-2081	KI	1013	Kitchen	KC	12/12/2025	7:02:00 AM

Samples Submitted 3



12/13/25
12/13/25
12/13/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 12 25, PM01:34

Building Address

11 Laurel Lane

Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Anthony Lombardo

Samplers Signature: RL

JCB Project Manager: LOMBARDO

Page 4 of 4

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557683**LIMS Reference ID:** ED57683**EMSL Customer ID:** JCBR50**Attention:** Select Contact - JCBR50

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name:

JCB# 23-53783, Laurel Lane School, Levittown
Union Free School District, 11 Laurel Lane,
Levittown, NY 11756

Project ID:

_06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish
Received: 12/12/2025 13:34
Reported: 12/13/2025 13:27

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-2075									
Metals									
Lead	1.8		1	1.0	µg/L	12/13/25 12:34	12/13/25 12:34	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2080									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/13/25 12:36	12/13/25 12:36	JH	EPA 200.8 (DA)/EPA 200.8
Sample: LVT-2081									
Metals									
Lead	1.4		1	1.0	µg/L	12/13/25 12:37	12/13/25 12:37	JH	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557683

LIMS Reference ID: ED57683

EMSL Customer ID: JCBR50

Attention: Select Contact - JCBR50

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name:

JCB# 23-53783, Laurel Lane School, Levittown
Union Free School District, 11 Laurel Lane,
Levittown, NY 11756

Project ID:

_06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/12/2025 13:34

Reported: 12/13/2025 13:27

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557683

LIMS Reference ID: ED57683

EMSL Customer ID: JCBR50

Attention: Select Contact - JCBR50

J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
elementsupport@emsl.com

Project Name:

JCB#: 23-53783, Laurel Lane School, Levittown
Union Free School District, 11 Laurel Lane,
Levittown, NY 11756

Project ID:

_06 - Carle Place Lead Analyses

Customer PO:

Jeromy Bish

Sales Rep:

12/12/2025 13:34

Received:

12/13/2025 13:27

Reported:

Notes and Definitions

Item**Definition**

(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.



James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492

FAX: (631) 584-3395

JCB #:

23-53783

Building: Northside Elementary School

NES

ED 57686

Page 1 of 1

Client:

Levittown Union Free School District

Retest New Install []

Turn Around: Normal 1 wk. Rush 2 days

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
LVT-0730	FL	1039	Faculty Lounge 531	KC	12/12/2025	6:26:00 AM

Samples Submitted 1

PL
12/13/2008

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 12 25, PM01:34

Building Address

35 Pelican Road

Levittown, NY 11756

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Anthony Lombardo

Samplers Signature: [Signature]

JCB Project Manager: LOMBARDO

Page 4 of 4



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557686

LIMS Reference ID: ED57686

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:34
Reported: 12/13/2025 13:31

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LVT-0730									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 12:41	12/13/25 12:41	JH	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557686

LIMS Reference ID: ED57686

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB# 23-53783, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:34
Reported: 12/13/2025 13:31

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557686

LIMS Reference ID: ED57686

EMSL Customer ID: JCBR50

Attention: Anthony Lombardo
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
alombardo@jcbroderick.com

Project Name: JCB#: 23-53783, Northside Elementary School, Levittown Union Free School District, 35 Pelican Road, Levittown, NY 11756
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:34
Reported: 12/13/2025 13:31

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.


Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Attachment 4:

Laboratory Certifications



J.C. Broderick & Associates, Inc.

Environmental Consulting & Testing

1775 Expressway Drive North

Hauppauge, New York 11788

631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. DANIEL CLARKE
EMSL ANALYTICAL, INC.
528 MINEOLA AVE.
CARLE PLACE, NY 11514

NY Lab Id No: 11469

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C
	SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Heterotrophic Plate Count	SM 20, 21-23 9215B (-04)

Metals I

Copper, Total	EPA 200.8 Rev. 5.4
Lead, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.8 Rev. 5.4

Miscellaneous

Asbestos	EPA 100.2
----------	-----------



Serial No.: 70480

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

